

Manitoba Hydro Undertaking #39

Manitoba Hydro to advise the board whether, since Lake Winnipeg regulation (1976), MH hydraulic generation exceeded domestic load in every year except 03/04.

Since Lake Winnipeg regulation began in 1976, total Manitoba hydraulic generation has exceeded Manitoba firm domestic load in all fiscal years except 1988/89 and 2003/04. This is indicated in the following table.

Fiscal Year Beginning	Total Hydraulic Generation (TWh)	Manitoba Firm Load (TWh)	Difference (TWh)
1976	12.1	11.8	0.3
1977	12.3	12.0	0.4
1978	18.6	12.5	6.1
1979	20.7	12.8	7.9
1980	18.5	12.5	6.0
1981	17.7	13.5	4.2
1982	21.6	13.3	8.3
1983	21.9	14.4	7.5
1984	21.0	15.0	6.0
1985	23.2	15.4	7.8
1986	24.0	15.5	8.5
1987	18.0	16.3	1.8
1988	15.2	17.1	-1.9
1989	18.7	17.3	1.4
1990	20.6	17.6	3.0
1991	23.6	17.7	5.9
1992	27.6	17.9	9.7
1993	27.2	18.1	9.1
1994	27.9	17.8	10.1
1995	29.1	19.0	10.1
1996	31.7	19.2	12.4
1997	33.8	19.1	14.7
1998	29.1	19.4	9.7
1999	29.5	19.1	10.4
2000	31.8	20.1	11.7
2001	32.2	20.5	11.6
2002	28.6	22.0	6.6
2003	18.5	21.9	-3.4
2004	31.1	22.5	8.7
2005	37.2	22.6	14.6
2006	31.6	23.3	8.3
2007	34.9	24.0	10.9
2008	34.2	24.3	9.9
2009	33.8	23.3	10.5