

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 1, Section 1.4.2.4 Annual Planning Cycle at 20:14-21:6**

4

5 **PREAMBLE:** Referring to Chapter 1, Section 1.4.2.4, "the capital expenditure forecast
6 (CEF) incorporates the assumptions related to new long-term generation and
7 transmission resources required, as well as expenditures required to sustain the existing
8 infrastructure and to meet safety, regulatory and reliability requirements."

9

10 **QUESTION:**

11 Please describe why the Bipole III transmission project was included in all of the alternatives
12 studied, and provide all cost documentation concerning the costs to deliver under each of the
13 alternatives.

14

15 **RESPONSE:**

16 Bipole III is included in all of the alternatives studied because it is an approved project which is
17 proceeding regardless of the decision as to which of the NFAT development plans are pursued.

18

19 The Bipole III costs are equal for the NFAT plans and are provided on page 29 of IFF12 which is
20 provided in the NFAT Business Case, Appendix – Corporate Documents, Appendix A, IFF 2012.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Sections 2.1.2.3 at 14:1-6 and 2.2.2.2 at 43:6-13 and 2.3.1 at**
4 **53:17-54:16.**

5


6 **QUESTION:**

7 Referring to the descriptions of the transmission projects relating to each of Keeyask and
8 Conawapa as contained in Chapter 2, please provide one-line or geographic diagrams
9 illustrating the transmission lines in the northern Nelson area today, after construction of
10 Bipole III, and after construction of the North-South Transmission Project.

11


12 **RESPONSE:**

13 The conceptual single line diagrams of the northern collector system upgrades and northern ac
14 system upgrades for the Manitoba Hydro preferred development plan are shown below.



15

1



2

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.2.2.2 at 43:6-13**

4

5 **QUESTION:**

6 What is the expected or actual in-service dates of the Riel and Keewatinoow Converter Stations,
7 and what will the initial and ultimate capability be of each converter station?

8

9 **RESPONSE:**

10 The in-service date for the Bipole III Converter Stations is currently October 2017.

11 The capability of each Converter Station is 2000 MW for the DC Equipment.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.2.2.2 at 43:6-13**

4

5 **QUESTION:**

6 What events, projects, and/or policies will result in changes to the initial and/or ultimate
7 capability of the Riel and Keewatinoow Converter Stations? Please quantify each such change in
8 capability, including the anticipated costs.

9

10 **RESPONSE:**

11 There is no event anticipated that could cause a change in the capability of the Bipole III
12 Converter Stations.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.2.2.2 at 43:6-13**

4

5 **QUESTION:**

6 How much will each of the Keewatinoow and Riel Converter Stations cost, and are any of these
7 costs allocated to the costs for the Keeyask and/or Conawapa Generating Stations?

8

9 **RESPONSE:**

10 The in-service cost for the Bipole III Converter Stations is \$1.83 billion. No costs from the Bipole
11 III project have been allocated to the Keeyask and/or Conawapa Generating Station projects.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.2.3.1 at 46:18.**

4

5 **QUESTION:**

6 What are the costs of upgrading PR280, and have these costs been included in the total cost for
7 the Keeyask project? If not, why not?

8

9 **RESPONSE:**

10 The portion of the costs associated with upgrading PR280 that is applicable to the Keeyask
11 Project has been included in the total cost for the project. The estimated costs of this work is
12 commercially sensitive information and cannot be publicly disclosed prior to completion of the
13 tendering process.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 15, Figure 15.4**

4

5 **QUESTION:**

6 What are the costs of upgrading PR290, and have these costs been included in the total cost for
7 the Conawapa project? If not, why not?

8

9 **RESPONSE:**

10 The costs of upgrading relevant sections of PR280 and PR290 as applicable to Conawapa have
11 been included. These are (in 2012\$):

12 • PR280 \$0.023B

13 • PR290 \$0.017B

14 Please refer to MMF/MH II-004c for more detail.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.3 at 53:6-12.**

4

5 **QUESTION:**

6 Please explain whether the North-South Transmission System Upgrade Project is necessary if
7 only the Keeyask Generating Station is built.

8

9 **RESPONSE:**

10 The North-South Transmission System Upgrade Project is required only for development plans
11 that include both Keeyask and Conawapa. If Keeyask is built first, then the North-South
12 Transmission System Upgrade Project will be required when Conawapa comes in service.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.3 at 53:6-12**

4

5 **PREAMBLE:** The economic risk associated with energy that can or cannot be delivered
6 to MISO depends upon the ability of the proposed transmission upgrades

7

8 **QUESTION:**

9 Please provide all transmission studies related to the ability of Manitoba Hydro's transmission
10 system to deliver energy from Keeyask and Conawapa, including but not limited to contingency
11 analyses, the critical contingencies examined, the associated N-1, N-1-1 and N-2 transfer
12 capabilities, and the extent to which exports to the U.S. were assumed in these studies.

13

14 **RESPONSE:**

15

16 The response to this information request would require the disclosure of commercially sensitive
17 information.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.3 at 53:6-12**

4

5 **PREAMBLE:** The economic risk associated with energy that can or cannot be delivered
6 to MISO depends upon the ability of the proposed transmission upgrades

7

8 **QUESTION:**

9 How much of Keeyask and Conawapa capacity can be transmitted over the existing HVDC
10 system?

11

12 **RESPONSE:**

13 No firm capacity is available to transfer power from Keeyask or Conawapa over the existing
14 HVDC system.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.3 at 53:6-12.**

4

5 **PREAMBLE:** The economic risk associated with energy that can or cannot be delivered
6 to MISO depends upon the ability of the proposed transmission upgrades

7

8 **QUESTION:**

9 How much of Keeyask and Conawapa capacity can be transmitted over the HVDC system after
10 construction of Bipole III?

11

12 **RESPONSE:**

13 Please refer to the response to PUB-MH II-492b. Under normal operating conditions, without
14 the North-South Transmission System Upgrade Project, about 1200 MW power of Keeyask and
15 Conawapa may be transmitted over the HVdc system after the construction of Bipole III to
16 respect the 4750 MW stability limit. Up to 1700MW power could be transferred on the HVdc
17 system with completion of the HVDC collector system upgrades (part of the North-South
18 Transmission System Upgrade Project).

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.3 at 53:6-12.**

4

5 **PREAMBLE:** The economic risk associated with energy that can or cannot be delivered
6 to MISO depends upon the ability of the proposed transmission upgrades

7

8 **QUESTION:**

9 How much of Keeyask and Conawapa capacity can be transmitted over the HVDC system after
10 construction of Bipole III and the North-South Transmission Upgrades?

11

12 **RESPONSE:**

13 With the completion of Keeyask Transmisison project (section 2.1.2.3 of the NFAT submission),
14 Conawapa Transmission project (section 2.2.2.2 of the NFAT submission), and the North-south
15 Transmission System upgrade project (section 2.3), all of the Keeyask and Conawapa power
16 can be transmitted over the HVdc system under normal operating conditions.

17

Please refer to the response to PUB/MH I-192 and CAC/MH I-014a.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.3.1 at 53:18-54:3.**

4

5 **PREAMBLE:** The economic risk associated with energy that can or cannot be delivered
6 to MISO depends upon the ability of the proposed transmission upgrades

7

8 **QUESTION:**

9 Are the HVdc collector system upgrades referred to in Section 2.3.1 required under all
10 alternatives studied in the NFAT?

11

12 **RESPONSE:**

13 The HVdc collector system upgrades will be required for the alternatives requiring the
14 development of both Keeyask and Conawapa Generating Stations.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.3.1 at 53:18-54:3**

4

5 **PREAMBLE:** The economic risk associated with energy that can or cannot be delivered
6 to MISO depends upon the ability of the proposed transmission upgrades

7

8 **QUESTION:**

9 Please provide all studies that illustrate the need for these HVDC collector system upgrades,
10 including all assumptions, contingency analyses, N-1, N-1-1 and N-2 transfer capabilities.

11

12 **RESPONSE:**

13 The response to this Information Request would require disclosure of Commercially Sensitive
14 Information.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.3.1 at 54:5-16**

4

5 **PREAMBLE:** The economic risk associated with energy that can or cannot be delivered
6 to MISO depends upon the ability of the proposed transmission upgrades

7

8 **QUESTION:**

9 Please provide all studies analyzing the need for the required AC upgrades listed as part of the
10 North-South Transmission Upgrades, including all assumptions, contingency analyses, N-1, N-1-
11 1, N-2 transfer capabilities, and forecasted exports.

12

13 **RESPONSE:**

14 The response to this Information Request would require the disclosure of Commercially
15 Sensitive Information.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.3.1 at 54:5-16.**

4

5 **PREAMBLE:** The economic risk associated with energy that can or cannot be delivered
6 to MISO depends upon the ability of the proposed transmission upgrades

7

8 **QUESTION:**

9 Are the AC upgrades associated with the North-South Transmission Upgrades necessary under
10 all alternatives, or only those alternatives including Conawapa?

11

12 **RESPONSE:**

13 The AC upgrades associated with the North South Transmission Upgrades are only necessary in
14 development plans that include both Keeyask and Conawapa.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 2, Section 2.3.2 at 56:6-7.**

4

5 **PREAMBLE:** The Manitoba-Minnesota Transmission Project will enable power to be
6 exported to the United States based on current sales agreements, improve reliability
7 and import capacity based on emergency and drought situations, and increase access to
8 markets in the U.S.

9

10 **QUESTION:**

11 Please provide all transmission studies and analyses of the proposed Manitoba-Minnesota
12 Transmission Project, either at 250 MW or 750 MW, including all assumptions, contingency
13 analyses, N-1, N-1-1 and N-2 transfer capabilities, that illustrate the specific reliability benefits
14 of the project.

15

16 **RESPONSE:**

17 Manitoba Hydro has completed a preliminary transmission study that analyzes the impact of
18 both a 250 MW and 750 MW Transmission Project. This report contains commercially sensitive
19 information and cannot be provided on the public record.

20

21 The report demonstrates that the proposed projects meet the NERC TPL standards in terms of
22 contingency analysis. The calculated incremental increase in Transfer Capability of 250 MW or
23 750 MW is based on system intact conditions and the ability to meet performance criteria
24 following N-1, N-1-1 and N-2 contingencies. The Transfer Capability for various prior outage
25 conditions are calculated in seasonal operating studies. The first such study for the proposed
26 Transmission Project would not be performed until 6-12 months prior to the inservice date. The
27 availability of the Manitoba to U.S. interface has been historically very high (>95-98%) over the
28 critical summer export period (May to August).

- 1 The reliability benefit of the 250 MW and 750 MW Transmission Project in terms of improved
- 2 loss of load capability has been demonstrated in the NFAT Reliability Report attached to the
- 3 NFAT submission as Appendix 13.1.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Appendix 13.1 at 2**

4

5 **QUESTION:**

6 Referring to the NFAT Reliability Evaluation , please provide the actual transmission studies
7 performed in evaluating each alternative and all related documents. If the studies are not
8 available, please provide the underlying assumptions, including what transmission facilities
9 were included or excluded in each Alternative evaluated, and the results of contingency
10 analyses.

11

12 **RESPONSE:**

13 As described on Page 2 of the NFAT Reliability Evaluation (located in Appendix 13.1 of the NFAT
14 submission), the following alternative development plans were evaluated:

- 15 1. Preferred Plan: Keeyask, Conawapa, 750 MW Manitoba-U.S. tie line and a 245 MW SCGT
- 16 2. All Gas: Four 245 MW SCGT and three 357 MW CCGT
- 17 3. Keeyask Gas: Keeyask, two 245 MW SCGT and three 357 MW CCGT
- 18 4. Keeyask Gas Tie: Keeyask, two 245 MW SCGT and three 357 MW CCGT and a 250 MW
19 capacity MH-U.S. tie line

20

21 The NFAT Reliability Evaluation examined the reliability of the above development plans in
22 terms of metrics such as loss of load expectation over a 25-year planning window. Specific
23 transmission studies for each of the development plans were not performed. The reliability
24 analysis considered the outage rates of the generation in each development plan and the three
25 Bipole HVDC system. The reliability of the Manitoba AC transmission network is much higher
26 compared to the generation forced outage rate and hence can be ignored for this type of
27 analysis.

- 1 The underlying assumptions in the NFAT Reliability Evaluation are included in Section 3 (page 5
- 2 and 6) of Appendix 13.1 of the NFAT submission.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Appendix 13.1 at 7**

4

5 **QUESTION:**

6 Referring to the NFAT Reliability Evaluation at 7, please explain why the Keeyask GAS
7 alternative was not changed to have a Keeyask ISD of 2019 in order to avoid breaching the 0.1
8 days/LOLE.

9

10 **RESPONSE:**

11 The addition of Keeyask in 2022/2023 is not solely based on reliability performance but on a
12 series of other factors. In order to be able to consistently compare the costs, benefits and other
13 attributes of each development plan assessed in the NFAT submission, in-service dates of the
14 generation options were kept constant within each development plan. Therefore, the Keeyask
15 GAS development plan (also referred to as K22/Gas or Plan 2) was not changed to have a
16 Keeyask in-service date of 2019. Manitoba Hydro agrees that if the Keeyask ISD is advanced to
17 2019 for the Keeyask GAS development plan, there will be no breach in the 0.1 days/year in
18 2022 but the LOLE of later years can still be greater than 0.1 days/year. A Keeyask ISD of 2019
19 would not change the conclusions drawn from the reliability studies.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Executive Summary at 18:1-3**

4

5 **QUESTION:**

6 Please provide all studies supporting the assumptions included in the statement that "[t]he 750
7 MW interconnection would have 750 MW of export and import capability whereas the 250 MW
8 interconnection is assumed to have 250 MW of export capability but only 50 MW of import
9 capability."

10

11 **RESPONSE:**

12 The response to this Information Request would require the disclosure of Commercially
13 Sensitive Information which cannot be filed on the public record.

14

15 The study that supports the statement is the confidential preliminary group Facility Study
16 report. Both 50 MW and 250 MW import capability of the 230 kV interconnection were
17 analyzed in the report. The higher import capability required the Glenboro phase shifter to
18 mitigate impacts. The additional cost of the phase shifter and additional import capability was
19 not included in the 250 MW plan included in NFAT. The 500 kV interconnection (Dorsey to
20 Blackberry 500 kV line) was demonstrated to have 750 MW of export and import capability.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 23:3-13.**

4

5 **PREAMBLE:** In order to analyze the financial and economic risk associated with building
6 two hydro generating units and transmission facilities instead of examining other
7 resources, such as importing power from other areas.

8

9 **QUESTION:**

10 Further to Chapter 5 at 23:3-13, please provide Manitoba Hydro's most recent transmission
11 study, including contingency analyses for NERC N-1, N-1-1 and N-2 contingencies

12

13 **RESPONSE:**

14 The referenced section in Chapter 5 is referring to the reliability of Manitoba Hydro's 10-year
15 capital plan. Each year, Manitoba Hydro conducts an assessment to ensure the plan meets the
16 performance criteria specified in the NERC transmission planning standards (TPL-001 through
17 TPL-004). The assessment reports contain Commercially Sensitive Information including
18 potential Critical Energy Infrastructure Information and cannot be filed on the public record.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Appendix 13.1 and Chapter 5, pp. 7-11.**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please state how Manitoba Hydro defines N-1, N-1-1 and N-2 transmission contingencies with
12 respect to the HVDC system under both Manitoba Hydro's reliability criteria and the criteria of
13 the North American Electric Reliability Corporation ("NERC"). For example, is a contingency loss
14 of one pole of any of the three Bipoles considered to be a single contingency event (N-1) or
15 must Manitoba Hydro experience a contingency outage of both poles of any one Bipole in order
16 to be considered to be experiencing an N-1 contingency?

17

18 **RESPONSE:**

19 Manitoba Hydro adopts the NERC reliability criteria and definitions which apply to both the ac
20 and dc system. Loss of a DC pole is considered as a single contingency (N-1). Manitoba Hydro
21 system is designed to meet the NERC reliability performance criteria.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Appendix 13.1 and Chapter 5, pp. 7-11.**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Similarly does Manitoba Hydro consider the successive loss of both poles of two entire Bipole
12 circuits to be an N-1-1 event or two N-2 events or something else (please specify and explain)?

13

14 **RESPONSE:**

15 Loss of a bipole is considered as a multiple contingency, or N-2 (category C) event. Loss of both
16 bipoles is an extreme event (category D). Manitoba Hydro system is designed to meet the NERC
17 reliability performance criteria. NERC does not specify performance criteria for extreme events
18 but requires that such events be evaluated for risks and consequences.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Appendix 13.1 and Chapter 5, pp. 7-11.**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please state the MW value of the firm transfer capability of the HVdc system - both with and
12 without the addition of Bipole III - before and after the occurrence of N-1, N-1-1 and N-2
13 transmission outages of each Bipole line and 500 kV AC line.

14

15 **RESPONSE:**

16 Bipole III is considered as the base case for all the alternatives evaluated in the NFAT. The
17 critical stability limit for the three-bipole system is approximate 4750 MW with the addition of
18 Bipole III, although the three-bipole system has a total capacity of 5854 MW.

19

20 The 4750 MW transfer capacity can be maintained with a loss of any pole power of a bipole (N-
21 1). With the loss of a bipole, i.e. loss of pole subsequent to a pole loss (N-1-1), or loss of bipole
22 (N-2), the transfer capacity reduces the transfer capability to 3854 MW for the outage of Bipole
23 II or Bipole III, and 4000 MW for a Bipole I outage.

24

25 The 500 kV ac line is not part of the HVdc system and has no impact on the HVdc transfer
26 capacity. If the 500 kV line to be constructed as part of the NFAT Preferred Plan goes out-of-
27 service, the Manitoba Hydro-U.S. transfer capability will revert back to the current levels of
28 2175 MW export and 700 MW import during the duration of the outage.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Appendix 13.1 and Chapter 5, pp. 7-11**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please provide all documents related to, arising from or used in connection with Manitoba
12 Hydro's definition and evaluation of N-1, N-1-1 and N-2 transmission contingencies on the
13 existing and planned HVDC transmission system and on its entire transmission system including,
14 but not limited to studies of the steady state and dynamic response of its system to loss of each
15 and every combination of Bipole, I, II and III.

16

17 **RESPONSE:**

18 The response to this Information Request would require production of Commercially Sensitive
19 Information which cannot be provided on the public record.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Appendix 13.1 and Chapter 5, pp. 7-11**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please state whether Manitoba Hydro has changed its reliability criteria with respect to the
12 HVDC system and its Northern Hydro generation since portions of the HVDC system first began
13 entering service in 1971. If so, please list the nature and date of each such change in those
14 reliability criteria, the reasons for adopting each such change and provide all documents
15 relating to, arising from or used in connection with making each such change.

16

17 **RESPONSE:**

18 Manitoba Hydro has historically adopted the “a dc pole reserve over load criteria” stated in the
19 1986 Transmission Planning Criteria (H&TPD 86-1), as quoted “The present Criteria is to
20 maintain a dc pole reserve toward meeting the Manitoba Firm load demand in conjunction with
21 existing southern system generation under median flows”. This criteria was applied to the
22 development of Limestone generation.

23

24 The reserve criteria is under continuous review by Manitoba Hydro. The past operating
25 experience (significant outages of HVdc valve groups) and increasing economic benefit received
26 from power exports have led to the criterion of maintaining “on-line valve group spare over
27 generation” to cover value group outages. This “spare valve” criterion is considered to provide
28 optimum reliability and economic benefits. The reserve criteria is currently under further
29 investigation for the split Northern Collector System associated with Conawapa.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 5:4-6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Referring to Chapter 5 at 5:4-6, please confirm that the existing HVdc system was designed to
12 bring 3562 MW of hydro generation in the Gillam area south to the Dorsey Converter Station. If
13 not, please state why not and state the rated capability of the existing HVdc system (Bipoles I
14 and II).

15

16 **RESPONSE:**

17 Please refer to the response to MMF/MH II-016e. The existing HVdc system was designed with
18 the reserve criteria of “a dc pole spare over load”. Bipole I and II have a total rating of 3854MW,
19 which can carry power of the existing generation under normal conditions.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 5:4-6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please specify the limiting system component or components of the existing HVDC system and
12 the limiting contingency or contingencies and identify all upgrades in voltage and/or current
13 ratings ever evaluated by Manitoba Hydro to increase the capability of the existing HVDC
14 system.

15

16 **RESPONSE:**

17 The response to this Information Request would require the disclosure of commercially
18 sensitive information.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 9 and Appendix 13.1 at 6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please confirm that the present HVdc system has a rating of 3854 MW and that the rating will
12 rise to 6154 MW upon the addition of the 2300 MW capacity of Bipole III with all facilities in
13 service. If not, please explain why not and state what the rating is and what it will be with the
14 addition of Bipole III.

15

16 **RESPONSE:**

17 The existing Bipole I and II has a rating of 3854 MW (1854 MW of Bipole I and 2000 MW of
18 Bipole II), and the rating of three-bipole system will increase to 5854 MW after the Bipole III
19 project. Bipole III project provides 2000 MW increase in system capacity . The dc equipment of
20 Bipole III can be overloaded up to additional 300 MW, but both ac and ac system upgrades
21 would be required to utilize such capacity. This additional 300 MW capacity is planned to be
22 provided with Conawapa.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 9 and Appendix 13.1 at 6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please assume that Bipole III has been placed in service and state the rated transfer capability
12 in MW of each of Bipole I, Bipole II and Bipole III, and the combined ratings of Bipoles I and II
13 and of Bipoles I, II and III, and the dates on which such ratings will apply.

14

15 **RESPONSE:**

16 Please refer to the response to MMF/MH II-018a.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 9 and Appendix 13.1 at 6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please state for each such rated capability in (b) above whether it has been determined under
12 N-0, N-1, or N-1-1 conditions (please define the condition).

13

14 **RESPONSE:**

15 The ratings stated in the response to MMF/MH II-018a assumes the system intact conditions
16 (N-0) with all elements in-service.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 5 and 9 and Appendix 13.1 at 6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please confirm that the existing HVdc system (Bipoles I & II) is rated at 3854 MW and can
12 accommodate the 3562 MW capability of Kettle, Long Spruce and Limestone but cannot
13 accommodate the addition of 695 MW of generating capability at Keeyask which addition
14 would bring the hydro capacity in the vicinity of Gillam to 4257 MW.

15

16 **RESPONSE:**

17 The existing Bipole I & II HVdc system is rated at 3854 MW and can accommodate the capability
18 of Kettle, Long Spruce and Limestone under normal operating conditions, but does not meet
19 the spare value over generation criterion. The existing HVdc system can not provide
20 transmission capacity for Keeyask power. Please also refer to the response to MMF/MH II-016e.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 5 and 9 and Appendix 13.1 at 6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please state whether the existing HVdc system rated 3854 MW is designed to accommodate,
12 and can accommodate, addition of the 200 MW Wuskwatim G.S.

13

14 **RESPONSE:**

15 The Wuskwatim 200 MW plant is integrated into the existing northern 230 kV AC system. The
16 following additional transmission outlet facilities were added to accommodate Wuskwatim:

- 17 • New Thompson-Birchtree 230 kV station
- 18 • New Wuskwatim 230 kV station
- 19 • 42 km Thompson-Birchtree to Wuskwatim 230 kV transmission line
- 20 • Two 137 km Wuskwatim to Herblet Lake 230 kV transmission lines
- 21 • 160 km Herblet Lake to The Pas Ralls Island

22 It is not possible to physically connect Wuskwatim to the existing or future HVdc system.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 5 and 9 and Appendix 13.1 at 6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please state the percentage losses on each of Bipole I, II and III when operating at full rated
12 capacity, and specify those rated capacities.

13

14 **RESPONSE:**

15 Please refer to the response to PUB/MH I-187. The existing Bipole I and Bipole II HVdc system
16 have a loss of about 8.8% when fully loaded with the existing generation (about 3600 MW). The
17 north-south transmission loss of the three-bipole HVdc system averages about 6.5% when
18 delivering the existing northern generation (about 3600 MW peak). Delivering the additional
19 Keeyask generation (a total of 4230 MW generation at peak) will increase the average
20 transmission losses to about 7.1%. The average north-south transmission loss will further
21 increase to 8.6% with Conawapa online (a total of about 5580 MW peak generation).

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 5 and 9 and Appendix 13.1 at 6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please state the amount of peak demand in the Northern part of Manitoba served by the
12 asynchronous AC system.

13

14 **RESPONSE:**

15 Only the station loads at the Radisson and Henday converter stations are supplied by the
16 northern collector system. Each station has a load in the range of 2-3MW.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 5 and 9 and Appendix 13.1 at 6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please state the amount of peak demand in the Northern part of Manitoba served by the HVdc
12 system.

13

14 **RESPONSE:**

15 There is no northern load served by the HVdc system.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 5 and 9 and Appendix 13.1 at 6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please provide detailed descriptions of all instances of the outages, including simultaneous
12 outages, of both Bipole I and Bipole II (both contingency and scheduled outages, specifying
13 which), and provide dates, times, precipitating events, MW load lost, MW load unserved,
14 cascading effects, transfer trips of loads and generation, etc.

15

16 **RESPONSE:**

17 As a joint effort of evaluating operation performance of the HVdc systems in-service, Manitoba
18 Hydro provides an annual report on Bipole I and II outage statistics to the CIGRE HVdc working
19 group. The report follows the CIGRE outage reporting criteria and includes detailed outage
20 type, causes, energy utilization, energy availability and etc. These reports contain Commercially
21 Sensitive Information and cannot be filed on the public record. The valve group outages are the
22 most frequently occurring events.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 at 5 and 9 and Appendix 13.1 at 6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please provide all documents related to, arising from or used by Manitoba Hydro in connection
12 with investigating such simultaneous or overlapping outages of both Bipole I and Bipole II,
13 including the impact on angular and voltage stability and consequences to service to loads and
14 generation in Manitoba and MISO (including amounts and locations of loads and generation
15 dropped by any means, including special protection schemes).

16

17 **RESPONSE:**

18 The response to this Information Request would require the disclosure of commercially
19 sensitive information.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Executive Summary at pages 1-6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Referring to NFAT Executive Summary at pages 1-6, please state why the HVdc existing system
12 needs 2300 MW of redundant (spare) capacity in Bipole III for contingency outages of Bipoles I
13 and II whereas the redundant capacity will shrink to less than 1900 MW when Keeyask is added
14 and drop further to less than 500 MW when Conawapa is added.

15

16 **RESPONSE:**

17 Bipole III is a major system reliability initiative to reduce dependence on the Dorsey Converter
18 Station and the existing HVdc Interlake transmission corridor and provide the required supply
19 during a catastrophic outages of these facilities. Bipole III has been reviewed and licensed by
20 the Clean Environment Commission, and is included in the base case for the NFAT. In the event
21 of loss of Biple I and II, Bipole III will provide 2000 MW north-south transmission capacity to
22 serve the southern load. This is still the case with the development of Keeyask and Conawapa.

23

24 With the failure of Bipoles I and II, exports will be stopped, imports will be maximized, all
25 hydro-electric generation not on the HVdc system and up to 2300 MW on Bipole III, and all
26 thermal resources will be put into service in an attempt to meet domestic load for the duration
27 of the outage.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Executive Summary at pages 1-6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please confirm that, initially, Bipole III will provide 2300 MW of spare transfer capacity for
12 delivering the 3562 MW of Kettle, Long Spruce and Limestone capability in the event of a
13 contingency outage of both Bipoles I and II.

14

15 **RESPONSE:**

16 Please refer to the response to MMF/MH II-020a. Bipole III will provide up to 2300 MW north-
17 south transmission capacity in the event of losing Bipole I and II.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Executive Summary at pages 1-6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please confirm that Bipole III will provide approximately 1900 MW of spare transfer capacity
12 (Bipoles I and II of 3854 MW + 2300 MW for Bipole III) for delivering the existing hydro output
13 as well as the output of Keeyask (3562 MW + 695 MW) and, if not, why not.

14

15 **RESPONSE:**

16 Bipole III will provide 2000 MW north-south capacity. Under normal operation, there will be
17 approximately 1670 MW spare capacity on the three-bipole system with the addition of
18 Keeyask. Keeyask will add 630 MW of new capacity to the system.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Executive Summary at pages 1-6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please confirm that Bipole III will provide only approximately 400 MW of spare transfer capacity
12 (Bipoles I and II of 3854 MW + 2300 MW for Bipole III=6154 MW) for delivering the existing
13 hydro output as well as the output of Keeyask and Conawapa (3562 MW + 695 MW + 1485 MW
14 = 5742 MW) and, if not, why not.

15

16 **RESPONSE:**

17 Please refer to the response to PUB/MH-I-192, CAC/MH-014a, and PUB/MH II-492b.

18

19 The existing HVdc system has to be divided into two separate systems to meet the reliability
20 criteria with the in-service of Conawapa power. The limiting factor is the approximate 4750MW
21 HVdc loading on a single HVdc system with three bipoles after Bipole III project. The
22 development of Keeyask Transmission Project, Conawapa transmission project and North-south
23 transmission system upgrades project will enable the delivery of most of Keeyask and
24 Conawapa power. Only about 200 MW Conawapa generation is non-firm.

25

26 Dividing the HVDC system into two systems, and maintaining a valve group spare in each
27 system, requires that 300 MW and 575 MW be held as spare in the separate HVdc systems,
28 reducing the available HVdc transmission to 5280 MW. Keeyask will add 630 MW of new
29 capacity to the system, and Conawapa will add 1400 MW of new capacity (during summer),

- 1 thus maximum generation is 5584 MW, leaving up to 300 MW of generation that will either use
- 2 the ac transmission system, or not have firm transmission.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Executive Summary at pages 1-6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Is it a fair characterization of Manitoba Hydro's long-term plan that Bipole III will be shifted
12 from its initial role of providing backup for simultaneous contingency outages of both Bipoles I
13 and II (a maximum credible event) to Bipole III's ultimate role of delivering the output of
14 Keeyask and Conawapa under N-0 and N-1 conditions? If not, please state why not.

15

16 **RESPONSE:**

17 No, the question does not provide an accurate characterization. Bipole III will provide the
18 backup power following simultaneous contingency outages of both Bipoles I and II for the
19 existing system as well as the future system with Keeyask and Conawapa. The 2000 MW backup
20 provided by Bipole III is critical to meet system reliability requirements up to year 2025. The
21 Manitoba Hydro preferred development plan will provide additional backup power through the
22 500kV Manitoba Hydro-U.S. tie line which allows Manitoba Hydro to meet the system reliability
23 beyond 2040 as detailed in the reliability evaluation (Appendix 13 of the NAFTA submission).

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Executive Summary at pages 1-6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please provide Manitoba Hydro's current operating criteria (including the need for reserves) for
12 loss of just one of the Bipole poles or lines, and its proposed operating criteria after the
13 construction of Bipole III.

14

15 **RESPONSE:**

16 There is no specific operating criteria for loss of an HVdc pole. The NERC Transmission Planning
17 standards (NERC TPL-002) defines loss of of an HVdc pole as a Category B contingency event.
18 Following this loss, the system should be stable, thermal and voltage limits should be within
19 applicable ratings, there should be no loss of demand or cascading outages. Curtailments of
20 contracted Firm transfers (e.g. Manitoba to US transfers) are permitted assuming generation
21 redispatch is available. Both pole and/or Bipole losses are normal contingencies analysed during
22 operating and planning assessments.

23

24 If the loss results in a significant generation capacity loss in real time, then Manitoba Hydro
25 would follow its real-time capacity and energy procedures (EOP-3324-1 Emergency Operations
26 – Real Time Capacity and Energy Emergency Procedures).

27

28 Manitoba Hydro shares generation planning reserves with MISO to cover for contingency losses
29 of generation. The Contingency Reserve Sharing Group (CRSG) requirement for the MISO

1 footprint is 2000 MW. MISO examines historic outages as well as credible (n-1) outages in
2 determining the appropriate level of reserves. Historically, loss of the Manitoba to US 500 kV at
3 maximum loading resulted in a loss of 1500 MW, which was considered the largest contingency
4 in the western part of MISO. Manitoba Hydro's share of the reserve obligation is 150 MW of
5 which 60 MW is required to be spinning. Manitoba Hydro can request up to 500 MW in
6 contingency reserves from the reserve sharing group on top of curtailment of any exports.

7

8 Loss of a pole today would result in a maximum generation loss of 1000 MW assuming it was
9 fully loaded due to a valve group prior outage, for example. After Bipole III goes into service,
10 the potential maximum pole loss will not change (however, a larger prior outage would be
11 covered initially). After Keeyask and Conawapa are placed in service, the rating of Bipole III will
12 increase from 2000 MW to 2300 MW, hence the maximum pole loss will increase to 1150 MW.
13 The CRSG requirement of 2000 MW will not change as a result of Bipole III being added.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Executive Summary at pages 1-6**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such delivery of hydro energy is
8 important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please state whether Manitoba Hydro stiffened its reliability criteria in advance of building
12 Bipole III (e.g., thereby requiring that Bipole III provide approximately 2300 MW of backup for
13 the 3562 MW of generation that would otherwise be undeliverable upon occurrence of
14 simultaneous or overlapping contingency outages of both Bipoles I and II) and will relax that
15 criterion over time until Bipole III will provide only 400 MW of backup upon the in-service date
16 of Conawapa in the event of outages of both Bipoles I and II? If not, please state why not and
17 explain why these facts do not demonstrate that Manitoba Hydro plans to relax its reliability
18 criteria.

19

20 **RESPONSE:**

21 Please see the response to MMF/MH II-020e. Manitoba Hydro did not relax its reliability criteria
22 in the development of Bipole III, Keeyask and Conawapa. In fact, the Manitoba Hydro preferred
23 development plan will improve the system reliability to above the industry standard as shown
24 in Appendix 13 of the NFAT submission.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 pages 16-28 and Chapter 15 at 9:13-21**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such revenue from delivery of hydro
8 energy is important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please provide all documents related to, arising from or used in connection with curtailments of
12 exports to the United States.

13

14 **RESPONSE:**

15 Curtailments of exports are possible for two reasons as follows;

16 a) Maintaining transmission reliability, and

17 b) Under circumstances defined in export contracts.

18

19 Transmission Reliability

20 Manitoba Hydro in coordination with the MISO Reliability Coordinator performs curtailment of
21 exports to the United States to ensure reliability of the interconnected power system by
22 mitigating the following system conditions:

23 1. System Operating Limit (SOL)/Interconnection Reliability Operating Limit (IROL)
24 violations,

25 2. Over-schedules, and

26 3. Capacity/Energy emergencies in Manitoba

27

1 The curtailment is accomplished in accordance with NERC Standards, MISO RC Policies, and
2 Manitoba Hydro Operating procedures as outlined in the following attachments:

- 3 1. MMF-MH II-021b Attachment 1 - MH Transmission Loading Relief (TLR) procedure (EOP-
4 1653-01)
- 5 2. MMF-MH II-021b Attachment 2 - MH Manual Schedule Reduction (NOP-3653-01)
- 6 3. MMF-MH II-021b Attachment 3 - MH Emergency Operations - Real Time (EOP-3324-01)
- 7 4. MMF-MH II-021b Attachment 4 - MH Emergency Operations - Planning (EOP-3324-02)
- 8 5. MMF-MH II-021b Attachment 5 - MISO Congestion Management Procedure (RTO-RA-
9 OP-001-r20)
- 10 6. MMF-MH II-021b Attachment 6 - NERC RC — Transmission Loading Relief (IRO-006-5)

11

12 Contract Curtailments

13 Each of Manitoba Hydro's export contracts define events on the Manitoba Hydro system which,
14 if they were to occur, would give Manitoba Hydro the right to curtail deliveries of energy.
15 However curtailments are only permitted if curtailment is necessary to allow Manitoba Hydro
16 to continue to serve higher priority loads such as load in Manitoba.

17

18 Some events that would qualify include forced outages and derates of generating equipment or
19 Manitoba Hydro's HVdc system, and maintenance outages necessary to avoid damage to
20 equipment. The specific curtailments rights and details contained in each export contract are
21 commercially sensitive and cannot be provided on the public record.

1. Purpose:

To provide a summary of how the Transmission Loading Relief (TLR) procedure is implemented by the Midwest ISO (MISO) Reliability Coordinator on Manitoba Hydro (MH) Transmission Facilities.

2. Scope:

Transmission Loading Relief procedures are used to prevent or manage potential or actual Security Operating Limit (SOL) and Interconnection Reliability Operating Limit (IROL) violations to maintain reliability of the Bulk Electric System. This procedure identifies TLR levels and the actions to be taken by MH and the MISO Reliability Coordinator (RC) to implement the TLR procedures.

3. Procedure:

MISO St Paul continuously monitors the loading on the MHEX, MH-SPC and MH-ONT interfaces. The Interchange Distribution Calculator will automatically post the TLR Level on the NERC TLR Status web page.

3.1. Notification TLR Level 1 - If 93% of the System Operating Limit (SOL) is reached, a TLR level 1 is initiated by the MISO RC. An exception exists for MHEX_S where TLR1 is called when the flow reaches or exceeds 99% of the SOL minus CRSG. A Level 1 is an alert to inform the marketplace and other Reliability Coordinators that curtailments are likely to occur. The Reliability Coordinator should announce a TLR level 0 once the Notification level is no longer necessary.

3.2. If 95% of the SOL is reached, MISO RC will initiate TLR Level 3a for next hour or TLR Level 3b for the current hour. An exception exists for MHEX_S where a TLR3 is called when the flow reaches or exceeds the SOL minus CRSG.

3.2.1. Reallocation TLR Level 3a - Transactions using Non-firm Point-to-Point Transmission Service are curtailed to allow Transactions using higher priority Point-to-Point Transmission Service.

3.2.2. Curtail TLR Level 3b - Curtail Transactions using Non-firm Point-to-Point Transmission Service to mitigate Operating Security Limit Violation

3.3. Reconfigure TLR Level 4 - If curtailment of non-firm point-to-point Transmission Service is insufficient to mitigate Operating Security Limit Violation, the transmission system may be reconfigured.

-
- 3.4. If attempts to accommodate all Firm Transactions by re-configuration is not possible or if further relief is required, TLR level 5 will be used to curtail firm transactions.
- 3.4.1. **Reallocation TLR Level 5a** - Transactions using Firm Point-to-Point Transmission Service are curtailed pro-rata to allow new Firm Transactions to begin (pro-rata). Also requires Pro-rata curtailment with Native Load.
- 3.4.2. **Curtail TLR Level 5b** - Curtail Transactions using Firm Point-to-Point Transmission Service to mitigate Operating Security Limit Violation. Also requires Pro-rata curtailment with Native Load.
- 3.5. **Emergency Action TLR Level 6** - Curtailment of Firm & Non-Firm transactions was unsuccessful in mitigating the Operating Security Limit Violation. Additional measures may be included redispatch, voltage reductions, interruptible and firm load shedding.
- 3.6. **TLR Concluded TLR Level 0** - Restore Firm & Non Firm Transactions.

4. TLR Notes:

- 4.1. Only transactions with a 5% or greater Transfer Distribution Factor (TDF) are subject to curtailments.
- 4.2. **Fixed Dynamic Interchange Scheduled associated with External Asynchronous Resources (EAR)** - EAR functions as an internal generator within MISO and is re-dispatched by MISO to mitigate Operating Security Limit Violations. The MISO Congestion procedures for EAR are as follows:
- 4.2.1. **MHEX Interface:**
- MISO RC issues TLR and curtailment report will include the MHEB_EAR_MISO tag for reduction.
 - MISO RC will curtail the MHEB_EAR MISO tag. Curtailments by an external constraint will trigger an EEE (Excessive Energy Exemption) and thus will not be subject RSG charges. (**** MISO internal procedures require MISO RC to contact MISO Scheduling to initiate the curtailment, ****)
 - MISO RC may reduce EAR for reliability purposes.
- 4.2.2. **Internal MISO Market flowgates:**
- MISO RC issues TLR and the curtailment report shall exclude the MHEB_EAR_MISO tag for reduction EAR shall be dispatched by MISO Unit Dispatch System (UDS).

-
- b) MISO RC will “disregard” the EAR tag prior to the “acknowledgement” process. By performing this step, the EAR tag will be displayed as “disregarded” at the top of the final congestion management report.
 - c) MISO RC “binds” the flowgate to maintain flow at 95% of limit or as prescribed by an operating guide. The EAR will then be automatically controlled by UDS.
 - d) If there is a mismatch between the EAR e-tag and the curtailment report on Midwest ISO Communication System (MCS), the Manitoba Hydro Operator will contact the MISO RC to verify the curtailment. The MISO RC may instruct MH-Operator not to curtail the tag and will inform the MISO Scheduling Department personnel to not deny the tag.

4.2.3. Non MISO Market flowgates:

- a) Non-MISO RC issues TLR and curtailment report will include the MHEB_EAR_MISO tag for reduction.
- b) MISO RC will curtail the MHEB_EAR MISO tag, .Curtailments by an external constraint will trigger an EEE (Excessive Energy Exemption) and thus will not be subject RSG charges.
- c) MISO RC may reduce EAR for reliability purposes.
- d) If there is a mismatch between the EAR e-tag and the curtailment report on MCS, the Manitoba Hydro Operator will contact the MISO RC to verify the curtailment. The MISO RC may instruct MH-Operator not to curtail the tag and will inform the MISO Scheduling Department personnel to not deny the tag.

4.3. **MHEX_N Loss of Critical Element** - Upon contingency loss of any critical element on the MH-USA interface, MISO RC will initiate the FAST procedure as detailed in EOP 3653-01. This procedure is a generation re-dispatch that will quickly reduce the north flow below the post contingency limits. Once the FAST procedure has been initiated, MISO RC will initiate TLR to reduce the schedules in order to end the FAST procedure.

4.4. **MHEX Metering** - There are two sets of metering values available for flows at Dorsey, Letellier, Richer and Glenboro, compensated and uncompensated values. The uncompensated values indicate the actual flows, including losses and any “off schedule” values on SPC or IESO (including the phase shifter bandwidth). The compensated values reflect the calculated values at the border. MH AGC controls to the compensated values and MISO monitors the uncompensated values to call TLR. There can be a difference of up to 50MW between the MISO values and the MH values. MH Control Centre also displays the uncompensated values and TLR is called on the uncompensated flow at the station.

- 4.5. **MISO Monitoring** - MISO St Paul uses the OGM (Operating Guide Monitoring Tool) to monitor the flows at the four Manitoba Hydro terminal stations. The OGM is programmed to provide alarming capability and instructions on using TLR procedures to ensure flows are maintained within limits. It is not required to call TLR if the flows are simply fluctuating in and out of alarm due to normal power system fluctuations, however if the flows are over the limit for more than 5 minutes, MISO St Paul will contact the MH operator to identify the source of the error. There are three potential sources for exceeding the flow limit, Manitoba Over-scheduling, Ontario Off Schedule, and/or SPC Off Schedule
- a) Manitoba Over-scheduling, (having schedules higher than the posted schedule limit), then either manual schedule reduction or TLR can be used to reduce as detailed below.
 - b) Ontario being Off Schedule, an Off Load on the Whiteshell Phase shifters must be performed as soon as possible.
 - c) SPC being Off Schedule, MISO will call SPC Power System Supervisor (306-566-3546) and request corrective action be taken. If SPC is over-generating, they may elect to reduce hydraulic generation if the thermal generation cannot be reduced quickly enough.
 - d) If steps b & c above cannot be completed within 15 minutes of the request, MISO St Paul will proceed with TLR level 3.

5. Reference Documents:

- 5.1. NERC Standard IRO-006-4 - Transmission Loading Relief
- 5.2. MH OATT Attachment Q - Curtailment Procedures (NERC Appendix 9C1 - Transmission Loading Relief Procedure - Eastern Interconnection
- 5.3. NOP 3760-1 - MHEX_S Realtime Dynamic Dispatchable (EAR) Procedure.
- 5.4. [NOP-3653-01 - Manual Schedule Reduction Procedure for MHEX-N & MHEX-S Interface](#)
- 5.5. EOP 3653-1 MHEX_N FAST Generation Runback Procedure

Revision History:

| Rev No. | Date of Issue | Owner or Author | Ext. Review | Appr. By | Revision | Review Date |
|---------|---------------|-----------------|-------------|----------|---|-------------|
| 0 | 2009 03 16 | CNM | LSH | BAP | Was CSOI 6-4-1-0. | 2010 03 01 |
| 1 | 2011 04 18 | CNM | MR | LSH | Corrected section 4.3 EOP 3653-01 was CSOI 6-4.2.0. | 2012 05 04 |
| 2 | 2011 06 08 | LSH | JW | LSH | Revised 4.2.2 d) If the EAR tag is included on the curtailment report and MISO RC has not called to verify, the Manitoba Hydro Operator will contact the MISO RC anytime the EAR tag was curtailed. The MISO RC may instruct MH-Operator not to curtail the tag and will inform the MISO Scheduling Department personnel to not deny the tag. Add same statement from | 2016 06 08 |

| | | | | | | |
|---|------------|-----|-------------------------|-----|---|------------|
| | | | | | above to section 4.2.3 | |
| 3 | 2011-06-29 | LSH | JW MH, AR MISO | LSH | <p>Changed 4.2.2 d)If there is a mismatch between the EAR e-tag and the curtailment report on Midwest ISO Communication System (MCS), the Manitoba Hydro Operator will contact the MISO RC to verify the curtailment. The MISO RC may instruct MH-Operator not to curtail the tag and will inform the MISO Scheduling Department personnel to not deny the tag.</p> <p>Add same statement from above to section 4.2.3</p> | 2016-06-29 |
| 4 | 2011-08-22 | LSH | JW | LSH | Revised section 3.1 and 3.2 to reflect changes in limits for ONT, SPC and USA. | 2016-06-29 |

1. Purpose:

To identify a process between the Manitoba Hydro System Operator and the MISO, IESO and SPC Reliability Coordinators to perform a BA to BA curtailment on the MHEX, ONT, and SPC interfaces when projected “over-scheduling” occurs.

2. Scope:

The Manitoba Hydro System Operator is responsible for monitoring schedules on the MHEX, ONT, and SPC interfaces. When projected “over-scheduling” occurs the Manitoba Hydro System Operator will contact the MISO Reliability Coordinator and/or appropriate Reliability Coordinator to notify them of the over schedule and that a BA to BA curtailment will be initiated.

3. Background:

3.1. Interface over-scheduling may be caused by:

- Errors in the ATC calculations
- Non-Firm transmission service schedules - Firm Transmission customers have until 1500 hours EST day prior to schedule on their firm transmission reservations, after 1500 hours EST the unscheduled firm transmission service is released for sale as hourly non-firm transmission service. The firm customer does not lose the right to schedule upon the original reservation. Thus if both the firm and non-firm customer schedule transactions the interface will be over-scheduled.

3.2. If real-time flows actually reach the defined operating limit, the MISO Reliability Coordinator will utilize NERC TLR to control the flow.

3.3. Late Tags - Late tags flowing north that come in after 20 minutes before the hour as “Late Tags” per the Manitoba tariff timing requirements will be automatically denied by webtrans.

4. Procedure

4.1. **Interface Monitoring** - If the Manitoba Hydro System Operator determines that the next hour MHEX, ONT, or SPC transfer limit will be exceeded, the System Operator shall immediately contact the MISO St. Paul Reliability Coordinator and/or the applicable Reliability Coordinator to communicate which interface has been overscheduled and that a BA to BA curtailment will be initiated by Manitoba Hydro. Notice should be provided to the applicable

Reliability Coordinator by xx:40 but after xx:30. The Reliability Coordinator will require information on the amount of overscheduled megawatts and the duration.

- 4.2. **BA to BA Curtailment** - Manitoba Hydro System Operator using the curtailment wizard in webTrans will initiate a “Pro-Rata by Priority” curtailment of etags for the upcoming hour as outline in EMS instruction.
- 4.3. **MISO Tariff Administration Notification** - The System Operator shall contact the MISO Carmel Tariff Administrator to communicate that a manual schedule reduction has been initiated on the MHEX, ONT, or SPC interface and that no additional transmission service should be sold for the next hour (s).
- 4.4. **MISO, IESO and SPC Reliability Coordinator Updates** - The Manitoba Hydro System Operator will communicate each hour with MISO St. Paul Reliability Coordinator to provide status updates.

5. Reference Documents:

[EMS 3-08-9 - webTrans Curtailment Wizard](#)

Revision History:

| Rev No. | Date of Issue | Owner or Author | Ext. Review | Appr. By | Revision | Review Date |
|---------|---------------|-----------------|-------------------|----------|---|-------------|
| 0 | 2009-03-15 | CNM | LSH | BAP | Modified format and changed naming convention. Was CSOI-6-4.2.1 | 2010-03-15 |
| 1 | 2011-06-20 | LSH | JW - MH/AR - MISO | LSH | MISO is no longer able to perform manual schedule reduction and results in almost a complete rewrite. | 2016-06-20 |

1. Purpose:

This procedure shall be invoked immediately when experiencing capacity or energy emergencies.

2. Scope:

This procedure defines energy and capacity emergencies and identifies the steps to manage and correct such events. Coupled with EOP-3324-2 Emergency Operations - Planning Horizon, comprises Manitoba Hydro's Capacity and Energy Emergency plan. Communications and instructions to MISO (Reliability Coordinator and Balancing Authority), Independent Electricity System Operator (Balancing Authority), Saskatchewan Power Corporation (Balancing Authority), Curtailable Customers, Major Customers, Power Sales and Operations, and Manitoba Hydro's Public Affairs Department are outlined herein.

3. Procedure:

- 3.1. This procedure serves and provides specific alert, warning, and event levels to mitigate a capacity emergency.
- 3.2. MH shall render all available emergency assistance to others as requested, provided that the requesting entity has implemented its comparable emergency procedures, unless such actions would violate safety, equipment, regulatory or statutory requirements.
- 3.3. Manitoba Hydro operates and schedules resources inside Manitoba to ensure energy and capacity supplies are adequate to meet Manitoba Hydro domestic load, firm commitments and required operating reserves, considering the single most severe contingency loss. Capacity and energy emergencies should only occur upon multiple contingency losses or during certain planned maintenance outages. Management of capacity and energy emergencies depends if they are slow developing or immediate:
 - 3.3.1 Slowly developing emergencies are those emergencies that can be predicted in advance of the operating day (such as forecast error, predicted equipment failure, drought).
 - 3.3.2 Immediate energy/capacity emergencies are expected to result from a sudden multiple contingency losses as a result of unforeseen circumstances.
- 3.4. This instruction is prepared for Real Time (current day) operation. EOP-3324-2 Emergency Operations - Planning Horizon details emergency operations for the planning horizon (next day operations).
- 3.5. An emergency exists whenever MH is no longer able to provide for its customer's anticipated energy needs and provide Operating Reserves. There

are three levels of energy emergencies in accordance with NERC Appendix 5C. They are called “Energy Emergency Alerts” (EEA) levels 1 to 3:

- 3.5.1 EEA1 – All resources are in use – concerned about sustaining Operating Reserves
- 3.5.2 EEA2 – Load Management Procedures in effect
- 3.5.3 EEA3 – Firm Load Shed is imminent or in progress

3.6. Steps to Manage and Correct Energy Emergencies:

3.6.1 These steps are sequenced in ascending order of emergency severity, however the magnitude or rate of progress of the emergency may not allow enough time to initiate or complete the steps in sequential order. As conditions require, MH may move directly to any step in this procedure, and give direction to complete actions provided in the earlier steps as time permits. Continue on to the next step in the sequence until the generation and load are matched (including reserves) and transmission line loadings are within System Operating Limits.

3.6.2 If operating conditions exist or are anticipated, where all available internal resources are committed or are operating at maximum values to meet firm load demand, firm transactions, and operating reserves:

1. System Operator will cancel scheduled generator, HVDC and critical transmission line maintenance outages that have not commenced and recall units and critical lines (that restrict imports) from maintenance outages.
2. Increase all generation on line to full load as required subject to all physical or license constraints, normal operating limits, and System Operating Limits.
3. Contact the Real Time Traders in Power Sales & Operations (PSO) to request the curtailment of non-capacity backed energy sales and/or purchase sufficient resources up to the maximum import transfer limits.
4. Start Natural Gas based Thermal Generation:
 - Brandon CT’s for Emergency Requirements. If time permits, utilize normal start (approx. 34 minutes to full load) and quick start (19 minutes to full load) if required. Request Real Time Traders to arrange gas if possible, if gas is not available, proceed to start on oil.
 - If emergency is expected to be greater than 8 hours request Selkirk Units 1 & 2 be brought on line as soon as possible. Expected startup time is 8-10 hours.
5. Contact Real Time Traders to request the curtailment of applicable capacity backed contract transactions. The majority of capacity backed contracts

- contains clauses that allow for the transactions to be curtailed upon contingent loss of generation or HVDC equipment once all available MH generation, including CTs, is online (or fails to start).
6. System Operator will advise all stations and key personnel by declaring a Red Day (Policy B7) to use extra diligence to minimize the risk of tripping system equipment.

7. Request MISO RC to declare a “NERC Energy Emergency Alert 1”.

MISO will broadcast via the MAPP Communication Network (MCN) and NERC Reliability Coordinator Information System (RCIS) that Manitoba Hydro is in EEA level 1 and has all available resources in use.

8. Start Coal based Thermal Generation (if available in generate mode):
 - If emergency is expected to be greater than 12 hours, system operator shall request Brandon Unit 5 to be brought on line as soon as possible.
9. Request stand-by staff to locate to Dovercourt for support. Stand-by staff will initiate the Level 2 Emergency Response Team (excluding Power Trading Staff). Among other actions, Emergency Operations Centre (EOC) staff will:
 - Request re-evaluation of the interface system security limits by System Performance.
 - Notify the Division Manager of the situation and provide details.
 - Notify Public Affairs that a public appeal may be required.
10. Curtail Option “A” load as follows:

- a. Canexus - Call 1 - 204 - 728 - 2267

When answered make the following statement,

“This is the Manitoba Hydro Control Centre calling to have Canexus curtail their Option A load.”

Canexus protects a load of 7 MW and will curtail the balance. This will provide up to 118 MW of relief for up to 4 ¼ hours. It can be used for a maximum of 10 hours per day in the summer and 6 hours per day in the winter.

- b. ERCO Worldwide: Call 1 - 204 - 748 - 8253

When answered make the following statement,

“This is the Manitoba Hydro Control Centre calling to have ERCO Worldwide curtail their Option A load.”

ERCO protects a load of 1.5 MW and will curtail the balance. This will provide up to 28.5 MW of relief for up to 4 ¼ hours. It can be used for a

maximum of 10 hours per day in the summer and 6 hours per day in the winter.

11. Curtail Option C loads (1 hour notice required) as follows:

a. TCPL: Call first: 1 - 403 - 920 - 5501 (or secondly 1 - 403 - 265 - 7960)

When answered make the following statement:

“This is the Manitoba Hydro Control Centre calling to have TransCanada Power curtail their Option C load.”

TCPL protects a load of 33 MW and will curtail the balance. This will provide up to 31 MW of relief, beginning in 1 hour, for up to 4 ¼ hours and can be used for a maximum of 8 hours per day.

12. Request generating stations reduce their non-essential station service demand.

13. The Emergency Response Team will update Public Affairs and will respond to all calls not directly involved in the dispatch of resources needed to mitigate the emergency.

14. The Emergency Response Team may inform EMO (945 - 5555) and call out additional help as needed, to initiate press releases, and generally assist as required.

15. Request MISO RC to declare a “NERC Energy Emergency Alert 2”.

MISO RC will broadcast via the MCN and NERC RCIS that Manitoba Hydro is in EEA level 2 and “Load Management Procedures Have Been Implemented.”

16. If MH is operating HVdc in parallel and has sufficient HVdc generation capacity to load paralleled poles above 1500 MW, seek approval from MISO RC to increase Most Severe Single contingency to above 1500 MW.

17. Notify IESO & SPC that MH is experiencing a Level 2 Emergency and that load management procedures are being implemented.

18. Confirm MISO RC has elevated Import Transactions from transmission Priority 6 to Priority 7.

19. Consume MHEB MISO-MBHydro CRSG reserves and remove MH available reserves from the MISO-MBHydro CRSG ARS system. Advise MISO BA (acting as MISO-MBHydro CRSG Administrator) that MHEB is currently experiencing an EEA2 and consistent with CRSG protocols has elected to remove MHEB’s reserves from the ARS system.

If Brandon CTs had been carrying spinning reserves and these reserves were then consumed, call Brandon G.S. Station Operator (726-9107 or 204-578-3121/3131) to inform them that the CT loading has increased.

-
20. Submit MISO-MBHydro CRSG ARS request for emergency energy and identify the loss type as “other extreme conditions.”
 21. Contact Real Time Traders to request they recall remaining firm interchange transactions (i.e., recall export power purchase agreements identified as Capacity Resources per MISO Tariff).
 22. Implement Emergency Energy purchases from neighbouring Balancing Authorities.
 23. Suspend Standards of Conduct – Send message on MCN “Manitoba Hydro is experiencing an EEA2, Curtailable load shed is in effect. MH is suspending the Standards of Conduct in order to be able to share related transmission information with the MH marketing staff to cope with the emergency.” Log the time and send an email message to Manager SCD, Manager TSD, and MH Compliance Officer as detailed in NOP-1628-1
- As part of this process, supervisory staff from the Power Trading Office will be requested to come to Dovercourt to provide additional support in their role as EOC member.
24. The Emergency Response Team will request approval from the PSO Stand-by staff to draw forebay levels below their normal operating minimum as long as the license and structural limits are maintained as detailed in NOP-3323-4 Hydraulic Plants Operating Parameters. If approval is not readily available, do not violate normal limits and instead proceed to the next step.
 25. The Emergency Response Team will contact Public Affairs to initiate a public appeal for voluntary load curtailment

Message for Public Appeal:

This is an emergency announcement. Due to ____ all electrical customers of Manitoba Hydro (in the ____ Area) are urged to reduce their use of electricity until further notice. Specifically, you should:

- Use only essential lighting in your home or business.
- Refrain from using any appliances except as absolutely necessary.
- Delay, if possible, cooking, washing or drying operations using electrical equipment.

If in Winter:

- Disconnect electric space heaters, car warmers and car block heaters.
- Turn off all decorative or ornamental lighting.

Manitoba Hydro is curtailing all non-essential loads. Maximum assistance is being received from neighbouring utilities but this is not sufficient to meet Manitoba's needs. A voluntary reduction in electrical usage could

eliminate the need for planned power interruptions by area on a rotating basis.

Customers will be advised when the situation returns to normal.

- 26. Request CDCC to reduce street lighting and festival lighting load to minimum.
- 27. The Emergency Response Team will initiate a request for a voluntary load reduction from major customers.

| Major Customers | Phone | Max Load |
|--|------------------|-----------------|
| INCO (Thompson) | 1-204-788-5567 | 115 |
| | Pax 2-53-160 | |
| HBM&S (Flin Flon) | 1-204-687-2389 | 104 |
| Enbridge (Edmonton Emergency Dispatcher) | 1-877-420-8800 | 82 |
| Canexus (Partial Load Curtailment) | 1-204-728-2267 | 120 |
| TCPL (Partial Load Curtailment) | 1-403-920-5501 | 64 |
| Manitoba Rolling Mills (Selkirk) | 1-204-485-0448 | 44.9 |
| | 1-204-795-7447 | |
| Tolko | 1-204-623-8635 | 20.0 |
| | 1-204-623-2966 | |
| Simplot (Brandon) | 1-204-729-2795 | 26.8 |
| | 1-204-729-2796 | |
| Griffin Steel (Transcona) | | 17.5 |
| Office Hours | 222-4252 Ext 232 | |
| After Hours (ask for | 222-4253 | |
| Shift Electrician) | 222-4254 | |
| TVX Gold Inc. | 1-204-358-2066 | 9.1 |
| Louisiana Pacific (Minitonas) | 1-204-525-2479 | 8.8 |

Most current telephone numbers for major customers will be in the SCC phonebook explorer. A detailed list of all large industrial customers is available from the Load Research Section in the Rates Department at local 4859 during normal working hours.

- 28. Update the MISO RC no less than each hour on the status of the energy emergency for EEA2 and EEA3 level emergencies.
- 29. Request mutual assistance from SPC operating reserve per Manitoba-Saskatchewan Standard Operating Practice MS-9. Dependant on the operating conditions at the time, Grand Rapids and/or power south of Ponton may need to be re-dispatched. TLAP study mode with the SPC detail can be used to maximize the import capability.

30. Request MISO RC declare a “NERC Energy Emergency Alert 3”.

MISO RC will broadcast via the MCN & the NERC RCIS that Manitoba Hydro is in an EEA3 and “Firm Load interruption imminent.”

This message goes to all Reliability Coordinators, Control Areas and Merchants.

31. **MANUALLY SHED LOAD** using the EMS Load Shed program and/or the the Winnipeg Central Load Shed Procedures (EOP-2832-1) to balance load and generation and maintain interconnection load levels within System Operating Limits.

Initiate additional load shedding as required to maintain ACE at practical zero (i.e. should average approximately zero).

Rotate customer load - Winter or Summer block of load, curtail the next block, and return service to the first block.

3.7. Termination of Emergency (above procedure should be reversed to return to normal), including:

- 3.7.1 Reinstatement of the Standards of Conduct as soon as possible per NOP-1628-1 Standards of Conduct Administration.
- 3.7.2 Return MH's MISO-MBHydro CRSG to normal level.
- 3.7.3 Request MISO RC terminate energy alert (Alert 0).
- 3.7.4 The Emergency Response Team will contact Public Affairs to terminate the public appeal for voluntary load curtailment.

Message to Follow Public Appeal:

“This is an announcement from Manitoba Hydro. The power emergency situation is now over and normal service is resumed. The cooperation of Hydro customers in averting a major power outage is greatly appreciated.”

3.8. Prepare an Energy Emergency Alert 3 Report as per NERC EOP-002 and Disturbance Reporting Requirements as per EOP-3324-6, as applicable.

3.9. Checklist

The following is a checklist that can be used during an emergency. It provides only high level details, however the step numbers are directly from this procedure. The check list can also be used in reverse to return to normal.

| Step | Description | During Emerg. | Return to Normal |
|------|--|---------------|------------------|
| 1 | Recall all available generation, HVdc and critical transmission | | |
| 2 | Increase all on line generation to full load | | |
| 3 | Request Real Time Traders curtail non-capacity backed energy sales and/or purchase resources to maximum import | | |
| 4 | Start natural gas based thermal generation | | |
| 5 | Request Real Time Traders curtail applicable capacity backed contract transactions | | |
| 6 | Declare Red Day | | |
| 7 | Request MISO RC declare EEA1 | | |
| 8 | Start coal based thermal generation | | |
| 9 | Stand-by staff to Dovercourt – Level 2 Emergency Response Team | | |
| 10 | Curtail Option A Load | | |
| 11 | Curtail Option C Load | | |
| 12 | Request Generating Stations to reduce their non-essential station service | | |
| 13 | Emergency Response Team update Public Affairs | | |
| 14 | Emergency Response Team inform EMO (if required) | | |
| 15 | Request MISO RC declare EEA2 | | |
| 16 | Request MISO RC approve loading HVdc paralleled poles above 1500 MW | | |
| 17 | Notify IESO & SPC of EEA2 status | | |
| 18 | Confirm MISO RC has elevated import transactions from Priority 6 to 7 | | |
| 19 | Consume MHEB MISO-MBHydro CRSG reserves and remove from ARS system | | |
| 20 | Submit MISO-MBHydro ARSG ARS request for “other extreme conditions” | | |
| 21 | Contact Real Time Traders to curtail all remaining firm transactions | | |
| 22 | Implement emergency energy purchases from neighbouring BAs | | |
| 23 | Suspend Standards of Conduct | | |

| | | | |
|----|--|--|--|
| 24 | Emergency Response Team request approval from PSO to draw forebays | | |
| 25 | Emerg. Resp. Team requests voluntary load curtailment through Public Affairs | | |
| 26 | CDCC to curtail street and festival lighting | | |
| 27 | Emergency Response Team requests major customers curtail load | | |
| 28 | Update MISO RC on status on an hourly basis | | |
| 29 | Request mutual assistance from SPC | | |
| 30 | Request MISO RC declare EEA3 | | |
| 31 | Manually Shed Load | | |

4. Reference Documents:

NERC STANDARDS:

[EOP-001](#)

[EOP-002](#)

[EOP-003](#)

AGREEMENTS:

MH-MISO BA Coordination Agreement (after January 6, 2009)

US Interconnected Parties Interconnection Agreements (prior to January 6, 2009)

SPC Agreement (Schedule "T")

Manitoba-Saskatchewan Standard Operating Practice MS-9

Interconnection Agreement Between Independent Electricity Market Operator and Manitoba Hydro-Electric Board

OPERATING PROCEDURES:

EOP-3324-6 Disturbance Reporting Requirements

EOP-3324-2 Emergency Operations - Planning Horizon

EOP-3325-01 Restricted Operation of Brandon Unit # 5 (Coal)

NOP-1628-1 Standards of Conduct Administration

NOP-3314-1 Operational Modes for Canexus

NOP-3323-4 Hydraulic Plants Operating Parameters

NOP-3760-2 MISO-MBHydro CRSG Activation

5. Revision History:

| Rev No. | Date of Issue | Owner or Author | Ext. Review | Appr. By | Revision |
|---------|---------------|-----------------|-------------|----------|---|
| 0 | 2009-04-19 | KDG | MISO | BAP | Modified format and changed naming convention. Was CSOI- 3-5-1-0 |
| 1 | 2010-01-15 | VK | MISO | BAP | Modifications to step 4, step 9 and checklist as per EOP-3325-01, Restricted Operation of Brandon Unit # 5 (Coal) |
| 2 | 2010-05-07 | VK | MISO | BAP | Modifications to step 11 and step 28 to remove Option A curtailable load of 52 MW allocated to Tembec |
| 3 | 2010-12-20 | BM | MISO | BAP | Modifications to steps 1 – 7 to reflect proper ordering of curtailing non-capacity and capacity backed contracts with CT generation |
| 4 | 2012-03-27 | GG | MISO | LSH | Modified section 1 to clearly indicate that this procedure will be invoked immediately when required. |
| 5 | 2012-08-31 | BM | MISO | LSH | Removed ability to curtail non-firm load at Canexus |

1. Purpose:

Procedure to invoke when a capacity or energy emergency is anticipated within the planning horizon, either day ahead or earlier in advance of the operating day.

2. Scope:

Coupled with EOP-3324-1 Emergency Operations - Real Time capacity and Energy Emergency Procedures, this procedure comprises Manitoba Hydro's Capacity and Energy Emergency plan. Communications and instructions to MISO (Reliability Coordinator and Balancing Authority), Independent Electricity System Operator (Balancing Authority), Saskatchewan Power Corporation (Balancing Authority), Customer Service Operations, Power Sales & Operations, and Manitoba Hydro's Public Affairs Department are outlined herein. This procedure applies to capacity and energy emergency procedures for emergencies that are anticipated with Day Ahead or longer lead times.

3. Procedure:

- 3.1. Manitoba Hydro operates and schedules resources inside Manitoba to ensure energy and capacity supplies are adequate to meet Manitoba Hydro domestic load, firm commitments and required operating reserves, considering the single most severe contingency loss. Capacity and energy emergencies should only occur upon multiple contingency losses or during certain planned maintenance outages. Management of capacity and energy emergencies depends if they are slow developing or immediate.
 - 3.1.1 Slowly developing emergencies are those emergencies that can be predicted in advance of the operating day (such as forecast error, predicted equipment failure, drought).
 - 3.1.2 Immediate capacity and energy emergencies are expected to result from a sudden multiple contingency losses as a result of unforeseen circumstances.
- 3.2. This instruction applies to the planning horizon when capacity and energy emergencies are anticipated Day Ahead or further in advance of the operating day. EOP-3324-1 Emergency Operations - Real Time Capacity and Energy Emergency Procedures details emergency operations for the Real Time horizon.

3.3. Possible causes for Planning Horizon Capacity and Energy Emergencies

3.3.1 Loss of HVDC transmission capacity for an extended period

An HVDC transmission loss may develop into an energy or capacity emergency. If the emergency is expected to be extend beyond 4 hours when the ambient temperature is below 0 degrees Celsius or 8 hours when the ambient temperature is above 0 degrees Celsius, HVDC paralleling procedures would be initiated as per NOP-4430-17 among other capacity and energy emergency operating procedures.

3.3.2 Inadequate fuel supply

Power Sales & Operations Division is responsible to ensure that adequate fuel supplies are available to meet energy demands for Manitoba Hydro load and firm commitments. Fuel supplies include water storage in reservoirs, coal, oil, gas, and interconnection contract adverse water clauses. The Generation Reliability Engineer (GRE) is responsible for planning the generation resources on a daily basis within the established guidelines in the Weekly Operating Plan while respecting license conditions. System Control Department staff are responsible to operate within these plans. PSO will interface with the GRE if an energy or capacity emergency is anticipated due to inadequate fuel supply.

3.4. Steps to Manage Anticipated Capacity/Energy Emergencies:

If operating conditions are foreseen where all available resources are insufficient to meet firm load demand, firm transactions, and operating reserves due to forced loss of generation resources, the following steps are to be taken:

1. The Generation Reliability Engineer (GRE) will determine the extent of the emergency through consultation with Power Sales & Operations Division staff.
2. The GRE will inform the Stand-by staff to evaluate the options available to minimize the impacts of the emergency.
3. The Stand-by staff may activate the Dovercourt Emergency Response Team (ERT) at any time during this process (Standards of Conduct must be suspended to include Power Trading Staff on ERT, see NOP-1628-1 Standards of Conduct Administration).
4. The GRE will defer generator maintenance scheduled to commence during the expected emergency time frame and have any generators recalled from maintenance outages, when feasible. If applicable, the GRE will coordinate with the Network Reliability Officer to recall non-forced out transmission

- equipment or defer transmission outages, for outages that restrict import capability or access to MHEB generation capacity.
5. Power Sales & Operations Division will attempt to procure adequate supplies by purchasing or modifying scheduled transactions to mitigate the emergency.
 6. The GRE will make arrangements to schedule thermal generation on line. (Brandon Units 6 and 7 may provide an additional 8 MW per unit during winter operation if the de-icing feature is turned off).
 7. The Stand-by staff or ERT will contact System Performance to verify import capabilities on all interfaces and identify emergency transfer limits.
 8. The GRE will notify Rates Department to curtail Dual Fuel Heating and Industrial Surplus Energy interruptible customer load.
 9. The Stand-by staff or ERT will notify MISO Reliability Coordinator, IESO and SaskPower of the anticipated emergency and provide details and expected duration of emergency operation.
 10. The GRE will request generating stations minimize their non-essential station service demand.
 11. The Stand-by staff or ERT will investigate mitigation alternatives. e.g. HVDC parallel operation, system reconfiguration (temporary bypass etc.).
 12. The Stand-by staff or ERT will contact major customers to initiate voluntary load reduction (see EOP-3324-1).
 13. The Stand-by staff or ERT will contact Public Affairs to plan for and initiate an appeal for voluntary load curtailment (see EOP-3324-1).
 14. The Network Reliability Officer will arrange for a 5% voltage reduction on the distribution system:

Contact each Customer Service Manager and request all distribution stations automatic voltage regulating devices placed on manual and initiate a voltage reduction at each station to 116 volts on the distribution station bus.

- Customer Service Operations Winnipeg West
- Customer Service Operations Winnipeg Central (*)
- Customer Service Operations Westman
- Customer Service Operations Eastman
- Customer Service Operations Parkland
- Customer Service Operations Interlake
- Customer Service Operations North

(*) In Winnipeg Central the following procedure will be initiated to obtain the 5% voltage reduction:

If time does not permit the full execution of any of the steps, proceed to the next step.

- a) Block transformer load tap changers and feeder regulators in their present position
 - b) Lower system voltage to 95% of normal voltage (to achieve 116 V on the stations' distribution bus)
15. The Stand-by staff or ERT will issue operating instructions to SCC as per decisions reached in concert with above departments and distribute to senior management.
16. If the emergency progresses into a Real Time capacity and energy emergency, proceed with steps in EOP-3324-1 Emergency Operations - Real Time Capacity and Energy Emergency Procedures.

4. Reference Documents:

EOP-3324-1 Emergency Operations - Real Time Capacity and Energy
Emergency Procedures

NOP-1628-1 Standards of Conduct Administration

5. Revision History:

| Rev No. | Date of Issue | Owner or Author | Ext. Review | Appr. By | Revision |
|---------|---------------|-----------------|-------------|----------|--|
| 0 | 2009-04-19 | KDG | MISO | BAP | Modified format and changed naming convention. Was CSOI-3-5.1.1 |
| 1 | 2009-06-05 | KDG | | BAP | Expanded step to recall or defer generation outages to include coordinating with Network Reliability Officer to do the same for relevant transmission outages. |
| 2 | 2011-01-26 | GG | | LSH | Added a note that Brandon CTs can supply an additional 8 MW per unit if the de-icing feature is turned off. Replaced GRO with GRE. Other minor changes. |
| 3 | 2012-05-01 | BM | | LAS | General review. Revised roles due to TSO department re-organization. |

A. Introduction

1. **Title:** Reliability Coordination — Transmission Loading Relief (TLR)
2. **Number:** IRO-006-5
3. **Purpose:** To ensure coordinated action between Interconnections when implementing Interconnection-wide transmission loading relief procedures to prevent or manage potential or actual SOL and IROL exceedances to maintain reliability of the bulk electric system.
4. **Applicability:**
 - 4.1. Reliability Coordinator.
 - 4.2. Balancing Authority.
5. **Proposed Effective Date:** First day of the first calendar quarter following the date this standard is approved by applicable regulatory authorities, or in those jurisdictions where regulatory approval is not required; the standard becomes effective on the first day of the first calendar quarter after the date this standard is approved by the NERC Board of Trustees.

B. Requirements

- R1. Each Reliability Coordinator and Balancing Authority that receives a request pursuant to an Interconnection-wide transmission loading relief procedure (such as Eastern Interconnection TLR, WECC Unscheduled Flow Mitigation, or congestion management procedures from the ERCOT Protocols) from any Reliability Coordinator, Balancing Authority, or Transmission Operator in another Interconnection to curtail an Interchange Transaction that crosses an Interconnection boundary shall comply with the request, unless it provides a reliability reason to the requestor why it cannot comply with the request. [*Violation Risk Factor: High*] [*Time Horizon: Real-time Operations*]

C. Measures

- M1. Each Reliability Coordinator and Balancing Authority shall provide evidence (such as dated logs, voice recordings, Tag histories, and studies, in electronic or hard copy format) that, when a request to curtail an Interchange Transaction crossing an Interconnection boundary pursuant to an Interconnection-wide transmission loading relief procedure was made from another Reliability Coordinator, Balancing Authority, or Transmission Operator in that other Interconnection, it complied with the request or provided a reliability reason why it could not comply with the request (R1).

D. Compliance

1. **Compliance Monitoring Process**
 - 1.1. **Compliance Enforcement Authority**

Regional Entity.
 - 1.2. **Compliance Monitoring and Enforcement Processes:**

The following processes may be used:

Compliance Audits

Self-Certifications

Spot Checking

Compliance Violation Investigations

Self-Reporting

Complaints

1.3. Data Retention

The Reliability Coordinator and Balancing Authority shall each keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:

- The Reliability Coordinator and Balancing Authority shall maintain evidence to show compliance with R1 for the most recent twelve calendar months plus the current month.
- If a Reliability Coordinator or Balancing Authority is found non-compliant, it shall keep information related to the non-compliance until found compliant or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

1.4. Additional Compliance Information

None.

Violation Severity Levels

| R # | Lower VSL | Moderate VSL | High VSL | Severe VSL |
|-----|-----------|--------------|----------|--|
| R1 | | | | <p>The responsible entity received a request to curtail an Interchange Transaction crossing an Interconnection boundary pursuant to an Interconnection-wide transmission loading relief procedure from a Reliability Coordinator, Balancing Authority, or Transmission Operator, but the entity neither complied with the request, nor provided a reliability reason why it could not comply with the request.</p> |

E. Variances

None.

F. Associated Documents

None.

G. Version History

| Version | Date | Action | Change Tracking |
|----------------|-------------------|---|------------------------|
| 0 | April 1, 2005 | Effective Date | New |
| 0 | August 8, 2005 | Removed “Proposed” from Effective Date | Errata |
| 1 | August 8, 2005 | Revised Attachment 1 | Revision |
| 3 | February 26, 2007 | Revised Purpose and Attachment 1 related to NERC NAESB split of the TLR procedure | Revision |
| 4 | October 23, 2007 | Completed NERC/NAESB split | Revision |
| 5 | TBD | Removed Attachment 1 and made into a new standard, eliminated unnecessary requirements. | Revision |
| 5 | November 4, 2010 | Approved by the Board of Trustees | |
| 5 | April 21, 2011 | FERC Order issued approving IRO-006-5 (approval effective June 27, 2011) | |

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 pages 16-28 and Chapter 15 at 9:13-21**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such revenue from delivery of hydro
8 energy is important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please provide in computer-readable form for the period beginning January 1, 2007: Hourly
12 pre-schedules and post-schedules on the HVdc system.

13

14 **RESPONSE:**

15 Manitoba Hydro dispatches generating resources to meet domestic load demand and
16 interchange commitments. Depending on the hydraulic conditions, hydro generation is typically
17 dispatched firstly at Winnipeg River, Kelsey, Jenpeg, and Wuskwatim, followed by HVdc and
18 Grand Rapids generation, and lastly the thermal generation at Selkirk and Brandon. Once the ac
19 hydro generation is fully dispatched, any further changes in load and interchange schedules will
20 be followed by HVdc generation. As a result, there is no normally termed “schedules” on the
21 HVdc system. Rather the HVdc generation is dispatched as required. Hourly HVdc loading is
22 Commercially Sensitive Information and cannot be filed on the public record.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 pages 16-28 and Chapter 15 at 9:13-21**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such revenue from delivery of hydro
8 energy is important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please provide in computer-readable form for the period beginning January 1, 2007: Manitoba
12 Hydro's hourly integrated demand.

13

14 **RESPONSE:**

15 Please see the [attachment](#) to this response.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 5 pages 16-28 and Chapter 15 at 9:13-21**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such revenue from delivery of hydro
8 energy is important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please provide in computer-readable form for the period beginning January 1, 2007: Manitoba
12 Hydro's hourly locational marginal price at the Manitoba-MISO interconnection(s).

13

14 **RESPONSE:**

15 The response to this Information Request would require the disclosure of Commercially
16 Sensitive Information and cannot be filed on the public record.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 15 at 11:16-19**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such revenue from delivery of hydro
8 energy is important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Manitoba Hydro states that it will have an increase in import transfer capability up to 1500 MW
12 with the construction of the Great Northern Transmission Project. Will this increased transfer
13 capability exist without the construction of the Manitoba-Minnesota Transmission Project?

14

15 **RESPONSE:**

16 No. The increased import capability requires the construction of new transmission due to both
17 thermal and voltage issues. The 750 MW 500 kV Manitoba-Minnesota Transmission Project
18 increases both the export and import capability by 750 MW over today's capability of 700 MW
19 import and 2175 MW export. Therefore, the new capability will be 1450 MW import and 2925
20 MW export.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 6 at 5:22-27**

4

5 **PREAMBLE:** The NPV of the alternatives depends in part upon the amount of revenue
6 received from exports to the U.S. The costs of transmission and the ability of the
7 transmission to deliver this power is at issue.

8

9 **QUESTION:**

10 Manitoba Hydro notes that generation and transmission are being built in MISO to take
11 advantage of windows of opportunity to fulfill RPS requirements. Has Manitoba Hydro
12 analyzed the expected costs of MISO's currently proposed transmission investment over the
13 next 10 years and, if so, please provide such studies?

14

15 **RESPONSE:**

16 The referenced section in Chapter 6 said several things:

- 17
- 18 • “Over the next several years, Manitoba Hydro anticipates that there will be generation and
19 transmission investment driven by RPS requirements.” Over the past four MISO MTEP
20 studies, investment has been: \$1.2 B (MTEP10), \$6.4B (MTEP11), \$1.5B (MTEP12), and
21 \$1.5B (MTEP13). Significant transmission investment was approved for a multi-valued
22 portfolio of seventeen projects in MTEP11 to provide regional public policy benefits (i.e. RPS
23 requirements). The majority of the investment in MTEP13 is for reliability needs. Proposed
24 air regulations show the potential for a 3-7 GW capacity shortfall as early as 2016. MTEP
25 futures assume between 5-9 GW of new wind and up to 2 GW of solar will be added by
26 2028 based on the current state mandate or goal. Therefore, significant investment in MISO
27 is expected over the next 10-15 years to help integrate wind and solar to meet state RPS
28 requirements.
 - 29 • Ref:[https://www.misoenergy.org/Library/Repository/Study/MTEP/MTEP13/MTEP13%20Re
port.pdf](https://www.misoenergy.org/Library/Repository/Study/MTEP/MTEP13/MTEP13%20Report.pdf)

1 • “Manitoba Hydro currently has an opportunity to build new transmission as part of a
2 regional plan that includes infrastructure to meet RPS requirements or assist with regional
3 wind integration.” The opportunity is twofold. On the one hand, Minnesota Power needs
4 250 MW to meet its long term capacity and energy needs and the new transmission helps to
5 facilitate that transaction. On the other hand, the new line increases regional reliability,
6 increases Manitoba to U.S. transfer bi-directional capability and allows for optimization of
7 renewable energy resources. This was well documented in the Manitoba-MISO wind
8 synergy report and summarized in MTEP2013.

9 Manitoba Hydro does not have a report that analyzes the cost of MISO’s investment plan over the
10 next ten years. MISO is responsible for ensuring the investment is prudent. The best documentation
11 available are the MISO MTEP reports, which are publicly available on MISO’s website.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 6 at 5:22-27**

4

5 **PREAMBLE:** The NPV of the alternatives depends in part upon the amount of revenue
6 received from exports to the U.S. The costs of transmission and the ability of the
7 transmission to deliver this power is at issue.

8

9 **QUESTION:**

10 Manitoba Hydro notes that generation and transmission are being built in MISO to take
11 advantage of windows of opportunity to fulfill RPS requirements. Will Manitoba Hydro pay a
12 share of the MISO's currently proposed transmission investment over the next 10 years?

13

14 **RESPONSE:**

15 No, Manitoba Hydro will not pay a share of the MISO's currently proposed transmission
16 investment over the next 10 years. The other MISO transmission projects are proceeding
17 without Manitoba Hydro's involvement and Manitoba Hydro will not be responsible for a share
18 of these other transmission project costs.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 6 at 5:22-27**

4

5 **PREAMBLE:** The NPV of the alternatives depends in part upon the amount of revenue
6 received from exports to the U.S. The costs of transmission and the ability of the
7 transmission to deliver this power is at issue.

8

9 **QUESTION:**

10 Manitoba Hydro notes that generation and transmission are being built in MISO to take
11 advantage of windows of opportunity to fulfill RPS requirements. Will Manitoba Hydro benefit
12 from transmission currently being planned in MISO, and if so, please describe the expected
13 benefit to Manitoba Hydro both in dollars and other forms of benefits and, if so, how much
14 does Hydro anticipate its share will be.

15

16 **RESPONSE:**

17 The MISO transmission build out is occurring regardless of Manitoba Hydro's plans and
18 Manitoba Hydro will not directly benefit from these transmission projects as they will not
19 increase the transfer capability between Manitoba and MISO. Therefore, there will be no direct
20 incremental benefit or costs to Manitoba Hydro.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 6 at 27:19-23**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such revenue from delivery of hydro
8 energy is important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Chapter 6 page 27 at 19:22 states: "For those development plans in which Keeyask and
12 Conawapa are both constructed, it is expected that transmission improvements will be required
13 in the Manitoba Hydro system once the second plant comes into service to be able to transmit
14 all the firm power to southern Manitoba. As the additional north-south transmission would not
15 be required for over ten years, the final determination of the design will be made nearer to the
16 time it is needed." Please provide all studies showing that the transmission of Keeyask power
17 will not depend upon the North-South Transmission Project.

18

19 **RESPONSE:**

20 The response to this Information Request would require the disclosure of commercially
21 sensitive information.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 7, Figure 7.3 at page 11**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such revenue from delivery of hydro
8 energy is important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Referring to Figure 7.3 in Chapter 7 at page 11, please provide detailed documentation
12 describing the calculation of the levelized cost of the various types of resource technologies.

13

14 **RESPONSE:**

15 Please see Manitoba Hydro's response to LCA/MH I-308.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 7, Figure 7.3 at page 11**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such revenue from delivery of hydro
8 energy is important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Referring to Figure 7.3 in Chapter 7 at page 11, does the levelized cost of any of the
12 technologies include the costs of Bipole III, the Manitoba-Minnesota Transmission Project or
13 the North-South Transmission Upgrade Project?

14

15 **RESPONSE:**

16 The levelized costs of resource technologies shown in Figure 7.3 only include transmission
17 sufficient to connect to the grid. As a result the levelized costs shown in Figure 7.3 do not
18 contain the costs associated with the Bipole III, Manitoba-Minnesota or North-South
19 transmission projects.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 7, Figure 7.3 at page 11**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such revenue from delivery of hydro
8 energy is important to the economics of the various alternatives.

9

10 **QUESTION:**

11 If the answer to part (b) is no, please explain why the hydro technology does not include these
12 costs; if the answer to part (b) is yes, please provide the levelized cost of each transmission
13 project (Bipole III, MMTP or the North-South Transmission Upgrade Project) attributable to
14 each type of resource studied.

15

16 **RESPONSE:**

17 It is typical of levelized cost calculations for generation technologies to contain costs for
18 generation and transmission to the point of connection to the grid to allow for comparison
19 and facilitate high level screening.

20

21 The cost of transmission projects such as the Manitoba-Minnesota Transmission Project and
22 the North-South Transmission Upgrade Project are included as part of a comprehensive plan to
23 meet growing domestic loads and firm export commitments. The various development plans
24 that were created and presented as part of the Business Case include the costs of transmission
25 required to provide the benefits associated with each development plan.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 9 at 6:3 - 7:7 and Appendix 9.2**

4

5 **PREAMBLE:** The NPV of the alternatives depends in part upon the amount of revenue
6 received from exports to the U.S. The costs of transmission and the ability of the
7 transmission to deliver this power is at issue.

8

9 **QUESTION:**

10 Manitoba's SPLASH generation system production cost model contains inputs for the electricity
11 export prices and proposed export power sales, as well as flow-related electricity export
12 revenues. Please provide in computer readable form the inputs for the electricity export prices
13 and proposed power sales, including amounts, prices, types by year and by development plan,
14 including the amount of associated revenue by each type of export sale by year by plan.

15

16 **RESPONSE:**

17 The inputs requested have not been provided as they are considered Commercially Sensitive
18 information.

19

20 Please see Appendix 3.1 of the NFAT Business Case entitled “Long-Term Price Forecast for
21 Manitoba Hydro’s Export Market in MISO – The Brattle Group” for a general explanation of the
22 expected trend of future electricity prices in MISO.

23

24 Please also see Appendix 9.3 of the NFAT Business Case, Tables 1.4 to Tables 1.11, which
25 contain long-term import and export contracts.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Appendix 9.3 at 1.5.1.2, 1.5.1.3, and 1.5.1.4**

4

5 **PREAMBLE:** The NPV of the alternatives depends in part upon the amount of revenue
6 received from exports to the U.S. The costs of transmission and the ability of the
7 transmission to deliver this power is at issue.

8

9 **QUESTION:**

10 Please provide on an annual basis the final long-term price forecasts for on-peak all-in, on-peak
11 long-term firm dependable and off-peak energy, for each of the 2012/13, August 2012/2013
12 and 2013/2014 Energy Price Forecasts described in Appendix 9.3 at Sections 1.5.1.2, 1.5.1.3 and
13 1.5.1.4.

14

15 **RESPONSE:**

16 Response to this Information Request would require the provision of Commercially Sensitive
17 Information.

18

19 Please see Appendix 3.1 of the NFAT Business Case entitled “Long-Term Price Forecast for
20 Manitoba Hydro’s Export Market in MISO – The Brattle Group” for a general explanation of the
21 expected trend of future electricity prices in MISO.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 9, Figure 9.3 at page 25.**

4

5 **PREAMBLE:** The NFAT describes in Chapter 5, pages 7-11, the attributes and necessity
6 for its HVDC and AC transmission system in order to serve Manitoba customers and
7 deliver hydro energy to Manitoba and elsewhere. Such revenue from delivery of hydro
8 energy is important to the economics of the various alternatives.

9

10 **QUESTION:**

11 Please explain why the NPVs for water rental, capital tax transfer and provincial guarantee fees
12 are not subtracted from the NPV of the Benefits to Manitoba Hydro and instead appear as
13 cumulative benefits.

14

15 **RESPONSE:**

16 The NPVs for water rental, capital tax transfer and provincial guarantee fees are already
17 included as a cost in the calculation of the NPV of Benefits to Manitoba Hydro. The reason they
18 are added back in Figure 9.3 and appear as cumulative benefits is to provide an indication of
19 the economic benefit to the Province as a whole.

20

So, from the perspective of Manitoba Hydro, the water rental, capital tax transfer and provincial guarantee fees are a cost. From the perspective of the provincial government and taxpayers, they are a benefit.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 13 at 23, Table 13.2**

4

5 **QUESTION:**

6 Table 13.2 in Chapter 13 shows the incremental capital expense between four alternatives.

7 Please explain how the Preferred Development Plan is only \$3.5 billion more than the

8 K19/G24/250MW plan when Conawapa is anticipated to cost more than \$10 billion alone.

9

10 **RESPONSE:**

11 The incremental capital expenditure values summarized in Table 13.2 of Chapter 13 are 2014

12 incremental present values calculated using a 6% real discount rate and expressed in millions of

13 2014 dollars. The difference of approximately \$3.5 billion present value dollars between the

14 Preferred Development Plan and the K19/Gas24/250MW plan is consistent with the difference

15 in the capital expenditure assumptions used in the economic evaluations provided in Chapters

16 9 and 10 of the submission. The approximate \$10 billion estimate for Conawapa is expressed in

17 nominal dollars, or in-service dollars, and includes interest and escalation during construction.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: Chapter 13 at 27:4-12**

4

5 **QUESTION:**

6 Referring to Chapter 13 at 27:4-12, please provide all spreadsheets calculating the expected
7 unserved energy costs of the Preferred Development Plan and the three other alternatives
8 reviewed, including the amount of unserved energy assumed under each alternative annually.

9

10 **RESPONSE:**

11 The calculations are provided in the Appendix E of the NFAT Reliability Evaluation report which
12 is referred to as Appendix 13.1. The original calculations are provided in the attached
13 spreadsheet "[Present Worth Calculation-MMF-033](#)".

1 **SUBJECT: Environmental Impacts**

2

3 **REFERENCE: MMF/MH I-028**

4

5 **PREAMBLE:** With respect to the North-South Transmission System Upgrade Project,
6 approximately 452 km of additional transmission lines are proposed (Kelsey GS to
7 Birchtree Station - 80 km, Birchtree Station to Wuskwatim GS - 42 km, Herblet Lake
8 Station to Overflowing River Station - 210 km, Vermillion Station to Neepawa Station -
9 130k) (Business Case, Section 2.3.1, p. 54). These new lines may or may not follow
10 existing lines. The new lines will increase habitat loss and fragmentation on the
11 landscape. The Bipole III Project includes 1,384 km of new transmission lines.

12

13 The table “Macro-environmental comparison of Resource Options” from CAC/MH I-231a
14 does not include the 452 km of transmission lines discussed above or the footprint of
15 the Bipole III project. Rather it simply states that the North-South Upgrade Project is
16 under study. Residual effects of these transmission lines will fall within the study areas
17 of those components that are part of the PDP. Therefore, they need to be considered in
18 a cumulative environmental effects assessment of the PDP and alternative plans.

19


20 **QUESTION:**

21 Provide a map showing the hypothetical locations of these new transmission lines within
22 Manitoba.

23

24 **RESPONSE:**


25 Please see the attachment file (MMF/MH II-034a Attachment), which shows the terminating
26 stations of the proposed new lines. The final line routings would be subject to the enviromental
27 and licensing process.



Legend

- North South Transmission Project
- Conawapa Generation Outlet Transmission Project
- Final Preferred Route (July 18 2013)
- Bipole I & II (Existing)
- Existing Transmission Line - 500 kV
- - - Existing Transmission Line 138-230 kV
- Road
- Railway Line
- First Nation
- Wildlife Management Area
- National/Provincial Park
- Provincial Forest

Future Transmission Station Connections



Projection: UTM
 Datum: NAD 1983
 Zone: 14N
 False Easting: 500000
 False Northing: 0
 Central Meridian: -99
 Scale Factor: 0.9996
 Latitude Of Origin: 0
 Linear Unit: Meter
 Scale: 1:500 000



1 **SUBJECT: Environmental Impacts**

2

3 **REFERENCE: MMF/MH I-028**

4

5 **PREAMBLE:** With respect to the North-South Transmission System Upgrade Project,
6 approximately 452 km of additional transmission lines are proposed (Kelsey GS to
7 Birchtree Station - 80km, Birchtree Station to Wuskwatim GS - 42km, Herblet Lake
8 Station to Overflowing River Station - 210km, Vermillion Station to Neepawa Station -
9 130k) (Business Case, Section 2.3.1, p. 54). These new lines may or may not follow
10 existing lines. The new lines will increase habitat loss and fragmentation on the
11 landscape. The Bipole III Project includes 1,384 km of new transmission lines.

12

13 The table “Macro-environmental comparison of Resource Options” from CAC/MH I-231a
14 does not include the 452 km of transmission lines discussed above or the footprint of
15 the Bipole III project. Rather it simply states that the North-South Upgrade Project is
16 under study. Residual effects of these transmission lines will fall within the study areas
17 of those components that are part of the PDP. Therefore, they need to be considered in
18 a cumulative environmental effects assessment of the PDP and alternative plans.

19

20 **QUESTION:**

21 Include the residual biophysical effects of the Bipole III Project in the evaluation of cumulative
22 environmental effects for the PDP and other alternatives.

23

24 **RESPONSE:**

25 Cumulative effects assessments will be undertaken in conjunction with environmental
26 assessments of all projects identified in the preferred and alternative development plans,
27 before any project is licensed and developed. (For example, Bipole III was considered in the
28 cumulative effects of the Keeyask Project, for which the Clean Environment Commission
29 recently completed public hearings.) As appropriate, Bipole III will be considered in the
30 cumulative effects assessments of those projects in the preferred and alternative development
31 plans.

1 **SUBJECT: Environmental Impacts**

2

3 **REFERENCE: MMF/MH I-028**

4

5 **PREAMBLE:** With respect to the North-South Transmission System Upgrade Project,
6 approximately 452 km of additional transmission lines are proposed (Kelsey GS to
7 Birchtree Station - 80km, Birchtree Station to Wuskwatim GS - 42km, Herblet Lake
8 Station to Overflowing River Station - 210km, Vermillion Station to Neepawa Station -
9 130k) (Business Case, Section 2.3.1, p. 54). These new lines may or may not follow
10 existing lines. The new lines will increase habitat loss and fragmentation on the
11 landscape. The Bipole III Project includes 1,384 km of new transmission lines.

12 The table “Macro-environmental comparison of Resource Options” from CAC/MH I-231a
13 does not include the 452 km of transmission lines discussed above or the footprint of
14 the Bipole III project. Rather it simply states that the North-South Upgrade Project is
15 under study. Residual effects of these transmission lines will fall within the study areas
16 of those components that are part of the PDP. Therefore, they need to be considered in
17 a cumulative environmental effects assessment of the PDP and alternative plans.

18

19 **QUESTION:**

20 “Proximity to Load Centre” falls under “Social & Policy” rather than “Environmental”. Please
21 explain how the environmental impact of transmission lines is a social or policy issue.

22

23 **RESPONSE:**

24 For the purpose of screening resource technologies, the characteristic Proximity to Load Centre
25 has been grouped into the category of “Social & Policy” and is a proxy for a combination of
26 different social and policy issues including those associated with transmission right-of-ways. In
27 the context of social impacts of projects, two of these issues include the potential impacts, Land
28 Use and Wildlife Species of Interest. Some associated social or policy issues with these
29 environmental characteristics include, and are not limited to, the following:

- 30
- Increased accessibility to formerly isolated wildlife species of interest potentially
31 affecting hunters, trappers and other resource harvesters.

- 1 • Increased land use impacts potentially affecting hunters, trappers, farmers and others
2 wishing to undertake a development within a transmission right-of-way corridor.
- 3 • Increased land use impacts potentially associated with right-of-way vegetation
4 management potentially affecting hunters, trappers, farmers and others wishing to
5 utilize areas near a transmission right-of-way corridor.
- 6 • Aesthetic issues associated with transmission rights-of-way may be an environmental
7 issue but are also a social or a policy matter.
- 8 • A transmission line ROW can also affect commercial resource based industries including
9 forestry, and mining. In addition commercial tourism operations such as lodges and
10 outfitters can also be affected. These would all be considered in socio-economic impact
11 assessment.
- 12 • Implications to conservation and protected lands are considered in routing and
13 assessment as well as heritage and archeological resources
- 14 • Potential effects on the transportation system and community services are also
15 considered in socio-economic assessment.
- 16 • Longer transmission has a greater risk of weather related impacts such as icing and its
17 associated loss of line impacts, which have the potential for short-term social impacts.

1 **SUBJECT: Environmental Impacts**

2

3 **REFERENCE: MMF/MH I-029c**

4

5 **PREAMBLE:** Cumulative effects are of an additive, interactive, synergistic, and often
6 indirect nature (Hegmann et al. 1999). Transmission interconnections to other
7 jurisdictions are not considered in each resource technology; however, they are likely to
8 be induced effects of the PDP.

9

10 **QUESTION:**

11 Please clarify whether or not interconnections to other jurisdictions have been considered
12 within the assessment of macro-environmental effects of the PDP.

13

14 **RESPONSE:**

15 Manitoba Hydro notes that the referenced Information Request, MMF/MH I-029c references
16 Manitoba Hydro's screening of individual resource options. As indicated in the response to
17 MMF/MH I-029c, transmission interconnections are not part of the screening of resource
18 options because the transmission interconnections are not required to develop the individual
19 resources.

20

21 However, the transmission interconnections are considered at a development plan level. The
22 macro-environmental effects of the transmission interconnection in the Preferred Development
23 Plan have been considered and are described in the response to CAC/MH I-231a.

1 **SUBJECT: Socio-economic impacts: employment**

2

3 **PREAMBLE:** In the "Socio-economic Comparison of Resource Options" table (CAC/MH
4 1-231a), employment estimates are provided for the Keeyask, Conawapa, Gas, and Wind
5 Resource Options. Construction employment estimates are greatest for Keeyask (4300
6 direct, 3400 indirect) and Conawapa (5000 direct, 4100 indirect), with Northern and
7 Aboriginal employment at 500-1700 for Keeyask, and greater for Conawapa, though not
8 yet known.

9 To understand not only employment effects, but other potential socio-economic effects,
10 it is necessary to have an understanding of the estimated direct employment, per year,
11 for each project, as well as for both projects.

12

13 **QUESTION:**

14 Please confirm the up-to-date construction schedule estimates (preferably by month, if
15 available) for the Keeyask and Conawapa projects.

16

17 **RESPONSE:**

18 Please refer to the NFAT Submission Chapter 15 Figure 15.3 and Figure 15.4 for the up-to-date
19 construction schedule estimates for the Keeyask and Conawapa projects respectively.

1 **SUBJECT: Socio-economic impacts: employment**

2

3 **REFERENCE: MMF/MH 1-001a; MMF/MH 1-001b**

4

5 **PREAMBLE:** In the "Socio-economic Comparison of Resource Options" table (CAC/MH
6 1-231a), employment estimates are provided for the Keeyask, Conawapa, Gas, and Wind
7 Resource Options. Construction employment estimates are greatest for Keeyask (4300
8 direct, 3400 indirect) and Conawapa (5000 direct, 4100 indirect), with Northern and
9 Aboriginal employment at 500-1700 for Keeyask, and greater for Conawapa, though not
10 yet known.

11

12 To understand not only employment effects, but other potential socio-economic effects,
13 it is necessary to have an understanding of the estimated direct employment, per year,
14 for each project, as well as for both projects.

15

16 **QUESTION:**

17 Please provide the locations where it is anticipated the direct workforce will reside, and specify
18 the number of workers that will reside in camps versus communities.

19

20 **RESPONSE:**

21 Keeyask construction workers will be housed at a camp capable of accommodating up to 2000
22 people on the north shore of Gull Rapids. The camp will be 140 kilometers via the north access
23 road from Gillam and 190 kilometers from Thompson. The 50 – 100 workers for the south
24 access road will likely reside in camp accommodations south of the river, but the exact location
25 has not yet been determined.

26

27 According to current plans, Conawapa construction workers will be housed in a camp capable
28 of accommodating 2,500 people. It is currently planned to be located two kilometers southwest
29 of the generating station site. By road, the Conawapa construction camp is approximately 29
30 km northeast of Fox Lake Cree Nation (Bird Lake) and 88 km northeast of Gillam.

- 1 Few, if any, construction workers are expected to commute to either construction site on a
- 2 daily basis.
- 3
- 4 Operational staff will commute on a daily basis to Keeyask. Operational staff at Conawapa will
- 5 commute on a rotational basis and will be accommodated in a staff house near the generating
- 6 station.

1 **SUBJECT: Socio-economic impacts: business opportunities**

2

3 **REFERENCE: MMF/MH 1-001a; MMF/MH 1-001b**

4

5 **PREAMBLE:** The "Socio-economic Comparison of Resource Options" table (CAC/MH 1-
6 231a) provides a figure of \$200 million for Northern and Aboriginal Local Business
7 Opportunities. The text that follows (p.23 of 29) states that "Total value of the contracts
8 to the four Cree Nations will total over \$200 million, which is substantial for these
9 communities with limited experience."

10

11 **QUESTION:**

12 Please confirm whether the \$200 million in contracts in the Socio-economic Comparison of
13 Resource Options table in CAC-MH I-231a is entirely planned for the KCNs.

14

15 **RESPONSE:**

16 Yes, the \$200 million in contracts identified in the aforementioned table are entirely planned
17 for the KCNs and were negotiated as part of the Joint Keeyask Development Agreement (JKDA).
18 Please see the response to PUB/MH II-499b for more information.

1 **SUBJECT: Socio-economic impacts: business opportunities**

2

3 **REFERENCE: MMF/MH 1-001a; MMF/MH 1-001b;**

4

5 **PREAMBLE:** The text on p.23 (CAC/MH 1-231a) refers to concerns raised by the MMF
6 regarding the difference in business opportunities between the KCNs and other
7 Northern and Aboriginal groups and communities, to which Manitoba Hydro states that
8 "The Partnership's analysis of the existing environment; the appropriateness of its
9 mitigation, monitoring and adaptive management plans; and conclusions regarding
10 business opportunities are the subject of review in the environmental review process."
11 The PUB process defers to the CEC process for socioeconomic assessment information,
12 however, the Metis have not been identified as a distinct and separate group in the CEC
13 process, and Metis-specific effects have not been identified and assessed as such.

14

15 **QUESTION:**

16 Please indicate the dollar amount of contracts in relation to the PDP that are anticipated to be
17 filled by Northern and Aboriginal businesses other than the KCNs.

18

19 **RESPONSE:**

20 On the Keeyask project, all contracts not designated as Direct Negotiation Contracts with the
21 KCNs will be procured through an open-tender-process and as such, it is not possible to
22 estimate the dollar amount of contracts that may be filled by northern and Aboriginal
23 businesses other than the KCNs. All northern and Aboriginal businesses, other than the KCNs,
24 will have the opportunity to submit tenders on this work as well as sub contracting
25 opportunities on a number of different contracts. The KCNs will have an opportunity to bid on
26 subcontracting opportunities via the bid depository process as outlined in the Joint Keeyask
27 Development Agreement.

1 Manitoba Hydro's Northern Purchase Policy encourages participation in business and
2 employment opportunities for Aboriginal northern communities within the Northern Affairs
3 boundary. Regarding the procurement process, Manitoba Hydro maintains a Vendor Database
4 which is populated based on vendor input via Vendor Registration (see website
5 http://www.hydro.mb.ca/selling_to_mh/vendor_information.shtml). Vendors are asked to self
6 declare status of being a Northern Aboriginal Contractor. Definitions are:

- 7 i. Northern Aboriginal: A First Nations, Non-status Indian, Métis or Inuit person who has
8 resided in Manitoba, north of the Northern Affairs Boundary, for a cumulative period of
9 5 years or more.
- 10 ii. Northern Aboriginal contractor: a Northern business (including Aboriginal Joint Venture,
11 partnership or corporation) that is:
- 12 • at least 51 per cent owned and controlled by a Northern Aboriginal; and
 - 13 • if the business has 6 or more full-time staff, at least one-third of them are Aboriginal
14 people.

15 Project Development Agreements for Conawapa are currently under negotiation and dollar
16 amounts are not yet determined.

1 **SUBJECT: Socio-economic impacts: infrastructure and services**

2

3 **REFERENCE: MMF/MH 1-001a; MMF/MH 1-001b; CAC/MH 1-231a**

4

5 **PREAMBLE:** Under the "Infrastructure and Services" component/topic of the "Socio-
6 economic Comparison of Resource Options" table (CAC/MH 1-231a), the only factor
7 considered is housing. The text on p.5 of 29 (CAC/MH 1-231a) states that "...the socio-
8 economic matrix focuses on housing, for which proponents of large projects accept
9 some measure of responsibility. However, the matrix does not include other services
10 such as transportation, health care and policing for which other agencies take a leading
11 responsibility." For large projects, it is not unusual for project-specific socio-economic
12 effects to require management from a responsible party other than the proponent. It is
13 also understood that responsible parties are better able to respond to changes (for
14 example, in demand for services) with complete and detailed information regarding
15 potential project effects.

16

17 **QUESTION:**

18 Please provide a rationale, other than that already provided (i.e. that other agencies have a
19 lead responsibility) for not including other items under Infrastructure and Services (e.g.
20 transportation, health care, and policing) on which the various resource options may have an
21 effect.

22

23 **RESPONSE:**

24 On September 30, 2013 Manitoba Hydro undertook to provide matrices of macro
25 environmental and socio-economic issues comparing Keeyask, Conawapa, gas turbines and
26 wind generation. PUB Order 119/13 added demand side (DSM) to the resource options to be
27 considered in the matrices, and Manitoba Hydro has chosen to also include transmission
28 projects. The matrices were filed in response to CAC/MH I-231a.

1 As noted in that response, the Keeyask Generation Project environmental impact assessment
2 identified 38 valued environmental components and dozens more supporting topics. The VECs
3 were originally selected through a process involving the members and advisers from Keeyask
4 Cree Nations, staff of Manitoba Hydro and professionals in their respective fields. The list was
5 subsequently shared with government specialists and other interested communities and
6 organizations, which resulted in adjustments to the list.

7

8 The NFAT Terms of Reference explicitly state that the environmental reviews are beyond the
9 NFAT's scope. Rather, the PUB directed that "a high level summary" be produced for the socio-
10 economic analysis. The matrices and accompanying text in CAC/MH I-231a is intended to meet
11 the PUB's objectives. The selection of topics is explained in CAC/MH I-231a.

1 **SUBJECT: Socio-economic impacts: infrastructure and services**

2

3 **REFERENCE: MMF/MH 1-001a; MMF/MH 1-001b;**

4

5 **PREAMBLE:** Under the "Infrastructure and Services" component/topic of the "Socio-
6 economic Comparison of Resource Options" table (CAC/MH 1-231a), the only factor
7 considered is housing. The text on p.5 of 29 (CAC/MH 1-231a) states that "...the socio-
8 economic matrix focuses on housing, for which proponents of large projects accept
9 some measure of responsibility. However, the matrix does not include other services
10 such as transportation, health care and policing for which other agencies take a leading
11 responsibility." For large projects, it is not unusual for project-specific socio-economic
12 effects to require management from a responsible party other than the proponent. It is
13 also understood that responsible parties are better able to respond to changes (for
14 example, in demand for services) with complete and detailed information regarding
15 potential project effects.

16

17 There is concern that project construction will result in increased demand on
18 infrastructure and services in the project area(s), and that this effect will be greatest for
19 current Northern and Aboriginal residents who will experience a change in their ability
20 to access or use infrastructure and services at current levels. It is presently not known
21 whether construction schedules for Keeyask and Conawapa will overlap, but in the case
22 that they do, it is anticipated that these effects will be of a greater magnitude.

23

24 It is also understood that each project will undergo a separate environmental review
25 process; however, there is an additional concern that these separate review processes
26 will fail to consider the combined effects of the separate PDP components.

27

28 **QUESTION:**

29 Please describe how the combined socio-economic effects of the separate components of the
30 PDP will be considered and assessed, and through which process.

31

32 **RESPONSE:**

33 Manitoba Hydro notes there are a number of the concerns and statements in the preamble
34 regarding infrastructure and services that are currently being considered and addressed.

1 According to the Cumulative Effects Assessment Summary for the Keeyask Generation Project
2 Environmental Impact Statement:

3 It is anticipated that the influx of non-local construction workers from future projects
4 will add to the pressure on community-based infrastructure and services, particularly
5 emergency (i.e., RCMP) and social services in Gillam. Future project and activities may
6 increase the magnitude of effects from small to moderate for the short term due to an
7 increase in workers and associated service needs. Collaborative mitigation measures are
8 in place to address these concerns.

9
10 The Keeyask Project, in particular the generating project, has undergone many years of
11 environmental study involving Manitoba Hydro and the Keeyask Cree Nations. In effect, it has
12 been subject to two environmental evaluations, the first by the KCNs based on their own Cree
13 world view and the next by the partnership for the regulatory reviews currently being
14 conducted by the federal and provincial governments.

15
16 The regulatory reviews of the Keeyask Project under *The Environment Act* (Manitoba) and the
17 *Canadian Environmental Assessment Act* include a cumulative effects assessment that considers
18 effects of past, current and future projects. The Keeyask cumulative effects assessment is
19 available in chapter 7 of the Response to the EIS Guidelines, filed as part of the Keeyask
20 Environmental Impact Statement. The Cumulative Effects Assessment Summary was
21 subsequently filed in the CEC proceedings in July 2013 in response to CEC Rd1 CEC-0020.
22 Through this mechanism, the combined socio-economic effects of projects with overlapping
23 spatial and temporal effects are considered.

24
25 Conawapa and the transmission projects will also be subject to extensive environmental
26 assessments that will include cumulative effects assessments.

1 **SUBJECT: Socio-economic impacts: infrastructure and services**

2

3 **PREAMBLE:** Under the "Infrastructure and Services" component/topic of the "Socio-
4 economic Comparison of Resource Options" table (CAC/MH 1-231a), the only factor
5 considered is housing. The text on p.5 of 29 (CAC/MH 1-231a) states that "...the socio-
6 economic matrix focuses on housing, for which proponents of large projects accept
7 some measure of responsibility. However, the matrix does not include other services
8 such as transportation, health care and policing for which other agencies take a leading
9 responsibility." For large projects, it is not unusual for project-specific socio-economic
10 effects to require management from a responsible party other than the proponent. It is
11 also understood that responsible parties are better able to respond to changes (for
12 example, in demand for services) with complete and detailed information regarding
13 potential project effects.

14

15 There is concern that project construction will result in increased demand on
16 infrastructure and services in the project area(s), and that this effect will be greatest for
17 current Northern and Aboriginal residents that will experience a change in their ability
18 to access or use infrastructure and services at current levels. It is presently not known
19 whether construction schedules for Keeyask and Conawapa will overlap, but in the case
20 that they do, it is anticipated that these effects will be of a greater magnitude.

21

22 It is also understood that each project will undergo a separate environmental review
23 process; however, there is an additional concern that these separate review processes
24 will fail to consider the combined effects of the separate PDP components.

25

26 **QUESTION:**

27 Please estimate the combined effects of the Keeyask and Conawapa projects on Infrastructure
28 and Services, including housing, transportation, health care services, and policing.

29

30 **RESPONSE:**

31 As noted in the response to MH/MMF I-38d, infrastructure and services have been considered
32 in the Cumulative Effects Assessment Summary for the Keeyask Generation Project

1 Environmental Impact Statement. As such, Manitoba Hydro notes that these topics are subject
2 to full review under the environmental reviews.

3

4 The following are extracted from the Cumulative Effects Assessment Summary:

- 5 • Housing: The summary notes that construction workers will be housed in construction
6 camps, Manitoba Hydro has plans to upgrade and increase housing in Gillam, and
7 income earned by the KCNs through their project investment could be used to invest in
8 community housing. The summary then concludes: “All future projects require
9 additional workforces with some workers likely drawn from within and outside the Local
10 Study Area. This non-local workforce may place an increased demand for housing in
11 Gillam and Thompson, although the Gillam Redevelopment Program will offset some of
12 that demand. Existing house shortages in KCNs, short term crowding and ongoing
13 demand for temporary accommodation may occur with the [Keeyask] Project in
14 combination with future projects.”
- 15 • Travel, access and safety: The summary notes Manitoba Infrastructure and Services is
16 improving PR 280 prior to the Keeyask Generation Project, and the project will re-route
17 PR 280 over the generating station, thereby reducing the travel distance between Gillam
18 and Thompson. It concludes: “Other future projects are not expected to overlap [with
19 the Keeyask Project] spatially with water or ice-based travel. In terms of road travel
20 safety, the expected increases in traffic due to cumulative effects of the [Keeyask]
21 Project (during the construction phases) with other future projects may result in overall
22 moderate to large residual effects for a short period of project overlap; however, the
23 conclusion from the residual effects significance assessment in chapter 6 remains
24 unchanged [i.e. it is not significant].”

- 1 • Transportation: The summary concludes, “With future projects and activities, traffic is
2 expected to increase sizably; however, due to road and service upgrades, the
3 significance of effects is not expected to increase.”
- 4 • Health care services and policing: Health care services and policing are included under
5 “Infrastructure and Services” in the summary. Proposed mitigation includes on-going
6 communication with services providers to allow for effective and timely planning of
7 service delivery; emergency medical and ambulance services and a health clinic at the
8 construction camp; and efforts with the Northern Regional Health Authority to secure
9 on-site public health care professionals for the project. The summary concludes: “It is
10 anticipated that the influx of non-local construction workers from future projects will
11 add to the pressure on community-based infrastructure and services, particularly
12 emergency (i.e., RCMP) and social services in Gillam. Future project and activities may
13 increase the magnitude of effects from small to moderate for the short term due to an
14 increase in workers and associated service needs. Collaborative mitigation measures are
15 in place to address these concerns.”

1 **SUBJECT: Socio-economic impacts: personal, family and community life**

2

3 **REFERENCE: MMF/MH 1-001a; MMF/MH 1-001b;**

4

5 **PREAMBLE:** "Worker interaction with local residents" is listed under the "Personal,
6 Family, and Community Life" component/topic of the "Socio-economic Comparison of
7 Resource Options" table (CAC/MH 1-231a). The text on p.26 of 29 (CAC/MH 1-231a)
8 describes measures to address adverse effects of worker interaction (i.e. camps, and
9 committees established to address issues) yet concludes that "...some adverse effects
10 are expected." There is concern that these effects will be greatest for current Northern
11 and Aboriginal residents. It is presently not known whether construction schedules for
12 Keeyask and Conawapa will overlap, but in the case that they do, it is anticipated that
13 these effects will be of a greater magnitude. It is also understood that each project will
14 undergo a separate environmental review process; however, there is an additional
15 concern that these separate review processes will fail to consider the combined effects
16 of the separate PDP components.

17

18 **QUESTION:**

19 Please estimate the combined effects of the Keeyask and Conawapa projects on "personal,
20 family, and community life", particularly in terms of "worker interaction with local residents",
21 and indicate the communities in which these effects are estimated to be greatest, and during
22 which years of project construction.

23

24 **RESPONSE:**

25 The Cumulative Effects Assessment Summary for the Keeyask Generation Project
26 Environmental Impact Statement sets out eight mitigation actions regarding public safety and
27 worker interaction, including a series of strategies to keep workers at the camp, a multi-party
28 committee to provide a coordinated approach to address issues across all Manitoba Hydro
29 projects, and regular dialogue with the RCMP regarding policing matters. The cumulative
30 effects summary concludes:

31 There is a potential for adverse effects during the construction of the [Keeyask] project
32 due to potential workers interactions. Future projects will further increase the number

1 of non-local, temporary construction workers in Gillam, increasing the potential for
2 adverse effects. As many as 2,300 local and non-local workers will be required at the
3 peak of the proposed Conawapa construction.

4

5 The residual adverse effects of the Keeyask Project on public safety and worker interaction may
6 interact cumulatively with adverse effects of other projects and activities planned during the
7 Keeyask construction phase. A collaborative and cooperative mitigation program is proposed to
8 mitigate these potential effects.

1 **REFERENCE: MMF/MH I-039b**

2

3 **SUBJECT: Socio-economic impacts**

4

5 **PREAMBLE:** The information presented in the “Socio-economic Comparison of Resource
6 Options” table (CAC/MH 1-231a) is not complete, or detailed enough, to allow for an
7 understanding of the socio-economic effects of the resource options. Further, it
8 presents very general information for all of the components of the PDP, but the same
9 type and level of information is not provided in the NFAT submission, or to subsequent
10 Round 1 IRs, including MMF/MH 1-004a, MMF/MH 1-004c, MMF/MH 1-038a, MMF/MH
11 1-039a, MMF/MH 1-046a, for the alternatives and other options.

12 It is still not clear whether, or how, the PDP is superior to the alternatives in even the
13 most general socio-economic terms, and with respect to the Metis in particular.

14

15 **QUESTION:**

16 Please explain whether, and how, any of the three development plans that were eliminated
17 (see Chapter 9) were preferable, in socio-economic terms, to the development plans that were
18 carried forward in the analysis.

19

20 **RESPONSE:**

21 The three plans eliminated for the economic uncertainty analysis from the 15 plans reviewed in
22 the response to MMF/MH II-40a are Plans 12, 14 and 15.

23

24 At a macro level, Plan 12 is similar to other plans in Group A (1, 2, 4, 6, and 8). They differ only
25 in that Plan 12 does not include a U.S. Interconnection. The interconnection represents a small
26 portion of potential socio-economic effects of the plans. For example, the interconnections
27 represent only about 1-2% of the total employment opportunities. Unlike most of the jobs and
28 business opportunities created in the Group A plans, the limited opportunities associated with
29 the interconnections would occur in southern Manitoba. The elimination of the interconnection
30 would also avoid potential effects on agricultural practices and southern resource users.

1 At a macro level, Plan 14 is similar to the effects of Plans 11 and 13. Together, they constitute
2 the “Group C” plans identified in the response to MMF-MH II-40a. The differences between
3 those plans and other development plans are described in MMF-MH II-40a.

4

5 Plan 15 (Wind and C26) was also among the three plans deleted from further consideration in
6 Chapter 10. Again, its merits relative to the other plans is discussed in the response to MMF-
7 MH II-40a.

1 **REFERENCE: MMF/MH I-046a**

2

3 **SUBJECT: Socio-economic impacts**

4

5 **PREAMBLE:** The information presented in the “Socio-economic Comparison of Resource
6 Options” table (CAC/MH 1-231a) is not complete, or detailed enough, to allow for an
7 understanding of the socio-economic effects of the resource options. Further, it
8 presents very general information for all of the components of the PDP, but the same
9 type and level of information is not provided in the NFAT submission, or to subsequent
10 Round 1 IRs, including MMF/MH 1-004a, MMF/MH 1-004c, MMF/MH 1-038a, MMF/MH
11 1-039a, MMF/MH 1-046a, for the alternatives and other options.

12

13 It is still not clear whether, or how, the PDP is superior to the alternatives in even the
14 most general socio-economic terms, and with respect to the Metis in particular.

15

16 **QUESTION:**

17 Please explain whether, and how, the 8 development plans that were selected for financial
18 evaluation (see Chapter 11) are preferable, in socio-economic terms, to the 15 development
19 plans identified in Chapter 8.

20

21 **RESPONSE:**

22

23 The eight plans reviewed in the financial evaluation are Plans 1, 4, 5, 6, 7, 9, 11 and 13, as
24 numbered in the response to MMF/MH II-40a. Previously eliminated from the economic
25 uncertainty analysis were Plans 12, 14 and 15 (please see the response to MMF/MH II-40b).
26 Eliminated from the financial evaluation were Plans 2, 3, 9 and 11.

27

28 In terms of macro socio-economic effects, Plans 1, 4 and 6 (which are part of the financial
29 evaluation) are very similar to Plans 2, 8 and 12. All would include the effects of Keeyask and
30 Conawapa, three gas turbines, and the North-South Transmission Upgrade, and all except for

1 Plan 12 would be affected by a new U.S. Interconnection. The effects on these plans are
2 discussed in the response to MMF/MH II-40a.

3

4 Plans 5 and 7 are also similar to each other, as well as Plan 3 (which was eliminated from the
5 financial analysis). Each is comprised of Keeyask, gas turbines, and a new U.S. Interconnection.
6 They do vary in details: the timing and composition of the gas turbines is different between the
7 two plans, and the size of the U.S. Interconnection varies from 750 MW to 250 MW. However,
8 these details are not considered in the macro analysis. For more discussion about these plans,
9 please see the response to MMF/MH II-40a.

10

11 Plans 11 and 13 are similar to each other, as well as Plan 14 (which was eliminated from the
12 economic uncertainty analysis). Each is comprised of a hydro-electric project and gas turbines,
13 but no U.S. Interconnection. They differ in that Plan 11 would develop Keeyask and Plans 13
14 and 14 would develop Conawapa. The timing and composition of the gas turbines also differ.
15 Total employment opportunities vary only marginally, and all three plans would be expected to
16 experience other socio-economic effects in a similar manner when considered at a macro level.
17 The effects on these plans are discussed in the response to MMF/MH II-40a.

18

19 Plan 11 (all gas) differs substantially from the other plans that include hydroelectric generating
20 stations. The effects on this plan are also discussed in the response to MMF/MH II-40a.

1 **SUBJECT: Macro-environmental**

2

3 **REFERENCE: CAC/MH 1-231a; MMF/MH 1-048; MMF/MH 1-053a**

4

5 **PREAMBLE:** The proponent treats the analysis of macroenvironmental and socio-
6 economic factors using the same methodology; yet, the definitions are very different
7 and require the use of different methodologies. In particular, the Proponent continues
8 to give no consideration to the "significance" of the "changes to air, land, water, flora
9 and fauna" in the macroenvironmental analysis. In its response to MMF-053a, MH
10 provides its view that "the specific use of "significance", as required in the
11 environmental reviews, is not being applied in the NFAT review. Rather, as used in the
12 NFAT submission, "significant" is synonymous with words such as important, major,
13 noteworthy and substantial." This is not meaningful for the purposes of comparing the
14 alternatives with respect to the "changes to air, land, water, flora and fauna".

15

16 **QUESTION:**

17 Please provide the specific criteria for determining whether "changes to the air, land, water,
18 flora and fauna" are "important, major, noteworthy and substantial" in comparing the
19 development plans, specifying different criteria for the five different environmental aspects, as
20 appropriate.

21

22 **RESPONSE:**

23 As noted in the response to MMF/MH I-053a, the determination of "significance" is a
24 requirement of the *Canadian Environmental Assessment Act*. The NFAT Terms of Reference
25 explicitly exclude a duplication of matters being considered in the environmental reviews. As
26 such, the term "significant" in the macro environmental and socio-economic analysis, including
27 in the Multiple Accounts Benefit Cost Analysis, should not be confused with the methodology
28 and criteria established for environmental assessments under environmental legislation.
29 Rather, it is used in a manner similar to everyday lexicon, based on the user's professional
30 judgement.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: MMF/MH 1-007; MMF/MH 1-069**

4

5 **PREAMBLE:** Figure 3.3 illustrates a downward trend in the rate of real GDP growth since
6 1971. (This corrects a misstatement in MMF-07 submitted during Round 1). In its
7 response to MMF-007, Hydro provides the requested best-fit line in Figure 3.3 clearly
8 showing a decline in real GDP for Manitoba, Canada and the U.S. over the past 40 years.
9 In its response to MMF-069, Hydro provides Table 1 showing projections of Manitoba
10 Real GDP indicating that RGDP is expected to stabilize by 2018 at 1.9%, which is
11 equivalent to the RGDP of the best fit line in Figure 3.3 in 2011.

12

13 **QUESTION:**

14 Please provide the data used to create Figure 3.3 in tabular format.

15

16 **RESPONSE:**

17 Please see the following table which provides a comparison of historical real GDP (% change).

| | MB | USA | CDN |
|------|-----------|------------|------------|
| 1971 | 2.60% | 3.36% | 5.50% |
| 1972 | 5.96% | 5.31% | 5.45% |
| 1973 | 4.11% | 5.79% | 6.96% |
| 1974 | -0.16% | -0.55% | 3.69% |
| 1975 | -0.88% | -0.21% | 1.82% |
| 1976 | 6.56% | 5.36% | 5.20% |
| 1977 | 0.45% | 4.60% | 3.46% |
| 1978 | 5.18% | 5.58% | 3.95% |
| 1979 | 5.65% | 3.13% | 3.80% |
| 1980 | 0.81% | -0.28% | 2.16% |
| 1981 | 8.74% | 2.54% | 3.50% |
| 1982 | -2.63% | -1.94% | -3.02% |
| 1983 | 0.71% | 4.52% | 2.57% |
| 1984 | 8.25% | 7.19% | 5.57% |
| 1985 | 6.47% | 4.14% | 4.68% |
| 1986 | 0.22% | 3.46% | 2.20% |
| 1987 | 1.50% | 3.20% | 4.04% |
| 1988 | -0.53% | 4.11% | 4.74% |
| 1989 | 2.66% | 3.57% | 2.38% |
| 1990 | 2.47% | 1.88% | 0.13% |
| 1991 | -3.36% | -0.23% | -2.12% |
| 1992 | 1.04% | 3.39% | 0.85% |
| 1993 | 0.36% | 2.85% | 2.61% |
| 1994 | 3.90% | 4.07% | 4.55% |
| 1995 | 0.27% | 2.51% | 2.74% |
| 1996 | 3.07% | 3.74% | 1.68% |
| 1997 | 3.72% | 4.46% | 4.25% |
| 1998 | 4.25% | 4.36% | 4.14% |
| 1999 | 1.58% | 4.83% | 5.00% |
| 2000 | 4.26% | 4.14% | 5.12% |
| 2001 | 0.81% | 1.08% | 1.69% |
| 2002 | 1.56% | 1.81% | 2.80% |
| 2003 | 1.37% | 2.54% | 1.93% |
| 2004 | 2.16% | 3.47% | 3.14% |
| 2005 | 2.64% | 3.07% | 3.16% |
| 2006 | 3.40% | 2.66% | 2.62% |
| 2007 | 2.28% | 1.91% | 2.01% |
| 2008 | 4.01% | -0.34% | 1.18% |
| 2009 | -0.50% | -3.07% | -2.71% |
| 2010 | 2.30% | 2.39% | 3.37% |
| 2011 | 2.20% | 1.81% | 2.53% |
| 2012 | 2.20% | 2.21% | 1.71% |

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: MMF/MH 1-007; MMF/MH 1-069**

4

5 **PREAMBLE:** Figure 3.3 illustrates a downward trend in the rate of real GDP growth since
6 1971. (This corrects a misstatement in MMF-07 submitted during Round 1). In its
7 response to MMF-007, Hydro provides the requested best-fit line in Figure 3.3 clearly
8 showing a decline in real GDP for Manitoba, Canada and the U.S. over the past 40 years.
9 In its response to MMF-069, Hydro provides Table 1 showing projections of Manitoba
10 Real GDP indicating that RGDP is expected to stabilize by 2018 at 1.9%, which is
11 equivalent to the RGDP of the best fit line in Figure 3.3 in 2011.

12

13 **QUESTION:**

14 Please explain on what basis the projections for long-term RGDP, provided in Table 1 of the
15 response to MMF-069, are considered to be maintained at 1.9% to the end of the planning
16 period, rather than declining further consistent with the historic trend in RGDP, which has been
17 declining for Manitoba, Canada and the US since 1971. In the response, identify any key social,
18 economic or other factors that account for the sudden end to the long-term decline in RGDP in
19 Manitoba.

20

21 **RESPONSE:**

22 The basis of the projection for long-term RGDP is the values produced from a consensus
23 average of both publicly-available and subscription-based forecasters. Please see Manitoba
24 Hydro's response to MMF/MH II-42c for further details.

1 **SUBJECT: Economic Risk**

2

3 **REFERENCE: MMF/MH 1-007; MMF/MH 1-069**

4

5 **PREAMBLE:** In reviewing Table 1 provided in response to MMF-069, it is apparent that
6 three long-term projections for RGDP were provided: by Spatial Economics, the
7 Conference Board of Canada and Inforetrica. It appears, however, that the three
8 projections are not averaged and that lesser weight has been given to the Spatial
9 Economics projections, the only one of the three that suggests that the long-term trend
10 in declining RGDP will continue throughout the future planning period as it has
11 historically.

12

13 **QUESTION:**

14 Please explain why the Spatial Economics projections have been given less weight in the
15 determination of long-term Manitoba RGDP.

16


17 **RESPONSE:**

18 The forecast of Manitoba RGDP is derived from the average of the consensus survey using the
19 sources as listed in Table 1 in the response to MMF/MH I-069.

20

21 The following chart presents Manitoba Hydro's Manitoba RGDP forecast, compared to the
22 forecast of the consensus survey.

23 Figure 1 – Forecast of Manitoba RGDP (2012 Economic Outlook)



24

25 From 2012 – 2018, Manitoba Hydro’s annual forecast is equal to the annual forecast of the

26 consensus survey. The long-term forecast of Manitoba RGDP beyond year 2018, however, is set

27 to a value such that the average over the forecast period from 2019 – 2033 (red line in above

28 figure) is equal to the average over the forecast period of the consensus survey (blue line in

29 above figure). For example, the long-run average over the forecast period 2019-2033 as

30 projected by the three long term forecasters - Spatial Economics, Conference Board and

31 Informetrica – was 1.9%. This “smoothed” 1.9% value was set as Manitoba’s forecast of

32 Manitoba RGDP for 2019 and beyond.

1 **SUBJECT: Socio-economic impacts: employment**

2

3 **REFERENCE: MMF/MH 1-056**

4

5 **PREAMBLE:** Further to MMF-056 asking the Proponent to "Provide the definition of a
6 "Manitoban" for the purposes of assigning employment benefits, including the criteria
7 used to determine this definition", the Proponent responded that a "Manitoban refers
8 to residents of Manitoba". The definition does not distinguish Manitobans who move to
9 the Province to take up work versus those who are already resident in the Province and
10 obtain work.

11

12 **QUESTION:**

13 Please describe the criteria required by the Province of Manitoba to be considered a "resident"
14 of the Province.

15

16 **RESPONSE:**

17 According to the the Government of Manitoba, generally, you are a resident of the Province if
18 Manitoba is where you lived for the last 12 consecutive months. This would include workers
19 who move to the Province to take up work, provided these workers lived in Manitoba for the
20 past 12 months.

1 **SUBJECT: Socio-economic impacts: employment**

2

3 **REFERENCE: MMF/MH 1-056**

4

5 **PREAMBLE:** Further to MMF-056 asking the Proponent to "Provide the definition of a
6 "Manitoban" for the purposes of assigning employment benefits, including the criteria
7 used to determine this definition", the Proponent responded that a "Manitoban refers
8 to residents of Manitoba". The definition does not distinguish Manitobans who move to
9 the Province to take up work versus those who are already resident in the Province and
10 obtain work.

11

12 **QUESTION:**

13 Please indicate for the Wuskwatim Project (as a most recent example), how many person-years
14 of direct employment for the construction phase of the Project were obtained by Manitobans
15 and by non-Manitobans, and the total person-years of direct employment for that Project on an
16 annual (or preferably monthly) basis.

17

18 **RESPONSE:**

19 From start of construction to end of November 30, 2012, direct total person years of
20 employment for Wuskwatim were estimated at 2859. This is based on an employee working
21 2000 hours in a year. Of this total, 2001 person years and 858 person years represent
22 employment by Manitobans and non-Manitobans, respectively. Cumulative year totals for
23 person years of employment were provided in Annual Monitoring Overview reports available at
24 the following link: <http://wuskwatim.ca/reports.html#monitor>.

25

26 Note that the total person years may be understated as a full validation of the employee
27 database to end of December 31, 2012 is ongoing.

1 **SUBJECT: Macro-environmental**

2

3 **REFERENCE: MMF/MH I-060**

4

5 **PREAMBLE:** In MMF-60, MH was asked to "Explain the declining effect in Figure 13.8 of
6 the hydro development plans on reduction of GHG emissions in export markets over
7 time, making reference to relevant legislation in these markets and any targets for GHG
8 emissions reduction at the municipal, state, regional and federal levels or within certain
9 industries or corporations producing electricity within these markets."

10

11 In its response, MH indicates that "This figure assumes a constant GHG displacement
12 factor of 0.75 kg CO₂e/kWh was applied to the Manitoba Hydro exports (and imports)
13 associated with the selected development plans."

14

15 It is unclear why Manitoba Hydro would apply the same GHG displacement factor over
16 time given commitments to reduce greenhouse gases in the target markets.

17

18 **QUESTION:**

19 Please explain and justify why a constant GHG displacement factor was assumed for the
20 duration of the planning period (shown as 2010 to 2048 in Figure 13.8), when GHG emissions
21 will need to be reduced substantially over that period in order to achieve climate change
22 objectives.

23

24 **RESPONSE:**

25 Please refer to the response to PUB/MH II-376a.

1 **SUBJECT: Macro-environmental**

2

3 **REFERENCE: MMF/MH I-060**

4

5 **PREAMBLE:** In MMF-60, MH was asked to "Explain the declining effect in Figure 13.8 of
6 the hydro development plans on reduction of GHG emissions in export markets over
7 time, making reference to relevant legislation in these markets and any targets for GHG
8 emissions reduction at the municipal, state, regional and federal levels or within certain
9 industries or corporations producing electricity within these markets."

10

11 In its response, MH indicates that "This figure assumes a constant GHG displacement
12 factor of 0.75 kg CO₂e/kWh was applied to the Manitoba Hydro exports (and imports)
13 associated with the selected development plans."

14

15 It is unclear why Manitoba Hydro would apply the same GHG displacement factor over
16 time given commitments to reduce greenhouse gases in the target markets.

17

18 **QUESTION:**

19 Please explain how Manitoba Hydro accounts for the potential for exports to displace demand-
20 side management or other renewables, as opposed to fossil-fuel generation, in the export
21 markets.

22

23 **RESPONSE:**

24 Manitoba Hydro's exports primarily displace fossil fuel generation rather than other renewables
25 or demand side management programs. In a market like MISO, generation unit dispatch
26 decisions are made by the system operator based on marginal energy production cost.
27 Renewable generation like wind, solar and hydro are very rarely on the margin because they
28 have very low dispatch costs relative to the fuel costs associated with coal and natural gas
29 generation. Similarly demand-side management programs affect load and have no marginal
30 energy cost and therefore are not affected by resource dispatch decisions.

1 Further, the construction of wind generation in the MISO market has been primarily driven by
2 state renewable portfolio standards and the federal US production tax credits (See Chapter 3,
3 Section 3.3.4 State and Provincial Policy Perspectives, page 21 of the Application). Wind
4 generation in MISO has grown to 11,857 MW registered wind capacity at June 2012 (Appendix
5 5.1 – MISO Corporate Information Fact Sheet) with these incentives, and while Manitoba Hydro
6 was exporting into the MISO market. Similarly, demand side management is often driven by
7 legislative requirements. For example, Minnesota passed an energy efficiency resource
8 standard in 2007 requiring electric and gas utilities to spend and invest for energy conservation
9 improvements a specified percentage of its gross operating revenues (Minnesota Statute
10 216B.241 Energy Conservation Improvement).