

2015 COST OF SERVICE METHODOLOGY REVIEW

Manitoba Hydro Undertaking Transcript Page 254

Why the February 2012 loads and time shown in GAC/MH I-57 (9 am, 3,883,517 kW) do not match that provided in GAC/MH I-8 (6 pm, 3,589,907 kW)?

Response:

The response to GAC/MH I-57 includes a table of the 12 monthly Common Bus CP (kW) that occurred during peak hours (06:00 to 22:00) from the 2011/2012 Load Research results. This table shows the single highest Common Bus peak for February occurred at 9:00 and was 3,883,517 kW.

The response to GAC/MH I-8 includes a table of the Top 50 Generation Peaks that occurred during winter peak hours from 06:00 to 22:00 in December, January and February. This list includes a generation peak that occurred on 2012-02-09 at 18:00. The Common Bus load at that time was 3,589,907 kW.