

1
2
3
4
5

MANITOBA HYDRO
APRIL 1, 2004 AND APRIL 1, 2005 RATE INCREASE APPLICATION
ENERGY SUPPLY

6
7

7.1 OVERVIEW OF ENERGY SUPPLY

8
9
10
11
12
13
14
15
16
17
18
19
20

Manitoba Hydro's hydraulic generating stations utilize water flowing into Manitoba from Alberta, Saskatchewan, northwestern Ontario, Minnesota, North Dakota, South Dakota and Montana. Water flows into the Winnipeg River do have particular significance as that water flows through not only all of the plants on that river, but ultimately the big Nelson River plants. The broad geographical area of Manitoba's watersheds provides a degree of diversity in precipitation to reduce the frequency and impact of droughts on the Manitoba Hydro system. Even with this diversity, there is a one-in-ten chance of drought in any one year. To ensure that these periodic droughts won't result in energy shortages, the generation system is planned to meet committed firm loads under a repeat of the lowest system water supplies (from records dating back to 1912) using hydro plants, thermal generation and imports. In addition actual system operations follow specific criteria to assure that the Manitoba load will be met without undue risk.

21
22

7.2 POWER RESOURCE PLANNING CRITERIA

23
24
25

In planning a reliable supply of electric power for Manitobans, Manitoba Hydro has established the following criteria:

26
27

Capacity Criterion

28
29
30
31

The capacity criterion for the Manitoba Hydro system requires that planned generation capacity (MW) must not be less than forecast firm annual peak demand plus a reserve requirement of 12% of forecast firm loads.

32
33
34
35
36

Reserves are intended to protect against capacity shortfalls resulting from three types of contingencies: breakdown of generating equipment, increases in peak load due to extreme weather, and deviation from the peak load forecast due to higher than projected provincial economic growth in the short term.

1 Reserve margins of 12% are adequate in Manitoba Hydro's predominantly hydraulic
2 system because of the relatively low outage rates of hydro generating units combined
3 with relatively small size of units. For comparison, reserve margins on thermal systems
4 are typically in the 15% to 30 % range.
5

6 Dependable Energy Criterion 7

8 Manitoba Hydro has adopted an energy supply planning criterion which recognizes the
9 limitation of hydraulic generation during drought conditions. The energy criterion
10 requires that the Manitoba System shall be capable of a dependable supply of energy to
11 meet forecast firm load demand. Specifically, there must be sufficient firm energy
12 sources to meet firm energy demand in the event of a repeat of the lowest historic river
13 flow conditions.
14

15 The dependable supply includes energy from hydro electric and thermal stations, firm
16 energy imports from out-of-province, as well as contracted non-firm imports from the
17 reserves of neighbouring utilities. Contracted non-firm imports for meeting firm load
18 should not exceed 10% of firm energy requirement. Non-firm imports are not included in
19 the 10% limit if they consist of an energy guarantee to Manitoba Hydro during low flow
20 years and they are associated with a firm export sale of an equal or greater magnitude.
21

22 **7.3 WATER CONDITIONS** 23

24 Hydraulic generation over the last six years was at or above average until the summer of
25 2002. Low rainfall after July was followed by a winter with little snow cover. Although
26 the spring and summer of 2003 had sufficient rainfall to grow crops in most parts of
27 southern Manitoba, there were insufficient amounts to result in significant runoff. Overall
28 water supplies across the Churchill / Nelson River basin are at lows that on average
29 would only be experienced once in every 50 years. Going into the winter of 2003/04
30 reservoirs were at or near historic lows. Manitoba Hydro has been importing energy
31 consistently since the spring of 2003 and expects to incur unprecedented power purchase
32 costs as a result.
33


34 The historical water supply as a percentage of average is shown in Figure 7.3.3. Overall
35 hydraulic supplies for 2003/04 are forecast to be similar to the 1988/1989 period, the
36 second driest on record since 1912. In addition, energy in storage in reservoirs affecting
Manitoba Hydro is as shown in Figure 7.3.4. Hydraulic reserves remain well below

1 average and remain below the previous minimum set since regulation of Lake Winnipeg
2 and Churchill River Diversion began in 1976. Releases from Manitoba Hydro reservoirs
3 are being minimized to protect storage reserves for next year.
4

5 Hydroelectric generation for 2003/04 is forecast to be 20,791 GWh down 7,809 GWh
6 from the long term mean as shown in Figure 7.3.5. The reduced hydro generation will be
7 replaced with increased thermal generation and power purchases at additional cost. The
8 forecast of net interchange revenue (net cost) for 2003/04 is (\$158) million, down
9 \$398 million from the 2002/03 actual results. If the drought conditions persist throughout
10 2004 then a similar result in net interchange revenue can be expected in 2004/05. Net
11 interchange revenues above are defined as export revenues minus generation costs which
12 include import, thermal and water rental costs.
13

14 It is estimated that a repeat of the worst drought on record would cost the Corporation at
15 least \$1.1 billion for the loss of energy volumes and potentially much more if combined
16 with market price increases for imports and thermal energy. Financing these losses over
17 a period of time would add to the overall cost. The current below-normal water supply
18 has weakened Manitoba Hydro's financial structure and slowed its progress toward
19 achievement of financial targets.
20

Precipitation Percent of Normal Winter 2002/03



Source: Manitoba Water Resources Branch
March 26, 2003

Figure 7.3.1




Figure 7.3.2

Historic Water Supply




Figure 7.3.3

Nelson-Churchill Drainage Basin Manitoba Energy in Reservoir Storage




Figure 7.3.4

Total Hydraulic Generation




Figure 7.3.5