

Table of Contents

7	Screening of Manitoba Resource Options	1
7.0	Chapter Overview	1
7.1	Resource Technology Screening	1
7.1.1	Resource Technology Characteristics	1
7.1.1.1	Technical Characteristics	4
7.1.1.2	Environmental Characteristics.....	5
7.1.1.3	Social and Policy Characteristics.....	8
7.1.1.4	Economic Characteristics.....	9
7.1.2	Screening Process	11
7.1.2.1	Selected Resource Technologies	12
7.1.2.2	Resource Technologies Not Selected	17
7.2	Resource Options Screening	20
7.2.1	Additional DSM Screening	20
7.2.2	Hydro Resource Options Screening	23
7.2.3	Natural Gas-Fired Resource Option Screening	28
7.2.4	Wind Resource Option Screening	31
7.2.5	Imports.....	34
7.3	Summary of Selected Resource Options	38

1 **7 Screening of Manitoba Resource Options**

2

3 **7.0 Chapter Overview**

4 Previously, *Chapter 4 – The Need for New Resources* described how Manitoba Hydro
5 establishes the need for new supply resources in order to meet the electricity demands of
6 Manitoba Hydro’s domestic and firm export customers. As part of the resource planning
7 process, Manitoba Hydro monitors a wide range of resource supply options and maintains an
8 inventory of options which are potentially available to meet future Manitoba needs. *Chapter 7*
9 – *Screening of Manitoba Resource Options* describes the process of screening resource
10 technologies and options and establishes the portfolio of resource options that is used by
11 Manitoba Hydro in determining development plans.

12

13 This chapter considers those technologies that are available for utility-scale generation.
14 Detailed information on resource technologies is available in *Appendix 7.1 Emerging Energy*
15 *Technology Review* and *Appendix 7.2 – Range of Resource Options*.

16

17 **7.1 Resource Technology Screening**

18 Screening of different resource technologies begins with a high-level review that identifies the
19 resource technologies most suitable for further evaluation. Sixteen resource technologies
20 potentially suitable for utility-scale generation are considered and discussed in this section.

21

22 **7.1.1 Resource Technology Characteristics**

23 This section provides a general description of 15 characteristics associated with each resource
24 technology.

25

26 These characteristics form the basis for the criteria used in screening the full range of resource
27 technologies to a select number for further consideration. A comparative summary of

- 1 descriptive characteristics for the resource technologies is provided in Table 7.1: Screening
2 Characteristics of Resource Technologies. The characteristics are grouped into the following
3 conventional categories:
- 4 • technical
 - 5 • environmental
 - 6 • social and policy
 - 7 • economic.

Table 7.1 SCREENING CHARACTERISTICS OF RESOURCE TECHNOLOGIES

SCREENING CHARACTERISTICS OF RESOURCE TECHNOLOGIES																	
		Screened Out			Some Concern				Minimal Concern or Positive								
Utility Scale Resource Technologies		Characteristics														Screening Summary	
		Technical					Environmental					Social & Policy			Economic		
		Maturity of Technology	Technical Challenges in Manitoba	Ease of Integration into System	Intermittency	Seasonality	Water Quality Impacts	Hazardous Air Pollutants	Greenhouse Gas Emissions	Land Use Impacts	Wildlife Species of Interest	Proximity to Load Center	Regulatory Constraints	Social Acceptability	Manitoba Delivered Fuel Costs		Forecast USA Unit Costs (\$/MW.h)
DSM	Additional DSM	increasingly customer dependant	uncertainty in market potential	unknown	unknown	unknown	program specific	program specific	none	none	none	reduction at load centre	none	not polled	no fuel cost	not included in AEO 2013	✓
Hydro	Hydro with Storage	>100 years of experience	long construction schedule	no issues	none	reservoir storage management	shoreline erosion	none	minimal reservoir GHG	flooded area	sturgeon caribou	northern generation southern load	lengthy approval process	strongly support	stable water rentals	use AEO 2013 Hydro plant type	✓
	Run-of-River Hydro	>100 years of experience	long construction schedule	no issues	lack of reservoir	flow dependent	shoreline erosion	none	virtually no GHG	limited flooding	sturgeon caribou	northern generation southern load	lengthy approval process	strongly support	stable water rentals	use AEO 2013 Hydro plant type	✓
Wind	On-Shore Wind	newly mature	blade icing & cold weather operation	forecast challenges & costs	highly variable wind speeds	moderate seasonality	none	none	virtually no GHG	set backs & land use limitations	birds & bats	southern generation potential	land use setbacks	strongly support	no fuel cost	use AEO 2013 Wind plant type	✓
	In-Lake Wind	lack of experience	no experience with lake ice	forecast challenges & costs	highly variable wind speeds	moderate seasonality	construction phase impacts	none	virtually no GHG	resource user impacts	birds & fish	large lakes preferred	migratory birds & fisheries	not polled	no fuel cost	use AEO 2013 Wind - Offshore plant type	✗ - Very High Unit Costs
Solar	Photovoltaic (Utility Plant Scale)	potential efficiency improvements	unproven in Manitoba	forecast challenges & costs	cloud cover creates rapid power drop off	winter energy is 1/2 of summer	none	none	virtually no GHG	large footprint	habitat loss	best resource in SW corner of Manitoba	none	strongly support	no fuel cost	use AEO 2013 Solar PV plant type	✗ - High Unit Cost & Intermittency
	Solar Thermal	potential efficiency improvements	unproven in Manitoba	forecast challenges & costs	weather dependant	winter energy is 1/2 of summer	potential thermal oil leaks	none	virtually no GHG	large footprint	habitat loss	best resource in SW corner of Manitoba	none	strongly support	no fuel cost	use AEO 2013 Solar Thermal plant type	✗ - Very High Unit Costs
Geo.	Enhanced Geothermal System	lack of experience in Manitoba	low grade resource requiring deep drilling	no issues	none	winter peaking	potential fracking impacts	none	virtually no GHG	small surface footprint	not significant	best resource in SW corner of Manitoba	groundwater quality concerns	not polled	no fuel cost	use AEO 2013 Geothermal plant type	✗ - Deep Low Grade Resource
Natural Gas	Simple Cycle Gas Turbine	>70 years of experience	not significant	no issues	none	lower summer capacity	none	easily mitigated with NOx controls	hydrocarbon combustion	small footprint	not significant	near southern pipelines	air emissions	somewhat support	2001 to 2009 price volatility	use AEO 2013 Advanced CT plant type	✓
	Combined Cycle Gas Turbine	>60 years of experience	not significant	no issues	none	lower summer capacity	boiler treatment chemicals	easily mitigated with NOx controls	efficient hydrocarbon combustion	small footprint	not significant	near southern pipelines	air emissions	somewhat support	2001 to 2009 price volatility	use AEO 2013 Advanced CC plant type	✓
Coal	Conventional Pulverized Coal Generation	>100 years of experience	emissions & waste management	cold start ramp times	none	not significant	mercury arsenic selenium	mercury & air toxics	restricted by legislation	fuel storage & ash disposal	deleterious substances to fish or fish habitat	likely located in southern Manitoba	restricted operations	strongly oppose	transportation costs	use AEO 2013 Conventional Coal plant type	✗ - Regulatory Constraints
	Integrated Gasification Combined Cycle	only 2 plants in North America	complex chemical systems	cold start ramp times	none	lower summer capacity	mercury arsenic selenium	easily mitigated with NOx controls	syngas combustion	fuel storage & waste disposal	deleterious substances to fish or fish habitat	likely located in southern Manitoba	restricted operations	not polled	transportation costs	use AEO 2013 Advanced Coal with CCS	✗ - Regulatory Constraints
Nu.	Nuclear Power Plant	>60 years of experience	fuel & waste management	huge individual units	none	not significant	radioactive wastes	none	virtually no GHG	1 kilometer exclusion zone	not significant	southern generation potential	complex & lengthy approval process	strongly oppose	limited supply market	use AEO 2013 Advanced Nuclear plant type	✗ - Difficult Integration into System
Biomass	Agricultural Crop Residue	mature Rankine technology	long-term biomass fuel storage	cold start ramp times	none	limited by annual crop harvest	combustion ash & boiler chemicals	NOx & air toxics	fuel collection & transport	fuel storage & ash disposal	deleterious substances to fish or fish habitat	southern generation potential	air emissions	not polled	collection & transportation costs	use AEO 2013 Biomass plant type	✗ - High Collection & Transportation Costs
	Wood Based Fuel	mature Rankine technology	long-term biomass fuel storage	cold start ramp times	none	limited by annual forest harvest	combustion ash & boiler chemicals	NOx & air toxics	fuel collection & transport	fuel storage & ash disposal	deleterious substances to fish or fish habitat	located adjacent to boreal forest	air emissions & allowable cut limits	not polled	collection & transportation costs	use AEO 2013 Biomass plant type	✗ - High Collection & Transportation Costs
Imp.	Imports	large well established market	tie line limits	no issues	not significant	not significant	regional impacts outside of Manitoba	regional impacts outside of Manitoba	regional impacts outside of Manitoba	new transmission right-of-ways	not significant	non-Manitoba generation	transmission right-of-way approvals	not polled	no fuel cost	projected market prices	✓

1 **7.1.1.1 Technical Characteristics**

2 **Maturity of Technology**

3 For this analysis, maturity of technology is represented as the extent of industry experience
4 with the implementation and operation of a particular technology. The higher the level of
5 industry experience the lower the level of risk and concern with implementing the technology.

7 **Technical Challenges in Manitoba**

8 For this analysis, technical challenges are defined in the context of project development in
9 Manitoba. Technical challenges include the availability of the resource, physical environment
10 conditions including Manitoba's northern climate, level of technical experience in Manitoba,
11 length of implementation time and waste stream management.

13 **Ease of Integration into System**

14 This characteristic measures the complexity of integrating a specific resource technology into
15 Manitoba Hydro's existing system. The factors considered include intermittency, size and
16 dispatchability. Most available technologies pose no significant integration issues.

17
18 For example, the intermittency of wind only becomes an issue when the amount of wind
19 variability exceeds the amount of load variability that occurs moment by moment. When wind
20 variability significantly exceeds that amount, additional reserves are required, increasing the
21 cost of integrating those additional wind resources.

22
23 Technologies that employ large individual units that are designed for base load operation over
24 long periods of time pose an economic challenge. Such units are difficult to integrate into the
25 current hydraulic system since they lack the dispatchability needed to complement the
26 variability in water flows and loads. Integration of large units is possible as long as additional
27 interconnection capability is provided to manage the increased amounts of surplus energy
28 generated. In addition, a large unit may require Manitoba Hydro to increase the amount of

1 contingency reserves available to it. Adding six 100 megawatt (MW) hydro units would require
2 one-sixth the reserves as one 600 MW unit.

3

4 **Intermittency**

5 An intermittent resource technology is one that is not continuously available and cannot be
6 dispatched to meet the demand of a power system.

7

8 **Seasonality**

9 “Seasonality” refers to those factors that affect the production capability on a season-by-
10 season basis. Seasonality may impact production efficiencies as well as have an effect on a
11 technology’s fuel availability.

12

13 **7.1.1.2 Environmental Characteristics**

14 **Water Quality Impacts**

15 This characteristic captures a range of potential environmental effects impacting either surface
16 or groundwater. Adverse surface water impacts may include increased turbidity due to erosion,
17 thermal plumes or the discharge of combustion by-products such as mercury, arsenic or
18 selenium. Adverse impacts to groundwater are typically associated with uncontrolled spills or
19 leaks of process chemicals or by-products.

20

21 **Hazardous Air Pollutants**

22 Hazardous air pollutants are the by-products of combustion. Contaminants of concern for an
23 individual resource technology may include nitrogen oxides, sulfur oxides, carbon monoxide,
24 particulate matter (including respirable particles), mercury, arsenic and lead.

25

26 **Greenhouse Gas Emissions**

27 This characteristic represents the greenhouse gases (GHG) emissions associated with the life
28 cycle of a particular electric generation technology from construction, operation and

1 decommissioning. Renewable resource options produce minimal GHG emissions, typically
2 during construction phase, while all forms of conventional thermal generation, with the
3 exception of nuclear, produce GHGs.

4

5 **Error! Reference source not found.**Figure 7.1 provides a comparison of the life-cycle GHG
6 emissions for several generation technologies and uses the Keeyask Generating Station (G.S.)
7 and Conawapa G.S. as examples for the hydro technology. The source document for this figure
8 is appended as ***Appendix 7.3 – Life Cycle Greenhouse Gas Assessment Overview.***

9


10 One of the key results of a life-cycle GHG assessment is to show a levelized GHG comparison
11 including all life-cycle components between different technologies. The life-cycle assessment
12 encompasses cradle-to-grave calculations of activities for a project inclusive of:

- 13 • construction components – raw material extraction, production and transportation
- 14 • construction activities – primarily vehicle fuel
- 15 • site-specific land-use changes including reservoir emissions
- 16 • operation and maintenance activities
- 17 • decommissioning GHG emission implications.

Needs For and Alternatives To Chapter 7 – Screening of Manitoba Resource Options

1
2

Figure 7.1 **COMPARISON OF LIFE CYCLE GHG EMISSIONS FOR ELECTRICITY**
GENERATION



3
4
5
6
7
8
9
10
11
12
13
14
15

The life-cycle GHG emission intensity for thermal generation options is dominated by the use of direct fuel (coal and natural gas), while the life-cycle GHG footprint for renewable options is dominated by construction and land-use change GHG emissions. As shown in **Error! Reference source not found.** Figure 7.1, the GHG emission intensity from the 100-year life of the Keeyask G.S. is 2.5 CO_{2e} (carbon dioxide equivalent) tonnes/GWh (gigawatt-hour); while a conventional pulverized coal generating station has a GHG emission intensity approaching 1,000 CO_{2e} tonnes/GWh and a Combined Cycle Gas Turbine (CCGT) generating station has a GHG emission intensity of 509 CO_{2e} tonnes/GWh. This means that a conventional pulverized coal generating station operating for less than 100 days would have the equivalent GHG emissions from the entire 100-year life of the Keeyask G.S. Similarly, a highly efficient CCGT generating station would emit an equivalent amount of GHG emissions in less than one year compared to the 100-year values from the Keeyask G.S.

1 **Land-Use Impacts**

2 Land-use impacts represent the physical footprint of a resource option as well as other
3 associated land-use limitations such as flooded areas, buffer or set-back limits, adjacent land
4 use restrictions and lands impacted by disposal of waste such as ash from coal plants. A small
5 physical footprint having no post-decommissioning land-use restrictions would have the least
6 land-use impacts. For example, a small, natural gas-fired combustion turbine with a small
7 physical footprint will have no perpetual land use restrictions following its decommissioning.

8

9 **Wildlife Species of Interest**

10 This characteristic represents specific at-risk species—or other regionally important wildlife
11 species noted in either Canada's *Species at Risk Act* or Manitoba's *The Endangered Species*
12 *Act*—that could potentially be affected by the development of a resource technology at a
13 specific location. Broader groupings of species that may be adversely impacted by significant
14 habitat loss or alteration are also considered.

15

16 **7.1.1.3 Social and Policy Characteristics**

17 **Proximity to Load Centre**

18 This characteristic is a proxy for a combination of different issues such as associated right-of-
19 way issues, construction challenges encountered in isolated areas as well as post-construction
20 line losses. Distances to potential new facilities are estimated from the Dorsey Converter
21 Station and are grouped into five categories: 0 to 100 kilometers (km); 100 to 250 km; 250 to
22 500 km; 500 to 900 km; and greater than 900 km. Shorter distances are of less concern.

23

24 **Regulatory Constraints**

25 Regulatory constraints can severely restrict or prohibit the development of a technology based
26 on federal or provincial governments' policy perspectives or enacted laws and regulations. In
27 some cases, the regulatory approval process itself can become an impediment to development.
28 Policy areas such as land use, environmental emissions and impacts on wildlife may become a

1 regulatory constraint requiring mitigation or compensation for any individual resource
2 technology within the planning horizon.

3

4 **Social Acceptability**

5 Two public opinion polls conducted by Ipsos and the Innovative Research Group in April 2011
6 were used to gauge Canadian public opinion regarding six methods of producing electricity
7 (solar, wind, hydro-electric, natural gas, nuclear and coal). Polling results plus inferences drawn
8 from the data are used to populate this characteristic. The degree of respondent support
9 corresponds to the level of acceptance of individual resource technologies.

10

11 **7.1.1.4 Economic Characteristics**

12 **Manitoba Delivered Fuel Costs**

13 Delivered fuel costs refers to the current and future cost of fuel and associated transportation
14 for each technology. This characteristic includes the effect of the recent fuel-price volatility
15 experienced by natural gas as well as rising transportation costs for fuel that have been
16 impacted by petroleum prices. Natural gas and coal fuels require additional management of the
17 fuel delivery system. Transportation services—either by rail for coal or pipeline service for
18 natural gas—need to be addressed in a manner that both maximizes flexibility but also
19 guarantees service.

20

21 **Forecast U.S. Unit Cost**

22 With the exception of demand side management (DSM) and imports, unit cost is represented
23 by levelized cost. The unit cost of DSM varies by program; information on the cost of additional
24 DSM is not available at this time. The unit cost of imports varies by market and by product and
25 is based on Manitoba Hydro’s consensus electricity export price forecast.

26

27 Levelized cost is a standard measure of the cost of constructing and operating a generating
28 resource over its life. While it is a useful measure for screening of technologies, it should be

Needs For and Alternatives To Chapter 7 – Screening of Manitoba Resource Options


1 noted that levelized cost does not indicate the value of the generation but is a relative measure
2 of the cost associated with a unit of energy. For the purpose of high-level screening, levelized
3 costs for new generation obtained from the U.S. Energy Information Administration (EIA) 2013
4 Annual Energy Outlook Early Release (AEO) were sorted into three categories as follows:

- 5 • less than \$100/megawatt-hour (MWh),
- 6 • \$100 - \$130/MWh, and
- 7 • greater than \$130/MWh.

8

9

Figure 7.2 TYPICAL LEVELIZED COST OF NEW GENERATION BY RESOURCE




10

11 Figure 7.2 above shows the levelized cost ranges for resource technologies as provided in the
12 EIA Annual Energy Outlook 2013. Additional information on resource technologies that have
13 the potential to be developed in Manitoba is provided in **Appendix 7.2 Range of Resource**
14 **Options** and further information on emerging technologies is provided in **Appendix 7.1**
15 **Emerging Energy Technology Review**.

**Needs For and Alternatives To
Chapter 7 – Screening of Manitoba Resource
Options**

1 Figure 7.3 shows the levelized cost ranges based on potential development of resource
2 technologies in Manitoba.

3 **Figure 7.3** LEVELIZED COST OF RESOURCE TECHNOLOGIES DEVELOPED IN MANITOBA



4
5 Note: Values reflect losses to bring energy to market.

6
7 **7.1.2 Screening Process**

8 The high-level screening of technologies uses a general characterization to determine whether
9 a technology will proceed to the next stage of evaluation. As shown in Table 7.1, there are
10 three possible outcomes from screening: screened out (red), some concern (yellow), minimal
11 concern or positive (green). If a characteristic for a particular technology receives a “screened
12 out” outcome, that technology does not advance to the next stage and is depicted by an “X” in
13 the Screening Summary column of Table 7.1. A technology will otherwise advance to the next
14 stage of evaluation.

1 **7.1.2.1 Selected Resource Technologies**

2 The screening process resulted in the following resource technologies advancing to the next
3 stage of evaluation:

- 4 • additional DSM
- 5 • hydro – with Storage and Run-of-River
- 6 • wind – On-Shore
- 7 • natural Gas-Fired – Simple Cycle and Combined Cycle Gas Turbines
- 8 • imports.

9

10 The following is a summary of the key characteristics of the selected resource technologies.

11

12 **Additional Demand Side Management**

13 Manitoba Hydro’s DSM initiative, Power Smart, consists of energy conservation and load
14 management activities designed to capture energy efficiency and economic opportunities in an
15 effort to meet the energy needs of Manitoba in a more sustainable manner while assisting
16 customers in using energy more efficiently and reducing their energy bills. DSM encompasses a
17 range of market-based conservation programs and activities.

18

19 As indicated in *Chapter 4 –The Need for New Resources*, the 2012 Load Forecast reflects the
20 expected load reductions as a result of past DSM programs. By the end of 2012/13, Power
21 Smart is estimated to have achieved an annual load reduction of 1,990 GWh and 586 MW (at
22 generation)¹. Manitoba’s net load is determined by subtracting the DSM energy savings from
23 the corporation’s electric load forecast.

24

25 Compared to other generation technologies in Table 7.1, DSM results in no flooding, no air
26 emissions and has a positive global environmental impact. In the latter regard, energy

¹ Interim estimate as of March 31, 2013.

Needs For and Alternatives To Chapter 7 – Screening of Manitoba Resource Options

1 conserved in Manitoba as a result of DSM efforts can be sold to export market customers, thus
2 displacing the use of fossil-fuel based generation in those regions. DSM may also have a net
3 positive impact on the environment by deferring the need for new electricity infrastructure in
4 Manitoba. However, this deferral may increase overall GHG if the deferred generation is hydro.

5
6 One of the main considerations with DSM is that, without regulation or legislation, achieving
7 energy reduction targets is strongly dependent upon market acceptance and voluntary action.
8 Also, in addition to market availability and adoption forecasts, the savings potential is
9 estimated based on a variety of assumptions that include natural technological development,
10 anticipated customer energy usage/savings and market cost projections. As a result, expected
11 energy savings from DSM do not have the same future certainty of supply as would the
12 development of a physical resource.

13
14 In the screening process, additional DSM did not receive a “screened out” outcome for any of
15 the 15 characteristics as shown in Table 7.1.

16

17 **Hydro – with Storage and Run-of-River**

18 From a technical perspective, hydro-electric generation is a mature, dependable technology
19 that easily integrates into Manitoba Hydro’s existing system. Approximately 4,700 MW of
20 developable hydro-electric potential remains within the province including the proposed
21 Keeyask and Conawapa projects.

22

23 From an environmental perspective, hydro-electric generation is a renewable resource that has
24 virtually no hazardous air pollutants or GHG emissions. Specific hydro developments do have
25 the potential to impact aquatic and terrestrial species. Hydro with storage can typically result in
26 a significant amount of flooding, while run-of-river hydro results in comparatively less flooding.
27 From a social and policy perspective, hydro-electric generation is a long lead-time resource that
28 has a lengthy approval process. Major hydro-electric resources are located in northern

1 Manitoba which is distant from the load centre. According to Canadian public opinion, hydro-
2 electric generation is generally viewed favourably.

3

4 From an economic perspective, hydro-electric generation is a long-lived resource with high
5 upfront investment but very low and stable operating costs over the long-term, resulting in a
6 levelized cost that falls within the range of other technologies selected for the next stage of
7 evaluation.

8

9 In the screening process, hydro with storage and run-of-river hydro did not receive a “screened
10 out” outcome for any of the 15 characteristics as shown in Table 7.1.

11

12 **Wind – On-Shore**

13 From a technical perspective, traditional on-shore wind is an established technology and a
14 good-quality wind resource exists within Manitoba. Wind is an intermittent resource that is
15 highly variable, is challenging to accurately forecast and can result in system integration issues.
16 The integration issues become more significant with higher proportions of wind in a system,
17 resulting in the requirement for additional dispatchable capacity resources.

18

19 From an environmental perspective, wind generation is a renewable resource that has virtually
20 no hazardous air pollution and no GHG emissions. However, there are potential negative
21 impacts on various avian species.

22

23 From a social and policy perspective, wind generation is a short lead-time resource that has
24 typically experienced short regulatory approval processes. According to Canadian public
25 opinion, wind is generally viewed favourably.

26

27 From an economic perspective, wind generation has significant upfront investment costs but
28 low operating costs over its approximate 20-year operating life. The unit cost of wind

1 generation falls within the range of other technologies selected for the next stage of evaluation.
2 The unit cost for wind generation does not include costs required to compensate for the
3 intermittency.

4
5 In the screening process, On-shore wind did not receive a “screened out” outcome for any of
6 the 15 characteristics as shown in Table 7.1.

7
8 **Natural Gas-Fired – Simple Cycle and Combined Cycle Gas Turbines**

9 From a technical perspective, natural gas-fired generation (simple cycle and combined cycle gas
10 turbines) uses modular, low capital cost technologies that are mature and well established.
11 Natural gas-fired generation is a short lead-time resource that is relatively easy to install and
12 integrate into the existing Manitoba Hydro system, provided that natural gas supply is readily
13 available.

14
15 From an environmental perspective, simple cycle gas turbine (SCGT) units emit minor amounts
16 of hazardous air emissions and produce approximately half as much carbon dioxide (CO₂) as
17 coal-based generation. The dual-stage combined cycle gas turbine (CCGT) units require a higher
18 capital investment compared to simple cycle gas turbines but are larger and more efficient,
19 resulting in a lower unit cost of energy. CCGT emit no meaningful amount of hazardous air
20 emissions and produce approximately one-third of the CO₂ of coal-based generation.

21
22 From a social and policy perspective, natural gas-fired generation is a shorter lead-time
23 resource that has typically experienced modest regulatory approval processes. According to
24 Canadian public opinion, natural gas-fired generation is generally viewed favourably. There is
25 ongoing concern with respect to GHG emissions, affecting the social acceptance and potential
26 cost of this technology.

1 From an economic perspective, the majority of the cost of natural gas-fired generation is a
2 result of the cost of fuel, which in recent years has been highly volatile as discussed in **Chapter**
3 **3 – Trends and Factors Influencing North American Electricity Supply**. Recently, as a result of
4 the adoption of innovative technological advancements in natural gas exploration and
5 extraction, the current and forecast price of natural gas is very low, resulting in a highly
6 competitive operating cost for natural gas-fired generation. However, there is general
7 expectation that the price of natural gas will increase.

8

9 In the screening process, SCGT and CCGT did not receive a “screened out” outcome for any of
10 the 15 characteristics as shown in Table 7.1.

11

12 **Imports**

13 Given Manitoba’s predominantly hydro system, resource diversity can be achieved by building
14 resources in Manitoba or through the purchase of imports from a non-hydro based region or a
15 combination of both. For planning purposes, under low flow or dependable flow conditions,
16 imports in the 2020 timeframe represent in the order of 10% of Manitoba Hydro’s total supply.
17 The primary source of imports to Manitoba is the Midcontinent Independent System Operator,
18 Inc.(MISO) market.

19

20 From a technical perspective, imports, utilizing existing or new transmission lines, are a flexible
21 resource option that can be called upon whenever required and on short notice. Imports
22 provide Manitoba Hydro with supply diversity by drawing from the MISO market, consisting
23 primarily of coal-fired, natural gas-fired, nuclear and wind generation.

24

25 From an environmental, social and policy perspective, generation from the MISO market—on
26 average across all generation types—results in significant amounts of CO₂ and other hazardous
27 air emissions on a per-unit (MWh) basis. Imports are also dependent on transmission

1 interconnections; new interconnections require both a willing counterparty as well as approvals
2 from U.S. and Canadian regulatory bodies.

3
4 From an economic perspective, the cost of market-based energy can vary by time of day and by
5 season. Manitoba Hydro is not committed to purchase any quantity of imports at any specific
6 time of day or year, and therefore has the flexibility to import when most effective for
7 Manitoba Hydro’s overall system operations.

8
9 In the screening process, imports did not receive a “screened out” outcome for any of the 15
10 characteristics as shown in Table 7.1.

11

12 **7.1.2.2 Resource Technologies Not Selected**

13 The screening process resulted in eliminating the remaining resource technologies that were
14 considered in Table 7.1. The technologies not selected were:

- 15 • Wind - In-Lake Wind
- 16 • Solar – Solar Photovoltaic and Solar Thermal
- 17 • Enhanced Geothermal Systems
- 18 • Coal – Conventional Pulverized Coal and Integrated Gasification Combined Cycle
- 19 • Nuclear Power Plants
- 20 • Biomass – Agricultural Crop Residue and Wood Based Fuel Biomass.

21

22 The following is a brief summary of the key characteristics of the resource technologies that
23 were not selected.

24

25 **In-Lake Wind**

26 In-lake wind shares common attributes with on-shore wind. This resource technology was
27 screened out primarily due to energy costs. In-lake wind costs are significantly higher than land-
28 based alternatives.

1 Development of in-lake wind resources in Manitoba is significantly more technically challenging
2 than on-shore wind due to issues such as winter ice floes. Additional issues include potential
3 adverse impacts affecting existing commercial and recreational lake users. As well, there is a
4 lack of experience within North America in developing in-lake wind resources.

5

6 **Solar Photovoltaic**

7 Solar photovoltaic is an established technology with significant opportunity for potential
8 technological improvement. A good-quality potential solar resource exists within southern
9 Manitoba. This resource technology was screened out because:

- 10 • energy costs for solar photovoltaic were significantly higher than other resource options
11 costs (although costs have recently been trending downwards)
- 12 • solar photovoltaic is an intermittent resource that is highly variable and, as a result of its
13 reliance on direct sunlight, there is potential for significant instantaneous drops in
14 power output due to the unpredictable nature of localized cloud cover.

15

16 **Solar Thermal**

17 Solar thermal is in advanced stages of development and still has a high cost of energy
18 production relative to other resource options. Solar thermal is considered an intermittent
19 resource as it is dependent upon daily weather. It is less intermittent than solar photovoltaic
20 since it is not impacted instantaneously by cloud cover.

21 From a technical perspective, Manitoba peak load occurs in the winter when solar intensity is
22 weak. In addition, peak load can occur after sunset.

23

24 This resource technology was screened out due to the energy costs for solar thermal being
25 significantly higher than other resource options.

1 **Enhanced Geothermal Systems**

2 An enhanced geothermal system is a proven technology but suitable geothermal heat gradients
3 required for these systems remain unproven in Manitoba. As a result, this technology did not
4 advance to the next stage of evaluation. The production of geothermal-based energy utilizes
5 conventional steam-based generation technology but there remain significant technological
6 and economic challenges in drilling to the 2-10 km depth required.

7
8 **Conventional Pulverized Coal**

9 Environment Canada's *Reduction of Carbon Dioxide Emissions from Coal-Fired Generation of*
10 *Electricity Regulations* (2012) established a performance standard for new coal-fired generating
11 units after 2015 of an annual average intensity of 375 tonnes of CO_{2e} per GWh. The Province of
12 Manitoba, under *The Climate Change and Emissions Reductions Act*, is phasing out the use of
13 coal for generation except to support emergency operations. As a result, coal-fired generation
14 as a technology has been eliminated from consideration for the next stage of evaluation.

15
16 **Coal - Integrated Gasification Combined Cycle**

17 Integrated gasification combined cycle is an evolving technology that is technically complex
18 with only a few utility-scale examples constructed in North America. While combustion of coal-
19 derived synthetic gas produces a significantly cleaner air emissions profile, the Province of
20 Manitoba, under the *Climate Change and Emissions Reductions Act*, is phasing out the use of
21 coal for generation except to support emergency operations. As a result, this technology has
22 been eliminated from consideration for the next stage of evaluation.

23
24 **Nuclear Power Plants**

25 Nuclear power plants require high up-front capital investment. The limited operational
26 flexibility and large individual unit-size of nuclear power plants together with their baseload
27 mode of operation, would not integrate well with the relatively small size of Manitoba Hydro's
28 existing system. Nuclear power plant development, based on proven technology, has large

1 individual units typically sized between 600 and 1,200 MW. Nuclear power plants have little
2 operational flexibility resulting in high capacity factors, meaning that there is little opportunity
3 to vary the level of production to suit the needs of the Manitoba system. Although the nuclear
4 industry is addressing this through the development of advanced small sized reactors (less than
5 300 MW unit capacities in size) they have not yet been commercially deployed in North
6 America and will not be for a number of years.

7
8 In addition, *The Manitoba High-Level Radioactive Waste Act* prohibits the long-term storage of
9 high level radioactive waste in Manitoba. As a result, nuclear power plants have been
10 eliminated from further evaluation on the basis of system integration issues and on the basis of
11 the provincial legislation related to the storage of radioactive waste in Manitoba.

12

13 **Agricultural Crop Residue Biomass & Wood-Based Fuel Biomass**

14 Agricultural crop residue biomass and wood-based fuel biomass are adaptations of
15 conventional steam-based generation. Currently, the cost of energy produced from these forms
16 of technology are not yet competitive with other forms of generation and are highly dependent
17 upon the uncertain price of transportation fuels. On this basis, these technologies have been
18 eliminated from consideration for the next stage of evaluation.

19

20 **7.2 Resource Options Screening**

21 The next step in the screening process is the selection of specific resource options from each of
22 the resource technologies identified in Section 7.1.2.1. The process for selecting resource
23 options involves comparing the characteristics of the resource technologies—the results of this
24 comparison identifies the resource options for the next stage of analysis.

25

26 **7.2.1 Additional DSM Screening**

27 Manitoba Hydro’s strategy for DSM involves a continued long-term commitment to pursuing all
28 cost-effective energy efficiency opportunities and to continually monitoring the market for

1 emerging trends and opportunities which may become economically viable. As new
2 opportunities are identified as being economic, these opportunities are included into Manitoba
3 Hydro’s DSM plan (e.g. the recently announced Power Smart Community Geothermal program,
4 which will be added to the next update of Manitoba Hydro’s DSM plan).

5
6 To assist in identifying the available DSM potential in Manitoba, the corporation recently
7 engaged a consultant to undertake a DSM potential study. As the results of this study were not
8 available in time to be incorporated into the 2012 main NFAT analysis, a DSM sensitivity and a
9 DSM stress test are included, based on 2013 planning assumptions and preliminary projections
10 from the DSM Potential Study, in **Chapter 12 – Economic Evaluations - 2013 Update on**
11 **Selected Development Plans**

12
13 As noted in **Chapter 4 – The Need for New Resources**, Section 4.2.2 and provided in **Appendix**
14 **4.3 – Demand Side Management Potential Study**, the DSM Potential Study examines the
15 “market potential” and “achievable potential” of existing energy-efficient technologies which
16 are economic in Manitoba and for those technologies that may be on the horizon. The
17 preliminary high-level projections from the study were used to frame threshold levels of
18 additional DSM over and above the 2012 base DSM forecast. These preliminary thresholds are
19 incorporated into the analysis in **Chapter 12 – Economic Evaluations - 2013 Update on Selected**
20 **Development Plans** as a sensitivity of 1.5 times the base DSM plan, and as a stress test of 4
21 times the DSM base forecast. Table 7.2 shows a comparison of the current approved Power
22 Smart Plan and the final findings of the DSM Potential Study. As shown by Table 7.2 the
23 thresholds incorporated into the analysis presented in **Chapter 12 – Economic Evaluations -**
24 **2013 Update on Selected Development Plans** remain reasonable.

**Needs For and Alternatives To
Chapter 7 – Screening of Manitoba Resource
Options**

1

Table 7.2 THRESHOLDS FOR POTENTIAL ADDITIONAL DSM

	Comparison at Forecast Year 2027/28 (at Meter)			
	GWh	% of Power Smart Plan	MW	% of Power Smart Plan
2013-16 Power Smart Plan (2012/13 – 2027/28)	713	100%	154	100%
DSM Potential Study				
Achievable	1135	159%	255	166%
Market	2915	409%	671	436%

2

3 Caution must be exercised in interpreting the results of a DSM potential study. The projections
4 represent a high-level assessment of the achievable and market potential with market potential
5 representing absolute level of energy and demand savings that are technically feasible,
6 economically attractive assuming the ideal market conditions. These conditions could be
7 characterized by the presence of a focused and coordinated effort across
8 organizations/governments (federal, provincial and utilities) eliminating all material market
9 barriers to adoption, such as product availability and market capacity, product awareness and
10 knowledge, price differentials, etc.—i.e., the probability of these ideal market conditions being
11 present in combination is doubtful and therefore represents a theoretical limit.

12

13 The setting of specific Power Smart targets involves more detailed and market-specific analysis
14 which was beyond the scope of this study. The study does not involve a detailed assessment of
15 each potential energy efficiency opportunity and does not account for the investment or
16 specific strategies required to support the market intervention.

17

18 Insights gathered through the study will need to be further investigated to more specifically
19 define the market and potential associated opportunities, determine the feasibility of the
20 opportunities and the most effective and cost-efficient market intervention strategies to create
21 an effective market change over time. As such, caution must be exercised in using the results of
22 the market potential study for planning purposes: the results of the study should only be used
23 for developing a refined DSM plan.

1 It is recognized that DSM savings are contingent on program participation and do not carry the
2 same degree of certainty that a generation resource provides. While Manitoba Hydro has relied
3 upon DSM to date at the same level of certainty as new generation, this is reasonable provided
4 realistic DSM programming is underlying the targets associated with DSM. It is reasonable to
5 consider this factor in determining the degree to which Manitoba Hydro will rely on DSM
6 targets which may be arbitrary and not based on sound DSM programming.

7

8 **7.2.2 Hydro Resource Options Screening**

9 Manitoba Hydro has identified a total of 8,200 MW of undeveloped renewable hydro-electric
10 potential of varying sizes and technical difficulties remaining within the province. Many of the
11 smaller sites are uneconomic in comparison to other sites as a result of their relative small size
12 and remoteness from the existing transmission system. Manitoba Hydro's cooperation with two
13 major government initiatives has eliminated many other potential hydro-electric sites from
14 further consideration.

15

16 Under the Treaty Land Entitlement Framework Agreement, Manitoba Hydro agreed to restrict
17 its interest to a total of 16 sites along the Nelson, Burntwood and Churchill rivers including
18 three sites on the Hayes River and Wuskwatim, thereby releasing lands around other sites for
19 selection by First Nations toward fulfillment of their treaty entitlements.

20

21 Under the Canadian Heritage Rivers System, which recognizes and conserves rivers of
22 outstanding natural, cultural and recreational heritage, Manitoba Hydro agreed not to pursue
23 development of the three sites on the Hayes River. The 12 remaining sites on the Nelson,
24 Burntwood and Churchill rivers have a hydroelectric potential of 4,700 MW—these sites have
25 been identified as having the highest potential for future development and are listed in Table
26 7.3.

**Needs For and Alternatives To
Chapter 7 – Screening of Manitoba Resource
Options**

1 Hydro-electric generating resources are highly site specific in terms of design, capacity, energy,
2 construction and cost. These factors, as well as a number of other regulatory, technical and
3 environmental considerations, limit the number and location of practical hydro-electric
4 developments within Manitoba. Hydro-electric plants are considered to have high up-front
5 capital costs, low operating costs, require long lead times for development, and can achieve
6 economies of scale if large in size. Hydro-electric plants also tend to provide more significant
7 economic stimulus to Manitoba than many other technologies.

8

9 While all sites included in Table 7.3 contain favourable characteristics for development, not all
10 have been investigated to the same degree. The stage of preparation shown in the table
11 represents the level of investigation and study for individual sites from inventory, feasibility,
12 and conceptual design to pre-investment. Inherent in the individual design concepts and overall
13 range of stages—as defined in **Appendix 7.2 – Range of Resource Options**—are a number of
14 other issues such as environmental concerns, social concerns, economics and system
15 integration.

16

17 The stage of development for a particular resource option is driven by the attractiveness of its
18 characteristics, which includes unit cost. Levelized cost is a significant factor at this stage of the
19 screening process.

20

21 As demonstrated in **Chapter 4 – The Need for New Resources**, new resources are required in
22 2022/23 according to the 2012 planning assumptions. In order to fully approve and develop a
23 resource in time to meet needs and opportunities, only sites suitable in terms of characteristics
24 and stage of preparation are considered for potential use in development plans. Keeyask G.S
25 and Conawapa G.S. are the only two potential hydro-electric sites with suitable characteristics
26 and at a sufficiently advanced stage of preparation.

Needs For and Alternatives To Chapter 7 – Screening of Manitoba Resource Options

1

Table 7.3 HYDRO RESOURCE OPTION CHARACTERISTICS

		Resource Timing		Technical Characteristics		Environmental Characteristics		Economic Characteristics		Considered for Further Evaluation	
		Stage of Preparation	Resource Lead Time (Years)	Nominal Capacity (MW)	Dependable Energy (GW.h)	Flooded Area (km ²)	Wildlife Species of Interest	Base Cost (2014\$ Billion)	Levelized Cost (2014\$/MWh)		
Hydro Resource Options	Keeyask GS	V	7	695	3000	45	Yes	3.5	60	✓	
	Conawapa GS	IV	13	1485	4650	5	Yes	5.7	67	✓	
	Notigi GS*	IV	10	120	650	0	No	1.0	88	✗	
	Gillam Island GS	II	19	1080	3800	12	Yes	7.2	113	✗	
	First Rapids GS	II	14	210	1000	55	Yes	2.1	127	✗	
	Manasan GS	II	14	270	1200	150	Yes	2.9	134	✗	
	Whitemud GS	II	14	310	1000	11	Yes	3.1	146	✗	
	Birthday GS	II	14	380	1100	70	Yes	3.8	161	✗	
	Red Rock GS	II	14	250	800	35	Yes	3.0	170	✗	
	Granville GS	II	14	120	300	11	Yes	1.8	196	✗	
	Early Morning GS	II	14	80	400	12	Yes	1.5	224	✗	
	Bonald GS	I	16	110	300	80	Yes	2.3	289	✗	

Stage I - Inventory Stage II - Feasibility Stage III - Concept Stage IV - Pre-Investment
Stage V - Final Design, Construction & Commissioning

Notes:

Levelized costs are calculated using a real discount rate of 5.05%.

Levelized costs are based on remaining estimated capital costs going forward from June 2014. All costs (incurred or estimated) prior to June 2014 are considered as sunk.

Descriptions of the stages of preparation are included in **Appendix 7.2- Range of Resource Options**

*Although Notigi is identified at a Stage IV— Preparation level, studies were suspended in 2002.

Energy values do not require transmission loss adjustment for supply & demand tables.

2
3
4
5
6
7
8
9
10

11 The following is a summary of the main positive and negative characteristics for the two
12 selected hydro-electric options along with a brief summary of why other sites were not selected
13 for further evaluation at this time.

1 **Keeyask Generating Station**

2 At 695 MW, Keeyask G.S. is the only medium-sized hydro-electric plant available for
3 consideration, and is significantly larger than most other plants but is smaller than Conawapa
4 and Gillam Island. This medium size makes it attractive for balancing the economies of scale
5 with the large increments of new capacity added by very large hydro developments. Developing
6 the site requires a moderate amount of flooding at 45 km² and is located in known sturgeon
7 habitat.

8

9 The Keeyask Project is at an advanced Stage V— Final Design, Construction and Commissioning
10 level of development. For a more detailed project description for Keeyask, see **Chapter 2 –**
11 ***Manitoba Hydro’s Preferred Development Plan Facilities.***

12

13 **Conawapa Generating Station**

14 At 1,485 MW, Conawapa is considered a large generating station and would be the largest
15 generating station within the province if developed. Its large size provides a large amount of
16 excess capacity and would require a more significant upfront investment than other hydro
17 generation alternatives. From a levelized-cost perspective, economies of scale result in
18 Conawapa having the second lowest levelized cost of the hydro options.

19

20 The development of this station results in the flooding of 5.1 km² within the flood plain of its
21 riverbank, but the location is a known sturgeon habitat. At the time of this analysis and based
22 on a 13 year lead time, Conawapa could be in service as early as 2025.

23

24 The Conawapa Project is at an advanced Stage IV—Pre-Investment level of development. For a
25 more detailed project description for Conawapa, see **Chapter 2 – Manitoba Hydro’s Preferred**
26 ***Development Plan Facilities.***

1 Hydro Resource Options Not Selected

2 After considering the characteristics of resource timing, environmental impact, capacity and
3 energy and economic information, nine of the 12 hydro-electric resource options have been
4 screened out on the basis of their higher levelized cost and on the basis of their state of
5 development being at the Stage II– Feasibility level or less.

6

7 The small size of Notigi, combined with a higher levelized cost than that for Keeyask G.S. and
8 Conawapa G.S., results in Notigi receiving no further consideration in this submission.

9

10 At 120 MW, Notigi is considered a small generating station located at the site of the existing
11 Notigi control structure. The primary function of this control structure is to regulate water flows
12 into the Burntwood River. As a result, in the winter the capacity of the plant would be
13 significantly reduced due to declining forebay water levels. The capacity of the plant would also
14 be reduced as tailrace water levels rise due to river ice staging. The combined effect is a
15 reduction of approximately 20 MW or 16% of the plant generating capacity. The resulting
16 capacity provided by Notigi would represent less than two years of load growth.

17

18 The development of the Notigi site, as a project, would have minimal environmental effects as
19 the forebay, transmission access, the road, and all of the civil structures, with the exception of
20 the powerhouse, are already established. As Notigi would retain its primary function as a
21 control structure, there is no expected change to existing operation and therefore no expected
22 environmental effects.

23

24 Stage IV engineering studies for Notigi were initiated as far back as 1999 but were suspended in
25 2002 in order to concentrate efforts on the Wuskwatim, Keeyask, and Pointe du Bois projects.
26 As a result of the engineering and related planning studies being at an early Stage IV level, there
27 is greater uncertainty in the levelized cost estimate for Notigi. The minimum time identified to
28 the earliest in-service date for Notigi is ten years. Given the vintage of the available project

1 information and engineering studies, it is likely that longer than ten years would be required for
2 Notigi's earliest in-service date.

3

4 In future studies, Notigi G.S.— along with other plants on the Burntwood River such as First
5 Rapids and Manasan G.S. — will be evaluated in a development plan which would allow for
6 economies of scale in construction.

7

8 **7.2.3 Natural Gas-Fired Resource Option Screening**

9 In Section 7.1.2 Manitoba Hydro determined that the natural gas-fired generation options
10 suitable for further consideration are SCGT and CCGT.

11

12 Natural gas-fired turbines are flexible, modular units that come in a variety of configurations
13 from a number of manufacturers and there is a large fleet of natural gas turbines world-wide.
14 Their prevalence ensures predictable operating and environmental performance characteristics.
15 Units range in size from very small (less than 1 MW) to very large (more than 400 MW). As fossil
16 fuel-based resources, natural gas-fired turbines emit carbon dioxide and minor amounts of
17 nitrous oxide. Considerations for siting include accessibility to gas supply, water supply and
18 transmission interconnections. Natural gas-fired generation is considered to be a shorter lead
19 time-resource option with lower capital costs, with the majority of the cost related to high fuel-
20 based operating costs.

21

22 Noteworthy decreases in future costs for combustion turbines are not anticipated; however,
23 innovation in the field of combustion turbine generation will lead to more efficient machines
24 that operate at lower heat rates. These efficiency improvements will be achieved through
25 higher cycle pressure ratios, improved turbo-machinery component efficiencies and higher
26 turbine inlet temperatures.

1 For planning purposes Manitoba Hydro considered the following gas turbine configurations,
2 representative of the different types of units that are available, for integration into the existing
3 system:

- 4 • heavy duty SCGT
- 5 • heavy duty CCGT
- 6 • aeroderivative SCGT.

7

8 The following is a summary of the characteristics for each natural gas-fired resource option and
9 how each option would be utilized.

10

11 **Heavy Duty Simple-Cycle Gas Turbine**

12 A heavy duty SCGT would be best suited as an addition to Manitoba Hydro's system when there
13 is a requirement for a capacity increment larger than 200 MW and when the resource is
14 intended to operate infrequently. Typically, heavy duty SCGTs are large units with short lead
15 times (3-5 years), low capital costs and high operational costs. Consequently, an SCGT is best
16 used as a capacity resource when operation is intended to be infrequent, typically less than
17 20% of the total time.

18

19 The heavy duty SCGT specified for planning purposes is the General Electric (GE) 7FA. The GE
20 7FA has a capacity of 209 MW and a mid-efficiency heat rate of 9,906 Btu/kWh (British thermal
21 units/kilowatt-hour). The GE 7FA has been in operation since 1994 and has 740 individual units
22 in operation in both simple and combined cycle configurations, lending confidence to its
23 operation, reliability and maintenance. In the event that development is pursued, actual
24 turbine selection would be based upon its intended operation, design requirements, cost, and
25 availability at the time of purchase.

1 **Heavy Duty Combined Cycle Gas Turbine**

2 A heavy duty CCGT is best suited as an addition to Manitoba Hydro’s system when there is a
3 requirement for a large increment of energy and capacity and when the resource is intended to
4 operate more frequently than a SCGT (typically more than 40% of total time). Typically, CCGTs
5 are large units with short lead times (3-5 years) and have higher capital costs and lower
6 operational costs than SCGTs.

7
8 The heavy duty CCGT specified for planning purposes is the GE 7FA CCGT. The GE 7FA CCGT has
9 a capacity of 308 MW and a high-efficiency heat rate of 6,652 Btu/kWh. In the event that
10 development is pursued, actual turbine selection would be based upon its intended operation,
11 design requirements, cost and availability at the time of purchase.

12

13 **Aeroderivative Simple Cycle Gas Turbine**

14 An aeroderivative gas turbine is best suited as an addition to Manitoba Hydro’s system when
15 there is a requirement for a small increment of capacity and is intended to operate
16 infrequently. Typically, aeroderivative gas turbines are available as small units with short lead
17 times (approximately three years), higher capital costs and higher operational costs than both
18 the simple cycle and combined cycle GE 7FA units. Thus, an aeroderivative SCGT is best used as
19 a capacity resource when the operation is intended to be infrequent or for quick-start and
20 black-start capabilities.

21
22 The aeroderivative SCGT specified for planning purposes is the GE LM6000PH. The GE
23 LM6000PH is based on the CF6 aircraft engine which powers the Boeing 747 aircraft among
24 others. The LM6000PH has a capacity of 47 MW and a mid-efficiency heat rate of 9,475
25 Btu/kWh. The engine has been in industrial operation since 1992 with a current fleet size of
26 1,025 units, lending confidence to its operation, reliability and maintenance. In the event that
27 development is pursued, actual turbine selection would be based upon its intended operation,
28 design requirements, cost, and availability at the time of purchase.

**Needs For and Alternatives To
Chapter 7 – Screening of Manitoba Resource
Options**

1 Table 7.4 summarizes the characteristics of the natural gas-fired resource options used for
2 planning purposes.

Table 7.4 NATURAL GAS-FIRED RESOURCE OPTION CHARACTERISTICS

		Resource Timing		Technical Characteristics							Environmental Characteristics		Economic Characteristics		Considered for Further Evaluation
		Resource Lead Time (Years)		Nominal Capacity (MW)	Dependable Energy (GWh/h)	Heat Rate (mmBTU/MW.h)	Fleet History	Quick Start	GHG Emissions (CO ₂ e/MW.h)	Base Costs (million 2014\$)	Levelized Costs (2014\$/MWh)				
Natural Gas	GE 7FA Heavy Duty CCGT	3-5		308	2460	6652	Yes	No		342	399	75 - 97 ₁	✓		
	GE 7FA Heavy Duty SCGT	3-5		209	1688	9906	Yes	No		506	161	125 - 266 ₂	✓		
	GE LM6000PH Aeroderivative SCGT	3		47	387	9475	Yes	Yes		506	71	163 - 430 ₂	✓		

1 Based on 70% to 35% capacity factor range.

2 Based on 20% to 5% capacity factor range.

Energy values require 10% transmission loss adjustment for supply & demand tables.

7.2.4 Wind Resource Option Screening

In Section 7.1.2 Manitoba Hydro determined through resource technologies screening, that on-shore wind generation is a short lead-time resource option suitable for further consideration. Large areas in southern Manitoba are both environmentally and technologically suitable for several thousand MWs of wind farm development.

Wind resource options are modular and are made up of multiple units that can be installed to closely match energy resource requirements. In the Manitoba Hydro system, a wind resource option is suitable when there is a requirement for energy only, and not capacity, as Manitoba experiences peak demand in winter. Wind generation is assumed to have a zero winter peak capacity due to the intermittent nature of the resource and the fact that the wind generators cannot be expected to operate reliably at temperatures below -30°C, the kind of temperatures which produce Manitoba peak winter load. This subject is further discussed in **Appendix 7.4 - Capacity Value of Wind Resources**. Wind turbine manufacturers have considered operations in extreme temperatures and have defined a cold climate as less than -20°C for more than one hour in nine days per year. Manufacturers' cold weather packages have been developed and

1 can extend the operational range of a turbine typically down to normal ambient temperatures
2 of -30°C.

3

4 Wind power cannot be reliably controlled due to fluctuations in wind speed; because of its
5 intermittency wind power alone cannot be relied upon to produce electricity when needed.

6 Other issues typically associated with a wind resource include extremes of wind speed (too low
7 or too high), extreme wind gusts, extreme wind shear, and extreme wind turbulence, as well as

8 lack of wind for periods of time. To accommodate a wind resource, other dispatchable
9 resources that have fast energy ramp-up times such as hydro-electric and natural gas-fired

10 generation are required to back-up wind generation when wind energy production is reduced
11 or not available.

12

13 In North America, recent on-shore wind development projects under construction have
14 predominantly utilized wind turbines ranging from 1.5 to 3.0 MW in size with hub heights

15 ranging from 80 to 120 metres. The trend over the past decade has seen the increased use of
16 taller wind towers and turbine units with larger capacity ratings, resulting in improved

17 performance as measured by increases in capacity factor. Evolving trends and factors make it
18 difficult to accurately predict which individual wind turbine unit sizes and types may be utilized

19 in the future. In addition, industry forecasts to 2030 anticipate a 45% increase in energy output
20 from wind turbines, assuming that material costs decrease by 10% in real terms from current

21 levels.

22

23 Wind speed is the most important factor affecting the production of wind energy. Therefore, it
24 is desirable to locate a wind project where the average annual wind speed is as high as possible.

25 It is assumed that the best wind resource locations would be developed first, proceeding to
26 progressively less windy locations as the number of developments increase over time. For

27 planning purposes, annual energy projections are estimated through statistical wind resource
28 assessments and operating history. An average annual capacity factor of 40% is assumed for all

**Needs For and Alternatives To
Chapter 7 – Screening of Manitoba Resource
Options**

1 future wind farm developments in southern Manitoba and 85% of the 40% is assumed to be
2 dependable wind energy.

3
4 Manitoba Hydro adopted the 85% factor for determining dependable wind generation based on
5 statistical analysis of wind records for extended periods of time in other jurisdictions. The
6 standard that was adopted required that the dependable energy could be achieved in 19 years
7 out of 20. It is estimated that each year there is a 5% chance that actual annual generation will
8 be less than the 85% level. The five percentile probability is the industry standard for
9 determining the dependable energy of wind generation.

10
11 Southern Manitoba's wind resource characteristics are well understood and, for the purposes
12 of modeling and evaluating wind farm developments, can be applied to a generic wind farm.
13 Thus, a generic 65 MW wind farm was created for use in future assessments and evaluations
14 without the need for defining the location, the make, the number or the size of individual
15 towers required. A 65 MW capacity development is a reasonably sized wind farm that can
16 benefit from economies of scale and is also approximately equal to the estimated provincial
17 annual load growth for energy. In order to simplify modeling and evaluations at this stage of
18 planning, it was assumed that all additional wind developments would be owned and operated
19 by Manitoba Hydro.

20
21 Table 7.5 summarizes the characteristics of the wind resource option used for planning
22 purposes.

**Needs For and Alternatives To
Chapter 7 – Screening of Manitoba Resource
Options**

1

Table 7.5 ON-SHORE WIND RESOURCE OPTION CHARACTERISTICS

		Resource Timing	Resource Lead Time (Years)	Technical Characteristics			Environmental Characteristics			Economic Characteristics		Considered for Further Evaluation
				Nominal Capacity (MW)	Winter Capacity (MW)	Dependable Energy (GW.h)	Capacity Factor	Wildlife Species of Interest	Base Costs (million 2014\$)	Levelized Costs (2014\$)/MWh		
Wind	Generic Wind Farm	3-5	65	0	194	40%	Yes	163	82	✓		

2

3 Note: Energy values require 10% transmission loss adjustment for supply & demand tables.

4

5 **7.2.5 Imports**

6 For planning purposes, imports are an option to meet either capacity or energy needs. Given
7 Manitoba Hydro’s strong connection to the large U.S. market, imports for both capacity and
8 energy needs are available with short lead times and are available for various durations to meet
9 short-term and long-term requirements.

10

11 When considering imports for capacity purposes, a critical consideration is that Manitoba
12 experiences a winter peak demand while most U.S. utilities have their peak demand during the
13 summer season. This means that there is likely to be a large pool of surplus U.S. capacity
14 available to Manitoba Hydro in the winter season if suitable transmission arrangements can be
15 made on a firm basis for the delivery of energy associated with the capacity.

16

17 Generally Manitoba Hydro has entered into capacity exchange arrangements with U.S.
18 suppliers to acquire winter capacity at no cost. In exchange for the rights to winter capacity,
19 Manitoba Hydro agrees to supply an equivalent amount of capacity to the supplying utility
20 during the summer season: i.e., a seasonal diversity arrangement. If existing firm import and
21 export transmission exists between Manitoba Hydro and the U.S. utility, both companies can
22 meet their capacity needs with no capital expenditures. If there is insufficient firm transmission,

**Needs For and Alternatives To
Chapter 7 – Screening of Manitoba Resource
Options**

1 then it would be cost-effective to build or buy the necessary transmission service when the cost
2 of the transmission service is less than the cost of acquiring a capacity resource.

3

4 When considering imports for dependable energy requirements, a critical consideration is
5 whether the supplying region has surplus energy available during the period when Manitoba
6 Hydro is experiencing dependable flow conditions. For example, because Saskatchewan and
7 northwestern Ontario share the same watersheds and have significant hydro resources on the
8 same river systems as Manitoba Hydro it is extremely likely that these regions will be short of
9 energy during dependable flow conditions. Conversely, because hydro is a very small
10 component of the generation fleet in the region of the U.S. from which Manitoba Hydro
11 purchases energy (1% of total annual generation), shared drought conditions in Manitoba
12 Hydro's watersheds and those of the U.S. Midwest will not noticeably reduce the supply of
13 energy available for purchase by Manitoba Hydro. Even severe drought conditions extending
14 beyond Manitoba and into the U.S. Midwest that potentially impact the supply of energy by
15 affecting cooling or boiler makeup water requirements of U.S. Midwest thermal generating
16 stations would not be expected to have a material impact in the overall availability of energy
17 for purchase.

18

19 Manitoba Hydro can access the supply of surplus energy through market purchases and energy
20 and/or capacity contracts. Firm transmission service is required to ensure the energy can be
21 delivered to Manitoba on a firm basis.

22

23 Under seasonal diversity agreements, the supplier not only agrees to provide winter capacity
24 but also agrees to provide winter energy and may provide summer energy if it is available
25 during off-peak periods. If an energy agreement is not associated with capacity, energy is not
26 guaranteed for any particular hour because it may be required to serve the supplier's firm load
27 obligations. To the extent that the supplier has surplus energy, the agreement makes the
28 energy available to the other party. Manitoba Hydro has a 500 MW import agreement with

1 Northern States Power which provides access to energy from the MISO market throughout the
2 year on firm transmission service.

3
4 Although Manitoba Hydro has access to large quantities of energy under contract, there are
5 limitations to the amount of imports that can be relied upon for planning purposes. As
6 described in more detail in **Appendix 4.1 – Manitoba Hydro Generation Planning Criteria**,
7 Manitoba Hydro’s long-term firm import limit on the existing transmission lines from the U.S. is
8 700 MW. This import limit will not change until new transmission interconnections are built or
9 existing transmission interconnections are upgraded. Manitoba Hydro’s Preferred Development
10 Plan includes a new interconnection with additional import capability of 750 MW.

11
12 Generation from the MISO market, on average across all generation types, results in significant
13 amounts of CO₂ and other hazardous air emissions on a per unit (MWh) basis. As explained in
14 **Chapter 3 – Trends and Factors Influencing North American Electricity Supply**, the MISO region
15 is coal-dominated, generating 75% of its electrical energy from coal in 2011, while natural gas-
16 fired and oil generation represents 5%, wind generation 5%, and nuclear generation 13%. The
17 share of energy generated using coal in the U.S. is on the decline. Coal-fired generation last
18 provided a 50% share across the U.S. in 2005 and is expected to be 40% in 2013 according to
19 the U.S. Department of Energy’s Energy Information Administration (DOE EIA). In the absence
20 of additional stringent coal regulations or very high carbon prices, the EIA is still projecting coal
21 to generate a significant proportion of electricity within U.S. and particularly in the Midwest
22 through 2030.

23
24 As discussed in **Chapter 5 – The Manitoba Hydro System, Interconnections and Export**
25 **Markets**, Manitoba Hydro’s imports (and exports) have implications on the dispatch of
26 resources in the MISO region. Based on MISO Independent Market Monitor’s 2011 annual
27 report, coal was on the margin 93% of all hours in the year. Natural gas was the only other

**Needs For and Alternatives To
Chapter 7 – Screening of Manitoba Resource
Options**

1 significant marginal fuel, on the margin 23% of the time. (Due to transmission constraints it is
2 possible for more than one fuel to be on the margin in any particular hour).

3

4 Coal generation GHG emissions are typically on the order of 0.9 to 1.1 tonnes CO₂ /MWh while
5 natural gas can range from about 0.3 to 0.8 tonnes CO₂/MWh depending on the specific
6 technology and its efficiency. Manitoba Hydro currently assumes that its exports displace and
7 its imports result in 0.75 tonnes CO₂/MWh.

8

9 This reflects a marginal generation mix of various fossil-fuels and technologies. Given that the
10 current marginal generation remains primarily coal (at an emission rate of about 1 tonne
11 CO₂/MWh) the 0.75 tonnes CO₂/MWh factor used by Manitoba Hydro is considered to
12 underestimate both the emissions displaced by exports and the emissions caused by imports.
13 Since Manitoba Hydro is typically a large net exporter, this assumption is considered
14 conservative in that it underestimates the emission displacement benefit. While Manitoba
15 Hydro does not forecast the annual marginal export displacements, it expects that as coal units
16 retire and more natural gas generation is built, the marginal emission factor should decrease
17 over time.

18

19 Manitoba Hydro does not have firm import transmission with either Ontario or Saskatchewan
20 and, as such, does not plan on firm imports from these markets to address the resource
21 diversity issue discussed above.

22

23 As mentioned previously, for planning purposes, imports have to date represented in the order
24 of 10% of Manitoba Hydro's total supply under low flow or dependable flow conditions. The
25 approximate proportion of imports associated with Manitoba Hydro's Preferred Development
26 Plan is expected to remain generally the same.

1 Since Manitoba Hydro generally has surplus energy available and cannot predict when it may
2 need to purchase energy, Manitoba Hydro does not contract for fixed blocks of fixed-price
3 electricity imports. Rather, the arrangements made with suppliers provide Manitoba Hydro
4 with the assurance that the energy will be there when needed but also with the flexibility to
5 buy it when most economical, utilizing the storage capability of the hydraulic system to reshape
6 the supply to serve load requirements. When Manitoba Hydro enters a drought period, in
7 which purchased power and a fixed price and delivery schedule are desired, those
8 arrangements can be made at that time.

9

10 **7.3 Summary of Selected Resource Options**

11 Table 7.6 presents an overview of the key technical, environmental, socio-economic/provincial
12 and economic characteristics of the resource options selected in Section 7.2. These resource
13 options are incorporated into the development plans which are presented in ***Chapter 8 –***
14 ***Determination and Description of Development Plans.***

Table 7.6 SELECTED RESOURCE OPTIONS CHARACTERISTICS

Resource		DSM	Keeyask	Conawapa	Wind	GE 7FA Heavy Duty CCGT	GE 7FA Heavy Duty SCGT	GE LM 6000PH Aeroderivative SCGT	Imports	
Technical	Fuel Type	-	Water	Water	Air	Natural Gas	Natural Gas	Natural Gas	Predominantly Thermal	
	Renewable	Yes	Yes	Yes	Yes	No	No	No	No	
	Dispatchability	No	Yes	Yes	No	Yes	Yes	Yes	Yes	
	Mode of Operation	Must Take	Baseload & Peaking	Modified Run-of-River	Must Take	Intermediate & Peaking (70-35% capacity factor)	Peaking (20-5% capacity factor)	Peaking (20-5% capacity factor)	Flexible	
	Asset Life	Variable	67 years	67 years	20 years	30 years	30 years	30 years	Not Applicable	
	Resource Lead Time	Variable	7 years	13 years	3 years	3 - 5 years	3 - 5 years	3 years	Not Applicable	
	Transmission Length	-	38 Km	7 Km	Avg. 29 Km	0 Km (First Plant)	0 Km (First Plant)	0 Km (First Plant)	0 Km	
	Capacity at Plant	Nominal	-	695 MW	1485 MW	65 MW	308 MW	209 MW	47 MW	Up to Transmission Interconnection Limits
Net Winter Peak		-	630 MW	1300 MW	0 MW	325 MW	223 MW	50 MW	Up to Transmission Interconnection Limits	
Environmental	Air Impacts	GHG Emission Intensity Plant Operations	None	Negligible	Negligible	Negligible	342 t CO ₂ e/GW.h	506 t CO ₂ e/GW.h	506 t CO ₂ e/GW.h	≈ 750 t CO ₂ e/GW.h
		Regional GHG Disp. Intensity Potential	≈ 750 t CO ₂ e/GW.h	≈ 750 t CO ₂ e/GW.h	≈ 750 t CO ₂ e/GW.h	≈ 750 t CO ₂ e/GW.h	≈ 408 t CO ₂ e/GW.h	≈ 244 t CO ₂ e/GW.h	≈ 244 t CO ₂ e/GW.h	-
		NOx Emissions Intensity	-	-	-	-	100 kg NOx/GW.h	150 kg NOx/GW.h	230 kg NOx/GW.h	Not Determined
	Land Impacts	GS Footprint	0 ha	214 ha	164 ha	≈ 10 - 20 ha	≈ 3 ha	≈ 2 ha	≈ 1 ha	0 ha
		Flooded Area	0 ha	4,463 ha	507 ha	0 ha	0 ha	0 ha	0 ha	0 ha
		Additional Impacted Area	0 ha	9,302 ha	1,381 ha	≈ 990 - 2,980 ha	0 ha	0 ha	0 ha	0 ha
		Total Impacted Area	0 ha	13,979 ha	2,052 ha	≈ 1,000 - 3,000 ha	≈ 3 ha	≈ 2 ha	≈ 1 ha	0 ha
	Water Impacts	Water Consumption	-	Domestic Needs Only	Domestic Needs Only	Domestic Needs Only	≈ 900 m ³ /GW.h	Domestic Needs Only	Domestic Needs Only	-
		Water Quality	-	Erosion & Mercury	Negligible	None	Negligible	None	None	-
		Water Regime	-	Regulated Operating Range	Regulated Operating Range	None	Negligible	None	None	-
	Wildlife Species of Interest	Aquatic	-	Lake Sturgeon Habitat	Lake Sturgeon Habitat	None	Negligible	None	None	-
		Terrestrial	-	Caribou Habitat	Caribou Habitat	Negligible	Negligible	Negligible	Negligible	-
		Avian	-	Nesting Habitat	Negligible	Bird & Bat Collisions	Negligible	Negligible	Negligible	-
Socio-Economic/Provincial	Generic Tech. Rating	Health Concerns	-	Very Low	Very Low	Low	Low	Low	Low	-
		Safety Concerns	-	Medium	Medium	Very Low	High	High	High	-
	MB Business Opportunities (% of capital spent in MB)		100%	53%	46%	18%	30%	17%	17%	-
	Employment	Direct Construction	Program Dependent	4480 Person-Years	6650 Person-Years	35 to 80 Person-Years	329 Person-Years	116 Person-Years	65 Person-Years	-
		At Northern Work Sites	Program Dependent	94%	94%	0%	0%	0%	0%	-
		Permanent O&M	Minimal	58 FTE	61 FTE	4 to 8 FTE	94 FTE (for 1 to 2 plants at site)	52 FTE (for 1 to 4 plants at site)	52 FTE (for 1 to 4 plants at site)	-
		At Northern Work Sites	0%	100%	100%	0%	0%	0%	0%	-
	Royalties/Taxes (2014\$)	Water Rentals	-	\$9.0 M/year	\$12.8 M/year	-	-	-	-	-
		Capital Taxes	Program Dependent	\$17.3 M/year	\$28.6 M/year	\$0.8 M/year	\$2.0 M/year	\$0.8 M/year	\$0.4 M/year	-
		Guarantee Fees	Program Dependent	\$27.7 M/year	\$45.8 M/year	Potential for \$1.3 M/year	\$3.2 M/year	\$1.3 M/year	\$0.6 M/year	-
Other		-	-	Grants-in-lieu of taxes	Land Rentals, Grants-in-lieu of taxes	Grants-in-lieu of taxes	Grants-in-lieu of taxes	Grants-in-lieu of taxes	-	
Nearby Population Centers		-	Fox Lake CN, Gillam, Tataskweyak CN, Thompson, War Lake FN, York Factory FN	Fox Lake CN, Gillam, Shamattawa FN, Tataskweyak CN, War Lake FN, York Factory FN	Southwest & South-central Manitoba	Brandon, Southern centre near pipeline	Brandon, Southern centre near pipeline	Brandon, Southern centre near pipeline	-	
Economic	Levelized Cost (2014\$)	Program Dependent	\$60/MW.h	\$67/MW.h	\$86/MW.h	\$75 - 97/MW.h	\$125 - 266/MW.h	\$163 - 430/MW.h	Projected Market Prices	